

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.40	2.06	45.29	1.22	19.75	9.69	1.35	80695.53
1	8.24	6.78	53.29	1.10	20.33	9.86	1.36	80948.67
2	8.73	4.15	48.72	1.51	17.32	10.30	1.34	78865.11
3	8.18	3.50	48.65	1.35	18.66	10.19	1.32	78929.32
4	8.75	3.60	49.55	1.46	18.38	10.33	1.31	79425.76
5	8.88	5.89	59.34	0.70	19.38	10.29	1.29	80926.42
6	11.58	4.90	51.88	1.89	17.27	10.51	1.29	79713.01
7	7.92	4.45	48.51	1.70	17.34	10.55	1.30	80215.59
8	8.06	4.99	53.57	1.73	16.91	10.61	1.33	78896.99
9	7.65	4.41	54.53	1.24	17.56	10.53	1.36	80413.10
10	9.16	4.58	53.16	1.76	17.18	10.67	1.36	80543.99
11	8.13	4.54	57.65	0.83	18.73	10.39	1.35	79368.44
12	12.34	5.55	45.37	1.86	17.66	10.34	1.36	79990.75
13	9.09	5.67	50.23	1.83	17.20	10.61	1.34	78366.46
14	6.66	1.57	53.63	1.94	16.76	11.00	1.36	79443.30
15	7.52	1.84	53.88	2.20	16.11	11.14	1.38	78375.60
16	8.19	2.31	53.67	1.84	16.57	11.06	1.36	78544.78
17	8.63	1.48	54.38	1.72	17.48	10.80	1.37	79786.85
18	7.98	1.61	50.54	1.81	16.76	10.74	1.37	79218.88
19	5.96	1.82	55.70	1.68	17.13	10.79	1.34	79037.54
20	5.64	1.83	58.19	0.95	18.33	10.91	1.33	76410.60
21	5.64	2.65	48.65	0.98	19.24	9.93	1.36	80226.16
22	8.42	2.75	42.45	1.60	18.21	10.12	1.34	78511.43
23	8.35	1.67	40.99	1.31	18.22	10.04	1.34	78470.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.30	3.52	51.33	1.51	17.85	10.48	1.34	79388.55
最 大 值	12.34	6.78	59.34	2.20	20.33	11.14	1.39	80948.67
發生時間	12	1	5	15	1	15		1
最 小 值	5.64	1.48	40.99	0.70	16.11	9.69	1.29	76410.60
發生時間	20	17	23	5	15	0		20
零點偏移(率)	-0.35 %	-0.00 %	-0.01 %	-0.00 %		-0.04		0.30 %
全幅偏移(率)	-0.22 %	1.36 %	0.08 %	0.18 %		-0.28		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月23日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.01	2.78	60.03	1.34	17.96	10.44	1.07	83756.94
1	7.97	3.02	59.04	1.93	16.40	10.92	1.10	84551.88
2	9.46	2.93	48.46	2.46	15.49	11.23	1.10	79087.07
3	7.49	2.93	50.50	1.64	17.14	10.87	1.10	82012.24
4	9.81	3.07	46.66	1.86	16.80	10.87	1.09	83725.30
5	9.46	2.98	47.81	1.59	17.01	10.86	1.08	82944.12
6	8.72	3.52	49.07	2.63	16.34	10.99	1.06	81668.04
7	6.63	2.72	51.57	2.03	15.87	11.05	1.08	80118.99
8	9.65	2.92	48.67	2.43	16.04	10.88	1.10	81782.74
9	10.27	2.89	49.00	1.96	16.31	10.88	1.07	83051.40
10	8.75	3.14	47.14	2.60	16.55	10.92	1.08	80593.24
11	9.29	2.94	47.27	2.52	15.93	10.89	1.09	81690.40
12	5.61	6.09	49.59	2.53	14.92	11.18	1.07	79528.35
13	5.93	8.79	52.95	2.82	14.72	10.95	1.09	80290.66
14	5.52	5.80	55.96	2.36	15.40	11.15	1.09	74635.45
15	4.06	1.39	49.34	2.47	14.80	12.15	1.09	73280.19
16	2.10	5.51	47.16	3.19	15.81	11.48	1.10	79597.55
17	1.67	1.55	53.76	3.10	14.90	11.23	1.06	81617.34
18	0.00	6.68	50.85	1.82	15.52	11.72	1.08	77995.46
19	3.26	3.48	48.46	2.92	15.81	11.21	1.08	79749.82
20	4.55	2.18	47.93	1.81	15.60	10.76	1.06	82075.73
21	4.74	7.59	46.57	1.66	15.56	10.78	1.06	80049.79
22	5.62	14.61	42.56	2.12	14.61	10.85	1.08	78584.65
23	5.21	2.61	33.01	1.62	16.28	10.35	1.09	76191.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.41	4.25	49.31	2.23	15.91	11.03	1.08	80357.46
最 大 值	10.27	14.61	60.03	3.19	17.96	12.15	1.14	84551.88
發生時間	9	22	0	16	0	15		1
最 小 值	0.00	1.39	33.01	1.34	14.61	10.35	1.05	73280.19
發生時間	18	15	23	0	22	23		15
零點偏移(率)	-0.05 %	-0.01 %	-0.04 %	0.00 %		-0.14		0.10 %
全幅偏移(率)	0.14 %	0.05 %	0.01 %	0.40 %		-0.29		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月23日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	4.36	2.67	42.62	0.26	17.68	10.30	1.57	78111.18
1	0.40	1.75	49.50	0.27	18.51	10.43	1.57	75319.61
2	5.09	1.59	52.52	0.44	17.18	10.30	1.56	83362.64
3	7.92	2.62	54.42	0.54	16.97	10.30	1.57	82701.53
4	5.69	1.66	56.04	0.43	17.82	10.14	1.56	82209.66
5	6.41	4.68	53.64	0.53	17.28	10.23	1.55	83336.33
6	8.86	6.61	56.57	0.54	16.88	10.47	1.55	81047.12
7	13.08	5.22	52.57	1.19	17.11	10.35	1.56	80569.82
8	5.18	2.57	56.98	0.78	15.80	10.64	1.58	79402.34
9	7.59	8.60	56.30	0.54	17.14	10.23	1.58	82275.36
10	9.29	6.01	58.04	0.78	16.55	10.50	1.57	81542.79
11	5.39	5.01	55.94	0.62	16.37	10.56	1.57	79723.44
12	5.49	3.84	54.20	0.59	16.20	10.53	1.55	79851.57
13	3.20	1.44	60.70	0.60	15.38	10.91	1.55	79053.64
14	2.59	2.56	55.71	1.47	13.99	11.07	1.54	75329.74
15	1.07	2.66	51.17	0.61	16.12	10.52	1.53	76111.29
16	2.21	3.84	47.49	0.26	17.05	10.13	1.55	78754.18
17	3.77	2.04	44.80	0.42	16.33	10.44	1.53	78062.40
18	0.60	1.77	60.14	0.28	17.33	10.97	1.53	74783.99
19	4.58	4.30	50.20	0.64	16.44	10.57	1.55	79193.69
20	6.86	3.73	55.59	0.72	16.24	10.64	1.53	79834.08
21	6.27	4.52	56.21	0.59	16.89	10.68	1.55	81055.27
22	8.24	7.01	52.65	0.38	17.97	10.15	1.55	82288.60
23	5.90	4.20	50.44	0.52	16.52	10.42	1.53	78645.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.42	3.79	53.52	0.58	16.74	10.48	1.55	79690.22
最 大 值	13.08	8.60	60.70	1.47	18.51	11.07	1.60	83362.64
發生時間	7	9	13	14	1	14		2
最 小 值	0.40	1.44	42.62	0.26	13.99	10.13	1.52	74783.99
發生時間	1	13	0	0	14	16		18
零點偏移(率)	-0.07 %	-0.01 %	-0.04 %	0.00 %		-0.14		-0.10 %
全幅偏移(率)	0.02 %	0.05 %	-0.40 %	-0.06 %		-0.34		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								