

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年08月14日

報表日期: 113年08月14日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	5.04	3.08	58.68	0.57	19.62	11.22	0.98	82039.72
1	1.16	3.28	58.13	0.54	20.12	11.55	0.97	79157.64
2	5.30	3.44	43.76	1.14	18.39	11.26	0.97	83214.49
3	6.44	3.88	48.02	2.11	16.45	11.76	0.97	80956.23
4	4.56	7.28	49.36	1.34	17.46	11.54	0.97	81812.07
5	7.42	2.97	48.73	1.99	16.89	11.43	0.97	85524.25
6	4.00	2.79	49.81	1.76	17.72	11.41	0.97	81803.52
7	3.87	2.63	51.97	1.40	17.32	11.61	0.97	81040.18
8	3.12	2.97	55.03	0.99	17.71	11.43	0.99	82111.33
9	2.08	3.90	45.78	1.61	16.56	11.67	0.99	78901.62
10	2.71	9.75	27.67	1.98	16.12	11.01	0.96	73807.67
11	4.16	1.64	45.40	1.78	15.37	12.02	0.98	72820.42
12	3.98	3.42	48.86	1.43	16.79	11.73	0.99	76964.38
13	3.93	3.47	47.56	1.92	15.81	12.05	0.97	73648.83
14	11.44	5.07	50.05	2.13	16.70	11.79	0.99	75353.67
15	7.51	3.44	38.69	2.21	15.77	11.71	0.97	72799.86
16	6.43	2.92	44.09	1.85	16.38	11.32	0.97	80315.47
17	4.71	2.70	57.89	0.90	18.07	11.27	0.97	83155.57
18	7.42	2.90	61.03	2.08	16.36	11.67	0.97	81562.61
19	12.94	2.53	62.86	2.37	17.75	11.36	0.98	83348.06
20	8.09	3.83	56.89	2.97	16.28	11.75	0.98	81166.90
21	8.62	7.66	60.46	1.40	17.06	11.59	0.97	82314.20
22	6.44	6.94	58.98	1.84	15.63	11.89	0.97	80624.44
23	5.41	6.98	50.75	1.79	15.70	11.85	0.97	80902.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.70	4.14	50.85	1.67	17.00	11.58	0.97	79806.06
最 大 值	12.94	9.75	62.86	2.97	20.12	12.05	1.01	85524.25
發生時間	19	10	19	20	1	13		5
最 小 值	1.16	1.64	27.67	0.54	15.37	11.01	0.94	72799.86
發生時間	1	11	10	1	11	10		15
零點偏移(率)	-0.07 %	0.00 %	-0.01 %	0.00 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		-0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月14日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.89	5.84	53.65	0.73	17.65	10.88	1.23	78986.03
1	7.10	5.04	51.13	0.79	17.40	10.96	1.25	77067.90
2	12.03	3.97	50.78	0.98	16.19	10.94	1.25	75700.61
3	7.71	4.06	50.48	1.10	15.55	11.07	1.23	75678.92
4	5.18	4.01	54.24	0.76	15.73	11.28	1.23	75202.47
5	13.07	3.90	55.54	1.35	15.40	11.17	1.23	75594.99
6	11.13	4.68	58.07	0.89	16.49	11.05	1.23	77004.90
7	10.93	3.37	51.35	0.88	15.53	11.35	1.18	74439.25
8	6.93	2.58	58.15	0.82	16.08	11.20	1.15	77412.33
9	3.73	4.84	46.04	1.36	14.64	11.45	1.16	74590.57
10	4.92	4.21	46.27	1.45	14.25	11.70	1.16	72199.93
11	8.68	2.92	51.66	1.01	15.57	11.58	1.16	73659.91
12	5.80	2.93	49.23	1.11	14.94	11.84	1.22	72615.20
13	15.05	3.20	54.08	2.76	14.40	12.15	1.18	71985.85
14	14.67	2.72	54.80	1.51	15.07	11.93	1.16	75828.08
15	9.92	2.92	50.12	1.37	14.47	12.00	1.18	73913.69
16	11.20	2.11	48.58	1.62	15.81	11.16	1.21	79555.02
17	13.14	2.14	54.08	1.82	16.37	11.01	1.23	80415.09
18	11.75	2.15	54.78	4.39	16.84	11.07	1.23	79824.93
19	3.12	2.51	53.90	2.70	15.27	11.50	1.23	77061.25
20	3.22	7.55	53.37	3.43	13.86	11.58	1.21	75556.49
21	4.63	3.00	52.36	3.48	14.01	11.52	1.21	76749.98
22	3.24	2.43	57.43	4.19	13.39	11.64	1.20	76996.02
23	7.14	4.43	50.11	2.92	14.15	11.56	1.15	75230.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.42	3.65	52.51	1.81	15.38	11.40	1.20	75969.58
最 大 值	15.05	7.55	58.15	4.39	17.65	12.15	1.26	80415.09
發生時間	13	20	8	18	0	13		17
最 小 值	3.12	2.11	46.04	0.73	13.39	10.88	1.13	71985.85
發生時間	19	16	9	0	22	0		13
零點偏移(率)	-0.06 %	0.00 %	-0.03 %	-0.00 %		-0.07		0.00 %
全幅偏移(率)	0.02 %	0.02 %	-0.14 %	0.01 %		0.23		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								