

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月25日

報表日期: 114年07月25日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.60	9.19	63.47	2.84	16.78	11.77	1.35	78837.94
1	5.55	10.20	59.83	2.05	18.27	11.75	1.37	78010.53
2	9.36	9.74	57.10	3.42	15.31	11.92	1.38	78985.49
3	8.21	9.22	57.73	3.27	16.67	11.62	1.35	80512.73
4	8.85	9.52	59.86	2.87	16.55	12.00	1.34	77228.56
5	4.00	9.07	57.99	2.64	16.79	11.64	1.35	77627.26
6	4.48	9.07	58.67	3.47	16.09	11.81	1.36	79052.11
7	8.07	9.18	65.04	3.49	16.49	11.97	1.37	77393.04
8	6.90	9.07	57.30	3.25	17.07	11.75	1.37	78666.88
9	6.49	10.29	54.06	3.68	15.94	11.81	1.36	79258.12
10	5.55	8.99	56.92	3.23	16.69	11.73	1.36	79350.16
11	9.24	9.01	54.67	3.93	16.68	11.87	1.37	78211.71
12	6.84	8.99	68.27	3.49	16.39	11.81	1.38	79109.92
13	7.37	9.22	63.20	3.94	15.89	11.86	1.35	79165.85
14	10.92	9.79	62.99	4.83	14.67	12.42	1.36	74827.47
15	7.61	9.73	67.13	3.96	15.96	12.23	1.36	76557.72
16	8.43	10.20	61.93	2.65	16.38	11.79	1.34	79488.10
17	7.43	10.74	54.64	1.10	17.09	11.80	1.36	78890.59
18	8.35	9.51	63.63	0.81	17.96	11.54	1.39	80198.61
19	8.26	8.91	58.63	1.03	17.34	11.40	1.38	81120.07
20	7.59	8.99	49.70	0.80	17.98	11.28	1.36	82106.13
21	8.95	8.97	55.05	2.43	17.87	11.51	1.34	80592.23
22	8.24	8.98	55.67	3.14	17.28	11.62	1.37	79737.55
23	9.21	9.25	57.64	2.91	17.07	11.80	1.38	78583.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.69	9.41	59.21	2.88	16.72	11.78	1.36	78896.36
最 大 值	10.92	10.74	68.27	4.83	18.27	12.42	1.39	82106.13
發生時間	14	17	12	14	1	14		20
最 小 值	4.00	8.91	49.70	0.80	14.67	11.28	1.34	74827.47
發生時間	5	19	20	20	14	20		14
零點偏移(率)	0.00 %	-0.01 %	-0.20 %	-0.09 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.03 %	0.00 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月25日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	8.25	54.30	1.08	18.95	10.69	1.02	80842.64
1	9.44	8.51	57.41	1.34	19.44	10.85	1.02	79686.25
2	8.84	8.22	52.29	1.48	18.40	10.64	1.00	81506.70
3	8.71	9.20	61.22	2.07	17.67	10.87	0.98	80742.43
4	12.07	8.74	57.28	2.43	17.77	10.49	0.99	81137.93
5	8.07	8.51	57.33	2.11	18.22	10.31	1.00	82637.16
6	7.14	7.88	53.03	1.24	19.26	10.23	1.01	84516.58
7	10.27	7.88	60.52	1.49	18.38	10.66	1.02	83595.07
8	8.64	8.73	56.67	1.78	17.98	10.79	1.02	82839.80
9	8.98	8.58	62.46	2.45	17.40	11.17	1.01	79850.02
10	7.97	8.07	56.38	2.19	17.87	10.80	1.02	78770.01
11	8.50	8.59	51.52	2.54	17.21	10.67	1.02	79429.47
12	9.79	9.04	58.52	2.34	18.20	10.62	1.01	82557.40
13	14.24	18.02	61.91	3.76	15.74	11.41	0.99	79713.06
14	9.93	10.06	58.18	3.65	15.45	11.42	0.99	79144.08
15	8.77	7.69	58.47	2.35	17.48	11.08	1.02	80984.25
16	10.04	9.12	61.52	2.10	17.63	10.99	1.02	82451.86
17	8.79	10.14	60.45	2.84	16.53	11.12	0.99	81414.05
18	8.56	8.23	59.96	2.80	17.43	11.00	0.99	80776.37
19	7.76	7.85	61.08	1.39	20.16	10.16	1.02	83661.79
20	9.31	8.96	57.68	1.29	20.39	9.87	1.02	85232.95
21	8.43	7.95	58.65	1.31	19.93	10.03	1.00	86453.77
22	8.74	7.81	59.57	1.25	19.43	10.22	1.00	86954.49
23	8.79	8.19	58.01	1.39	18.71	10.80	1.00	81792.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.16	8.93	58.10	2.03	18.15	10.70	1.01	81945.45
最 大 值	14.24	18.02	62.46	3.76	20.39	11.42	1.04	86954.49
發生時間	13	13	9	13	20	14		22
最 小 值	7.14	7.69	51.52	1.08	15.45	9.87	0.97	78770.01
發生時間	6	15	11	0	14	20		10
零點偏移(率)	0.00 %	-0.00 %	-0.24 %	-0.06 %		-0.08		0.00 %
全幅偏移(率)	0.14 %	1.02 %	-0.08 %	0.09 %		0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月25日

報表日期: 114年07月25日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.11	8.06	59.59	3.17	18.55	9.51	1.39	78933.05
1	2.58	7.10	57.46	3.23	19.97	9.41	1.39	79618.86
2	7.04	7.22	61.50	3.53	19.25	9.44	1.40	78741.91
3	4.53	8.57	57.36	3.03	19.27	9.36	1.42	80669.99
4	2.96	8.92	58.26	1.78	18.83	9.65	1.43	76185.37
5	6.24	9.38	52.94	1.69	18.30	9.40	1.43	79847.46
6	4.14	7.99	58.56	1.80	18.39	9.87	1.42	76846.02
7	3.29	8.24	52.93	2.60	18.70	9.31	1.43	81530.46
8	5.72	8.56	54.69	2.34	18.31	9.47	1.44	79209.00
9	3.27	8.24	54.03	2.31	18.69	9.26	1.45	80759.16
10	7.97	8.31	55.10	2.56	17.73	9.51	1.43	78587.92
11	3.34	8.79	54.67	2.39	17.66	9.47	1.43	78310.31
12	4.23	9.88	65.36	2.41	18.47	9.72	1.44	77133.18
13	7.69	9.26	64.74	2.70	18.69	10.00	1.43	79851.33
14	2.88	11.17	69.04	2.19	17.95	10.00	1.40	79476.44
15	8.05	11.91	67.27	2.52	17.67	10.04	1.41	80059.98
16	6.11	10.54	61.80	2.94	17.62	9.99	1.40	79901.05
17	9.04	7.95	46.74	3.40	16.65	10.61	1.39	77427.31
18	4.14	7.55	56.14	2.73	18.87	10.16	1.40	74030.97
19	6.94	9.11	59.43	3.66	19.25	9.05	1.40	82551.80
20	10.45	7.30	60.82	3.60	19.29	8.98	1.39	80604.67
21	8.52	11.72	50.51	2.85	21.41	8.30	1.40	85601.83
22	5.85	6.91	65.09	0.70	19.54	9.40	1.43	81265.76
23	3.60	7.30	58.46	0.56	18.99	9.52	1.42	80258.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.57	8.75	58.44	2.53	18.67	9.56	1.42	79475.11
最 大 值	10.45	11.91	69.04	3.66	21.41	10.61	1.46	85601.83
發生時間	20	15	14	19	21	17		21
最 小 值	2.58	6.91	46.74	0.56	16.65	8.30	1.39	74030.97
發生時間	1	22	17	23	17	21		18
零點偏移(率)	-0.01 %	-0.00 %	-0.32 %	-0.04 %		-0.07		0.20 %
全幅偏移(率)	0.02 %	0.24 %	0.10 %	0.28 %		-0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								