

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.81	3.76	61.50	2.09	17.06	11.65	1.46	74598.30
1	1.65	3.48	55.89	2.27	16.13	12.01	1.44	72999.83
2	4.67	4.90	53.38	2.85	14.79	12.23	1.45	71833.46
3	2.34	4.55	55.15	3.01	14.53	12.44	1.46	70756.96
4	0.84	5.04	54.29	3.12	13.78	12.35	1.47	72077.67
5	1.22	6.88	55.53	3.76	13.12	12.68	1.46	73837.86
6	2.32	5.62	57.29	3.02	14.41	12.26	1.46	72501.86
7	0.64	4.64	53.76	2.96	14.67	12.48	1.47	70394.25
8	1.69	4.42	56.64	2.78	14.91	12.20	1.46	72024.73
9	3.20	4.34	57.00	2.92	14.86	12.16	1.47	73143.82
10	2.60	4.23	52.95	3.35	13.99	12.36	1.46	71240.49
11	4.82	5.91	56.50	3.85	13.60	12.57	1.45	69778.72
12	11.26	11.45	43.82	5.05	12.14	12.71	1.43	69145.39
13	8.52	6.80	46.82	4.57	12.34	12.75	1.46	68874.08
14	9.46	3.77	54.79	4.39	12.79	12.69	1.46	69156.46
15	7.52	9.77	56.49	4.20	12.79	12.68	1.46	69702.01
16	8.48	12.20	54.78	4.37	12.04	12.70	1.46	70408.26
17	7.61	6.18	50.68	3.96	12.83	12.44	1.43	71695.74
18	8.52	4.81	59.56	3.96	13.17	12.40	1.42	71992.67
19	8.93	7.80	53.78	4.46	12.27	12.59	1.41	71342.38
20	12.24	9.53	49.98	5.07	11.51	12.75	1.41	70291.63
21	9.51	7.13	53.46	4.71	11.81	12.76	1.42	69922.04
22	9.39	2.94	69.69	3.44	14.18	12.32	1.45	72296.18
23	6.13	5.50	57.50	3.70	13.84	12.85	1.45	67594.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.60	6.07	55.05	3.66	13.65	12.46	1.45	71150.39
最大值	12.24	12.20	69.69	5.07	17.06	12.85	1.50	74598.30
發生時間	20	16	22	20	0	23		0
最小值	0.64	2.94	43.82	2.09	11.51	11.65	1.41	67594.60
發生時間	7	22	12	0	20	0		23
零點偏移(率)	-0.05 %	-0.01 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.06 %	-0.48 %	-0.32 %	0.12 %		0.35	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.72	5.93	52.57	1.34	17.66	10.65	1.38	84835.16
1	4.63	5.74	61.63	1.31	18.23	10.74	1.41	83560.69
2	8.61	5.68	50.81	1.92	18.49	10.35	1.38	84017.74
3	5.26	1.66	52.31	1.60	17.50	10.25	1.38	83449.94
4	1.23	1.68	51.45	1.05	18.19	10.11	1.41	87429.18
5	1.97	1.60	58.33	1.14	18.36	10.20	1.44	88382.13
6	6.08	6.49	52.03	1.55	18.19	10.28	1.43	82624.47
7	3.90	4.44	54.84	1.34	18.28	10.42	1.41	86080.98
8	7.86	5.00	51.12	1.67	18.53	10.34	1.42	85300.30
9	10.75	4.61	52.95	1.78	19.27	9.88	1.41	89329.40
10	13.60	7.81	50.79	2.56	17.49	10.24	1.38	86662.19
11	2.59	5.40	49.67	1.68	16.72	10.32	1.38	83903.65
12	8.04	3.44	54.35	1.90	16.57	10.52	1.38	84983.16
13	9.78	3.78	57.59	2.04	17.08	10.43	1.38	86013.14
14	10.21	3.95	44.57	2.52	17.02	10.42	1.41	86010.31
15	10.63	6.73	58.82	3.05	15.68	10.65	1.42	85263.53
16	10.67	6.60	57.33	2.37	14.90	10.95	1.44	85873.08
17	8.97	5.26	62.10	1.74	16.68	10.61	1.46	86737.23
18	9.53	6.97	59.45	1.88	16.11	10.61	1.44	86943.48
19	10.62	13.14	56.23	2.44	13.87	11.05	1.43	84691.90
20	11.94	3.23	53.24	2.53	14.55	10.87	1.46	84405.70
21	8.69	1.75	60.12	1.72	17.01	10.80	1.44	84777.75
22	8.61	3.31	59.89	1.52	17.68	10.81	1.44	82437.25
23	1.31	5.15	46.83	1.08	18.78	11.18	1.44	78760.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.47	4.97	54.54	1.82	17.20	10.53	1.42	85103.06
最大值	13.60	13.14	62.10	3.05	19.27	11.18	1.53	89329.40
發生時間	10	19	17	15	9	23		9
最小值	1.23	1.60	44.57	1.05	13.87	9.88	1.38	78760.99
發生時間	4	5	14	4	19	9		23
零點偏移(率)	-0.16 %	-0.00 %	-0.01 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.22 %	-0.28 %	-0.59 %	-0.02 %		0.24	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

