

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年02月05日

報表日期: 114年02月05日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.96	3.17	57.43	0.82	16.27	11.77	1.27	80857.45
1	1.58	4.22	59.11	0.57	18.69	11.94	1.28	77521.79
2	6.10	3.81	43.86	0.72	17.68	10.98	1.27	86831.55
3	5.94	3.51	52.09	0.56	17.33	11.25	1.28	84658.10
4	8.63	3.34	57.16	0.63	18.22	10.67	1.29	88771.64
5	1.97	2.59	58.84	0.69	16.99	11.42	1.29	84899.76
6	6.86	2.80	53.41	0.63	17.32	11.19	1.29	84859.86
7	2.86	3.14	54.07	0.88	16.96	11.80	1.29	79929.94
8	6.39	2.59	56.35	0.46	18.25	11.05	1.29	85484.63
9	10.57	2.84	53.50	0.35	17.74	11.36	1.29	84820.28
10	9.17	2.78	53.57	0.51	16.88	11.73	1.26	82691.97
11	3.69	2.82	64.56	0.60	17.86	11.35	1.28	84291.64
12	3.42	2.97	42.32	0.74	17.23	11.06	1.29	86449.04
13	4.19	4.05	36.84	1.54	15.33	11.66	1.29	82842.18
14	8.49	2.16	47.37	2.01	15.33	11.71	1.29	82302.14
15	4.72	1.69	61.16	0.50	16.68	11.59	1.29	82288.78
16	7.84	2.07	58.85	1.09	16.06	11.47	1.29	83370.19
17	11.03	1.79	52.41	1.33	15.45	11.86	1.28	80702.43
18	9.84	1.76	53.77	1.01	15.82	12.02	1.26	79339.41
19	11.61	3.36	52.17	0.74	16.73	11.88	1.25	83531.57
20	11.35	2.00	37.66	0.85	16.64	11.94	1.24	83259.31
21	9.40	1.98	50.58	0.49	17.11	12.27	1.26	79935.96
22	10.56	3.04	43.48	0.40	17.81	12.02	1.26	81488.17
23	10.38	3.45	44.44	0.36	18.21	11.28	1.25	87380.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.31	2.83	51.88	0.77	17.02	11.55	1.28	83271.17
最 大 值	11.61	4.22	64.56	2.01	18.69	12.27	1.30	88771.64
發生時間	19	1	11	14	1	21		4
最 小 值	1.58	1.69	36.84	0.35	15.33	10.67	1.23	77521.79
發生時間	1	15	13	9	13	4		1
零點偏移(率)	-0.13 %	0.01 %	-0.09 %	0.00 %		-0.06		0.30 %
全幅偏移(率)	0.00 %	0.00 %	-0.04 %	0.00 %		-0.05		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.76	2.73	56.41	1.31	17.52	10.88	1.07	84324.32
1	3.58	5.94	43.47	2.25	15.85	10.59	1.06	87203.54
2	4.13	3.09	54.50	1.69	15.19	10.81	1.06	80961.72
3	2.59	2.26	54.05	0.83	17.48	10.39	1.07	87427.58
4	2.96	2.15	52.11	1.70	15.81	10.64	1.08	88131.43
5	3.48	2.05	53.94	1.80	15.50	11.08	1.08	84099.28
6	2.34	1.96	52.61	1.23	17.30	10.55	1.08	84587.96
7	2.43	2.03	44.74	1.53	16.07	10.70	1.09	86478.40
8	2.48	1.69	51.74	1.32	16.65	10.85	1.10	85243.43
9	2.41	1.70	49.87	1.70	15.88	11.02	1.11	84014.83
10	2.20	4.90	44.78	1.87	15.98	10.60	1.09	87524.04
11	2.14	3.80	53.35	1.49	16.53	10.78	1.09	85394.34
12	2.21	1.85	65.12	1.45	16.23	10.47	1.10	88913.72
13	2.45	2.53	57.29	1.74	13.79	11.26	1.10	83885.26
14	2.53	1.86	56.27	2.34	12.49	11.81	1.11	80125.20
15	2.53	1.42	57.69	1.41	14.58	11.30	1.10	83202.17
16	2.52	1.39	57.84	2.16	14.52	11.18	1.10	84524.57
17	2.50	2.05	41.24	1.90	16.17	10.85	1.09	85239.13
18	2.42	4.03	42.14	2.22	16.14	10.59	1.07	87387.44
19	2.62	2.86	44.09	2.17	15.65	11.03	1.07	83241.78
20	4.52	0.74	42.09	2.28	15.25	11.12	1.07	84174.62
21	2.51	3.42	46.51	1.32	17.30	11.52	1.11	78930.77
22	2.49	2.04	54.86	1.48	17.65	10.86	1.08	83521.53
23	2.38	2.94	38.78	1.58	17.15	10.40	1.06	87797.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.72	2.56	50.65	1.70	15.94	10.89	1.09	84847.27
最 大 值	4.52	5.94	65.12	2.34	17.65	11.81	1.17	88913.72
發生時間	20	1	12	14	22	14		12
最 小 值	2.14	0.74	38.78	0.83	12.49	10.39	1.06	78930.77
發生時間	11	20	23	3	14	3		21
零點偏移(率)	-0.02 %	-0.13 %	-0.04 %	0.00 %		-0.03		0.10 %
全幅偏移(率)	0.14 %	0.34 %	0.60 %	0.36 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.48	1.89	61.82	0.19	18.10	10.77	1.53	80136.12
1	8.09	7.64	44.21	0.78	16.66	10.38	1.52	83373.30
2	8.60	4.10	45.64	0.97	15.28	10.68	1.52	79984.24
3	7.60	4.20	50.95	0.30	17.44	10.41	1.54	83620.43
4	7.02	5.85	45.92	0.19	17.64	10.32	1.54	84063.45
5	7.48	3.25	48.53	0.26	17.70	10.49	1.53	82713.90
6	7.97	2.46	45.54	0.29	17.72	10.22	1.52	84704.73
7	6.19	3.99	57.27	0.69	15.74	11.89	1.53	75682.30
8	8.33	3.47	45.00	0.27	17.32	10.51	1.52	82888.81
9	10.16	2.15	41.88	0.53	15.84	10.83	1.52	80947.20
10	9.29	3.50	41.01	0.48	16.22	10.65	1.52	81232.24
11	8.39	3.70	54.23	0.59	15.14	11.01	1.52	77392.09
12	7.48	4.90	58.82	0.31	16.11	10.75	1.52	80541.92
13	10.16	5.48	60.61	0.54	15.41	10.91	1.52	79876.49
14	12.90	4.52	60.54	0.61	15.19	11.10	1.52	77888.51
15	8.37	2.56	63.81	0.46	15.78	11.14	1.52	77752.33
16	11.13	5.17	62.53	0.26	17.05	10.64	1.52	81985.78
17	11.54	10.91	43.53	0.46	16.91	10.36	1.52	84088.77
18	10.96	1.87	40.96	0.53	15.76	10.81	1.52	81404.21
19	16.37	2.97	44.11	1.70	16.25	10.80	1.52	82298.68
20	1.55	2.39	50.46	0.29	16.88	11.21	1.55	77419.03
21	10.34	5.13	36.10	0.96	20.22	9.21	1.57	89158.13
22	7.71	6.20	40.66	0.30	17.13	10.31	1.53	83369.77
23	10.43	4.62	48.82	0.48	15.15	11.25	1.52	78919.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.94	4.29	49.71	0.52	16.61	10.69	1.53	81310.07
最 大 值	16.37	10.91	63.81	1.70	20.22	11.89	1.69	89158.13
發生時間	19	17	15	19	21	7		21
最 小 值	1.55	1.87	36.10	0.19	15.14	9.21	1.51	75682.30
發生時間	20	18	21	0	11	21		7
零點偏移(率)	-0.03 %	0.01 %	-0.02 %	0.00 %		-0.18		-0.10 %
全幅偏移(率)	-0.13 %	0.32 %	-0.19 %	0.06 %		-0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								