

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年01月17日

報表日期: 115年01月17日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月17日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	14.61	12.94	52.93	1.93	16.49	11.40	1.11	78348.38
1	13.42	13.22	56.59	2.54	16.33	11.52	1.12	79953.49
2	16.97	12.88	47.93	4.07	16.15	11.14	1.12	81037.59
3	11.51	13.00	55.15	1.54	15.95	11.37	1.10	78873.26
4	12.86	12.99	72.95	1.76	15.63	11.02	1.10	79241.21
5	9.58	12.09	45.37	3.66	16.30	10.73	1.10	77365.42
6	4.44	11.75	47.87	2.41	16.47	10.66	1.09	78493.93
7	9.44	11.72	55.28	3.22	16.37	10.56	1.09	79854.38
8	9.72	12.44	55.86	2.49	15.92	10.90	1.09	77899.33
9	9.88	12.79	47.27	2.82	15.77	10.49	1.09	76645.41
10	11.90	12.15	65.40	1.16	15.27	10.79	1.11	75650.55
11	16.32	12.36	43.82	2.84	15.56	10.46	1.11	75485.47
12	10.87	12.46	51.04	2.08	15.38	10.94	1.10	75326.80
13	10.84	12.42	53.21	2.58	15.50	10.87	1.09	75868.50
14	15.46	12.74	40.63	2.04	14.11	10.91	1.08	74334.39
15	7.62	12.20	60.39	2.50	15.43	10.80	1.08	76746.40
16	10.77	12.29	49.17	2.51	15.56	10.33	1.10	79099.05
17	11.61	12.28	53.99	2.35	14.33	10.48	1.10	76744.91
18	9.67	11.69	53.54	1.98	17.44	10.37	1.09	75923.65
19	10.94	11.63	44.21	2.01	16.86	10.24	1.07	77722.92
20	13.62	12.40	55.20	2.12	15.38	10.54	1.09	76546.27
21	10.06	11.70	37.08	1.92	17.32	10.25	1.10	78174.94
22	11.58	11.90	44.67	2.51	15.96	10.61	1.10	78347.83
23	9.76	11.95	59.02	1.95	17.28	10.59	1.10	80298.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.39	12.33	52.02	2.37	15.95	10.75	1.10	77665.95
最 大 值	16.97	13.22	72.95	4.07	17.44	11.52	1.15	81037.59
發生時間	2	1	4	2	18	1		2
最 小 值	4.44	11.63	37.08	1.16	14.11	10.24	1.06	74334.39
發生時間	6	19	21	10	14	19		14
零點偏移(率)	-0.10 %	0.01 %	-0.06 %	-0.01 %		-0.05	-0.01	0.10 %
全幅偏移(率)	-0.34 %	-0.23 %	-0.41 %	-0.83 %		-0.25	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.18	10.66	37.35	2.36	18.43	8.90	1.36	73583.64
1	10.97	10.93	39.09	2.20	19.86	8.99	1.36	74148.25
2	9.42	12.79	39.38	2.25	19.61	9.12	1.36	73843.12
3	9.54	12.79	40.05	2.20	17.28	9.58	1.36	74962.88
4	9.53	14.53	43.08	2.80	16.38	9.42	1.36	74437.98
5	9.68	12.69	42.59	2.50	17.52	9.22	1.36	74715.64
6	9.39	16.00	46.35	4.34	15.40	9.47	1.36	73459.04
7	5.62	10.85	37.52	1.90	16.64	8.86	1.32	74123.26
8	4.32	10.77	32.90	1.08	15.76	9.17	1.32	70470.62
9	10.64	12.27	49.56	2.52	13.51	10.04	1.34	70353.65
10	10.05	12.30	56.60	1.17	14.45	9.85	1.32	70963.46
11	9.68	11.87	59.47	1.71	14.89	9.87	1.32	71096.11
12	9.65	11.96	59.94	1.27	15.89	9.83	1.34	71273.03
13	9.23	11.76	50.63	1.22	15.58	9.72	1.31	72310.46
14	9.45	12.40	44.80	1.94	13.52	10.09	1.31	69279.50
15	9.02	15.34	44.02	3.20	14.03	9.61	1.31	69877.02
16	9.75	12.15	32.40	1.73	16.73	8.86	1.31	73510.57
17	9.27	11.67	33.82	1.74	16.42	8.96	1.31	73113.18
18	9.45	12.14	34.13	1.98	15.59	9.35	1.31	70833.80
19	9.63	12.21	44.93	2.04	18.07	9.45	1.32	76642.09
20	9.33	11.48	33.45	1.18	16.06	9.29	1.31	73357.58
21	9.21	10.95	44.70	1.99	17.15	9.22	1.31	73100.14
22	9.76	11.11	46.80	1.92	17.78	9.03	1.32	74578.97
23	9.60	10.96	50.50	1.96	17.90	9.38	1.34	74710.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.27	12.19	43.50	2.05	16.44	9.39	1.33	72864.37
最 大 值	10.97	16.00	59.94	4.34	19.86	10.09	1.36	76642.09
發生時間	1	6	12	6	1	14		19
最 小 值	4.32	10.66	32.40	1.08	13.51	8.86	1.31	69279.50
發生時間	8	0	16	8	9	7		14
零點偏移(率)	-0.11 %	0.01 %	-0.05 %	-0.01 %		-0.07	-0.01	0.20 %
全幅偏移(率)	-0.67 %	0.22 %	-0.61 %	0.30 %		-0.06	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								