

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.24	13.35	54.70	2.09	19.00	11.19	1.25	72054.73
1	7.99	13.54	33.15	1.82	21.83	10.17	1.25	77009.84
2	8.27	11.09	30.65	3.88	19.18	10.37	1.25	78048.61
3	5.01	12.51	64.59	3.59	16.78	11.22	1.25	74002.44
4	3.77	13.87	69.19	3.98	15.19	12.39	1.25	66289.01
5	11.87	16.39	39.51	5.25	18.27	10.66	1.25	70936.04
6	8.55	12.23	51.62	2.55	18.97	10.72	1.25	75326.89
7	12.77	12.76	45.27	3.17	18.47	10.82	1.26	74962.23
8	10.90	13.73	54.23	2.11	19.73	10.24	1.25	78543.51
9	8.97	13.10	48.34	2.66	17.96	11.21	1.24	73437.60
10	7.99	11.86	43.12	2.15	18.22	11.30	1.25	72231.20
11	11.83	12.08	54.43	2.46	18.28	11.21	1.21	72924.93
12	8.90	11.96	52.60	2.64	19.11	11.07	1.23	73019.51
13	11.09	12.84	57.01	2.89	18.96	11.40	1.23	70065.75
14	14.28	12.75	44.22	2.99	19.64	10.41	1.23	76339.64
15	14.25	11.70	46.58	2.43	18.82	10.81	1.23	75277.49
16	14.65	11.60	49.00	2.84	17.21	11.18	1.22	73809.94
17	15.19	11.50	52.44	2.41	19.14	10.79	1.22	75369.53
18	14.36	12.33	49.82	3.13	17.68	10.93	1.23	74208.61
19	14.28	12.07	54.88	2.17	18.02	10.84	1.23	74679.71
20	16.40	11.74	58.19	2.39	17.99	10.85	1.22	74805.89
21	10.93	11.35	54.96	2.34	17.24	11.04	1.23	73648.14
22	12.28	11.47	53.06	2.05	18.56	10.62	1.24	75835.51
23	13.32	12.89	53.47	2.79	17.85	10.74	1.25	75715.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.05	12.53	50.63	2.78	18.42	10.92	1.24	74105.93
最大值	16.40	16.39	69.19	5.25	21.83	12.39	1.27	78543.51
發生時間	20	5	4	5	1	4		8
最小值	3.77	11.09	30.65	1.82	15.19	10.17	1.20	66289.01
發生時間	4	2	2	1	4	1		4
零點偏移(率)	-0.01 %	-0.00 %	-0.06 %	-0.01 %		-0.07	-0.01	0.20 %
全幅偏移(率)	-1.25 %	-0.01 %	-0.03 %	-0.15 %		0.00	0.10	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.42	12.48	45.20	1.01	18.87	10.85	0.99	80499.57
1	10.06	12.94	51.18	0.98	20.42	11.00	0.99	76290.77
2	9.65	11.83	42.52	1.32	20.55	9.74	0.97	86941.30
3	10.12	13.00	47.31	0.60	21.50	9.49	0.98	88290.36
4	9.51	12.59	36.31	1.09	20.05	9.87	0.97	82316.58
5	9.14	11.79	42.53	0.83	20.89	9.45	0.97	81929.96
6	9.42	12.52	26.54	1.63	20.93	9.48	1.01	79654.86
7	9.80	12.01	42.61	1.23	19.05	10.41	1.02	76080.87
8	9.31	12.94	55.29	0.81	20.11	10.09	1.01	80093.90
9	11.46	11.81	46.44	0.70	19.97	10.07	1.02	82308.14
10	8.95	12.57	51.87	0.48	20.01	10.63	1.03	78451.90
11	10.70	12.35	52.79	0.58	20.96	10.20	1.04	82431.23
12	11.94	12.41	52.79	1.17	20.34	10.17	1.04	83853.91
13	10.94	12.17	52.40	1.43	19.57	10.42	1.04	82676.24
14	9.42	12.14	47.28	1.03	19.49	10.32	1.04	82070.85
15	9.02	12.23	48.03	1.55	18.39	10.56	1.03	80767.39
16	10.74	12.14	53.32	1.23	18.73	10.52	1.04	81667.52
17	10.41	12.16	51.23	2.65	18.11	10.53	1.05	81072.10
18	10.15	12.15	52.31	1.64	19.86	10.10	1.05	81791.60
19	9.04	12.94	41.96	1.57	18.86	10.10	1.04	82505.48
20	10.32	11.89	52.80	1.21	18.65	10.34	1.04	80826.47
21	10.93	11.73	50.60	1.00	19.79	9.92	1.04	83178.81
22	11.54	12.14	51.36	0.92	18.86	10.12	1.02	82345.91
23	12.17	13.53	48.90	0.73	19.20	10.03	1.02	82310.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.17	12.35	47.65	1.14	19.72	10.18	1.02	81681.52
最大值	12.17	13.53	55.29	2.65	21.50	11.00	1.06	88290.36
發生時間	23	23	8	17	3	1		3
最小值	8.95	11.73	26.54	0.48	18.11	9.45	0.97	76080.87
發生時間	10	21	6	10	17	5		7
零點偏移(率)	-0.09 %	-0.06 %	-0.04 %	-0.00 %		-0.12	-0.01	0.10 %
全幅偏移(率)	-2.23 %	1.51 %	-0.59 %	0.26 %		-0.38	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.33	13.45	53.56	2.92	19.07	10.24	1.33	77996.27
1	6.31	15.58	51.95	2.74	19.97	10.10	1.33	76767.39
2	8.01	11.00	44.29	2.89	19.63	9.38	1.31	75366.57
3	8.00	11.03	44.31	2.75	18.31	9.59	1.31	75318.26
4	9.75	11.30	47.80	3.06	18.92	9.78	1.31	78799.04
5	8.91	11.29	44.08	2.85	17.85	9.55	1.31	76479.01
6	7.93	11.19	43.68	2.96	18.47	9.33	1.32	78041.59
7	10.25	11.34	41.93	3.56	19.20	9.15	1.36	80187.15
8	8.52	11.94	42.25	2.88	20.17	9.10	1.34	78068.86
9	8.48	12.54	41.36	2.87	18.92	9.28	1.36	77093.94
10	7.87	11.75	43.41	2.84	19.76	9.23	1.35	76472.37
11	9.63	12.05	41.14	2.93	18.81	9.25	1.35	76136.96
12	8.69	12.46	41.80	2.81	19.94	9.02	1.36	78217.22
13	9.26	11.97	44.53	2.93	18.89	9.45	1.36	75129.82
14	9.38	11.69	44.22	2.99	19.04	9.32	1.36	75449.56
15	8.93	11.40	45.91	2.93	19.83	9.36	1.36	75308.21
16	6.95	13.85	53.85	3.54	18.80	9.42	1.34	75976.00
17	9.66	11.68	58.99	3.18	17.56	10.39	1.33	76968.46
18	8.99	11.66	62.68	3.23	18.03	10.37	1.32	76013.51
19	8.58	11.54	58.46	3.01	17.67	10.29	1.34	76480.25
20	9.79	11.55	58.90	3.11	18.24	10.12	1.35	77408.12
21	9.58	11.32	58.80	3.07	18.78	9.90	1.32	75983.01
22	9.21	11.45	55.07	3.03	18.03	10.14	1.32	74584.02
23	10.54	12.94	56.51	3.13	17.92	10.05	1.34	74366.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.81	12.00	49.14	3.01	18.83	9.66	1.34	76608.84
最大值	10.54	15.58	62.68	3.56	20.17	10.39	1.37	80187.15
發生時間	23	1	18	7	8	17		7
最小值	6.31	11.00	41.14	2.74	17.56	9.02	1.31	74366.51
發生時間	1	2	11	1	17	12		23
零點偏移(率)	-0.09 %	-0.03 %	-0.02 %	-0.00 %		-0.12	-0.01	0.20 %
全幅偏移(率)	-1.07 %	1.32 %	-0.12 %	0.46 %		0.22	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								