

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.29	8.41	59.04	0.43	19.96	10.51	1.10	78460.25
1	7.69	9.49	43.91	0.73	20.17	10.93	1.10	74949.47
2	8.41	9.42	57.95	0.59	20.05	11.07	1.10	73982.11
3	9.18	8.85	58.14	0.77	19.13	11.06	1.10	74618.23
4	7.81	10.96	59.22	0.79	18.55	11.05	1.10	75793.60
5	11.57	10.33	51.42	1.58	17.81	11.10	1.10	76006.78
6	10.27	7.95	50.73	1.86	18.04	11.21	1.10	74417.20
7	8.58	7.55	60.76	1.01	19.17	11.26	1.10	74152.34
8	9.97	7.25	53.55	1.18	19.03	10.86	1.10	77225.27
9	8.28	7.23	55.66	0.97	19.28	10.92	1.10	76543.19
10	8.31	6.69	48.36	1.12	18.49	10.87	1.10	76277.24
11	6.27	6.78	45.76	1.53	16.93	11.25	1.10	72006.11
12	7.06	6.63	55.73	1.02	19.00	11.00	1.10	75373.25
13	5.88	6.68	46.35	1.13	18.55	10.63	1.10	78792.15
14	8.37	7.09	53.35	1.25	18.41	11.24	1.11	75167.48
15	5.19	7.25	56.30	0.92	18.15	11.58	1.11	72337.59
16	8.34	6.65	48.86	1.13	18.43	10.89	1.10	76267.00
17	9.06	7.05	48.34	1.51	17.06	11.16	1.09	74304.26
18	10.80	6.94	51.55	1.77	16.60	11.36	1.06	74629.63
19	9.71	6.84	53.84	1.50	16.97	11.16	1.05	76304.70
20	9.24	7.28	54.61	0.81	18.70	11.03	1.05	76582.59
21	9.81	7.27	57.04	1.48	17.70	11.24	1.05	75672.67
22	10.67	7.93	46.67	2.24	16.39	11.34	1.05	75405.35
23	8.81	6.71	63.67	0.72	18.27	11.21	1.07	76433.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.57	7.72	53.37	1.17	18.37	11.08	1.09	75487.59
最大值	11.57	10.96	63.67	2.24	20.17	11.58	1.12	78792.15
發生時間	5	4	23	22	1	15		13
最小值	5.19	6.63	43.91	0.43	16.39	10.51	1.05	72006.11
發生時間	15	12	1	0	22	0		11
零點偏移(率)	-0.12 %	-0.01 %	-0.01 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.01 %	0.04 %	-0.83 %	-0.09 %		0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.84	8.15	55.94	1.20	17.31	10.81	1.02	80895.52
1	0.74	7.30	55.82	0.84	20.14	10.14	1.02	83357.12
2	0.53	11.70	48.27	1.26	20.22	10.04	1.04	84318.28
3	0.19	5.76	55.68	1.56	17.83	10.54	1.04	82429.59
4	1.74	10.18	53.31	1.47	19.20	9.54	1.02	88601.00
5	3.01	6.24	47.32	2.10	17.95	9.92	1.02	86597.30
6	1.98	9.39	56.31	1.35	19.37	9.95	1.00	84156.48
7	2.88	2.95	48.14	1.28	18.95	10.04	0.98	84937.86
8	5.82	2.42	51.72	1.62	19.48	10.00	0.97	85070.07
9	9.63	2.96	47.01	2.39	17.46	10.21	0.97	86318.79
10	6.84	3.80	53.29	2.83	16.56	10.68	0.97	83304.53
11	5.98	4.31	53.08	2.44	16.35	10.42	0.98	85650.82
12	2.13	5.50	54.35	2.71	16.85	10.47	1.01	84782.28
13	6.73	2.67	57.40	2.21	17.88	10.36	0.98	84577.12
14	8.54	6.38	54.62	2.96	16.97	10.44	0.97	84917.53
15	9.74	3.26	54.42	2.08	17.36	10.29	0.99	85330.46
16	8.82	3.25	56.22	2.86	15.25	10.89	0.99	83067.80
17	8.49	3.30	56.14	2.47	15.89	10.83	0.99	82978.15
18	5.14	2.50	60.65	1.42	17.70	10.54	0.98	83433.52
19	2.50	10.01	50.66	2.19	17.35	10.27	0.97	86046.14
20	4.84	9.17	59.12	2.94	15.94	10.53	0.97	85126.08
21	9.70	5.22	58.93	3.86	14.88	10.73	0.97	84384.03
22	4.58	1.21	57.13	2.33	16.80	10.65	0.98	83651.12
23	7.09	4.46	55.22	1.88	17.99	10.19	0.99	85374.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.06	5.50	54.20	2.09	17.57	10.35	0.99	84554.42
最大值	9.74	11.70	60.65	3.86	20.22	10.89	1.08	88601.00
發生時間	15	2	18	21	2	16		4
最小值	0.19	1.21	47.01	0.84	14.88	9.54	0.97	80895.52
發生時間	3	22	9	1	21	4		0
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.03 %		0.03		-0.20 %
全幅偏移(率)	0.04 %	0.15 %	-0.49 %	0.17 %		-0.10		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.84	12.32	42.89	1.07	15.68	10.91	0.99	77158.90
1	3.75	6.09	57.01	0.91	17.23	10.88	0.99	76930.84
2	4.06	8.06	43.04	0.94	16.84	10.76	0.99	78699.07
3	6.06	10.52	47.05	1.11	16.91	10.53	0.99	79676.98
4	2.65	6.54	47.67	0.92	16.84	10.68	0.99	78328.85
5	2.29	11.62	46.06	1.26	16.25	10.28	0.99	80046.12
6	4.26	6.76	54.15	1.29	16.32	10.90	1.00	76165.96
7	2.06	5.54	47.13	0.93	16.93	10.97	0.98	75448.62
8	2.01	2.91	50.39	0.92	17.69	10.65	0.98	78717.52
9	5.66	5.61	42.68	1.32	16.65	10.50	0.97	80369.41
10	5.58	4.87	47.12	1.24	16.18	10.57	0.97	78509.41
11	7.67	4.52	47.39	1.60	15.23	10.81	0.97	78457.78
12	2.31	9.85	54.80	2.03	14.34	11.24	0.96	75722.91
13	3.37	3.48	52.43	1.08	16.98	10.75	0.97	82685.70
14	5.70	5.81	52.34	1.80	15.21	11.02	0.97	79696.83
15	6.43	3.13	59.38	1.37	15.74	11.24	0.95	79410.39
16	8.56	7.86	51.13	1.96	14.78	11.23	0.97	79967.00
17	8.59	5.67	49.40	1.82	15.35	10.89	0.97	81589.46
18	3.45	3.91	53.54	1.38	15.61	11.22	0.95	75721.16
19	1.68	4.21	57.26	0.86	16.94	11.44	0.97	76999.76
20	8.65	4.33	49.08	1.57	16.12	10.79	0.97	83839.39
21	8.92	2.14	48.21	1.73	15.77	10.92	0.97	82001.22
22	9.49	9.02	53.62	2.81	13.34	11.28	0.96	76168.95
23	9.28	4.57	55.55	1.92	15.70	10.79	0.94	79465.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.26	6.22	50.39	1.41	16.03	10.89	0.97	78824.08
最大值	9.49	12.32	59.38	2.81	17.69	11.44	1.02	83839.39
發生時間	22	0	15	22	8	19		20
最小值	1.68	2.14	42.68	0.86	13.34	10.28	0.94	75448.62
發生時間	19	21	9	19	22	5		7
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.41 %	-0.12 %	-0.41 %	0.12 %		0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								