

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月28日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.46	10.80	54.97	1.35	16.23	11.80	1.03	81099.93
1	7.31	11.17	62.60	0.89	17.29	12.55	1.04	73699.97
2	9.23	9.83	49.50	0.81	18.01	11.20	1.05	84969.96
3	9.59	11.95	48.37	1.91	16.28	11.58	1.06	82865.98
4	9.30	6.35	56.35	1.72	15.62	11.73	1.06	82081.85
5	6.18	9.55	68.31	0.93	16.49	11.96	1.03	80621.04
6	9.51	7.02	54.09	1.98	15.40	11.68	1.03	82379.57
7	9.26	6.86	53.15	2.49	14.88	11.93	1.03	80782.93
8	9.45	6.85	56.50	2.43	14.61	12.04	1.02	80215.79
9	9.91	6.78	57.28	2.09	15.33	12.04	1.00	79514.48
10	9.32	6.35	53.36	2.35	14.56	11.95	1.03	80668.67
11	10.04	5.86	60.70	1.90	15.10	12.04	1.02	79307.97
12	7.74	6.09	61.75	0.96	16.48	11.86	1.03	79535.98
13	2.22	6.86	55.59	0.62	16.65	11.98	1.05	78423.16
14	7.01	7.32	47.08	1.22	16.38	11.64	1.03	81135.89
15	9.37	6.30	54.97	1.59	15.67	11.86	1.04	80571.53
16	12.28	6.75	59.32	2.10	14.91	11.65	1.02	82946.46
17	13.52	6.29	58.16	1.45	16.15	11.60	1.01	82408.46
18	9.39	7.45	53.62	2.38	14.95	11.77	1.01	81673.08
19	8.68	7.21	62.65	1.45	16.34	11.69	1.00	81773.42
20	8.86	6.79	54.47	1.92	15.91	11.73	1.01	81575.90
21	9.26	7.98	65.59	1.48	16.52	11.81	1.01	80176.29
22	6.54	7.24	65.09	1.00	16.88	11.65	1.01	80932.71
23	9.79	7.60	53.34	1.07	17.04	11.29	1.01	84105.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.88	7.64	56.95	1.59	15.99	11.79	1.03	80977.79
最 大 值	13.52	11.95	68.31	2.49	18.01	12.55	1.06	84969.96
發生時間	17	3	5	7	2	1		2
最 小 值	2.22	5.86	47.08	0.62	14.56	11.20	0.99	73699.97
發生時間	13	11	14	13	10	2		1
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.01 %		-0.04		0.20 %
全幅偏移(率)	0.00 %	-0.17 %	-0.67 %	-0.06 %		0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月28日

[illegible]