

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月14日

報表日期: 114年09月14日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	7.71	13.10	58.81	1.75	16.95	11.34	1.22	81336.74
1	8.05	14.50	52.74	1.89	17.00	11.71	1.20	78316.95
2	7.21	12.93	55.49	2.54	15.24	11.76	1.20	77049.19
3	9.17	12.93	48.95	3.37	14.21	11.77	1.22	75721.37
4	9.02	13.39	67.59	2.13	16.24	11.99	1.24	75810.09
5	11.28	10.25	58.38	3.65	17.12	11.55	1.23	78069.72
6	11.64	11.68	61.52	3.68	16.64	11.29	1.23	82035.72
7	9.65	14.89	62.26	2.81	15.35	11.75	1.24	79475.08
8	9.32	10.50	60.38	2.52	16.35	11.45	1.25	81074.89
9	8.44	10.69	63.69	2.68	14.62	11.84	1.22	78838.71
10	9.14	11.47	67.17	2.49	15.17	11.79	1.23	78844.95
11	7.57	13.30	62.27	2.71	14.45	11.88	1.23	79187.19
12	8.37	13.14	63.18	2.16	16.01	11.61	1.21	80055.47
13	8.15	13.39	62.49	2.46	15.16	11.86	1.20	78969.87
14	9.04	13.34	60.91	2.29	15.79	11.70	1.23	80010.70
15	11.73	13.52	60.51	3.24	14.13	11.88	1.23	79480.25
16	13.45	12.61	59.94	3.16	14.97	11.63	1.23	81129.51
17	8.99	11.80	58.40	2.18	16.65	11.43	1.21	81455.12
18	5.80	11.90	59.58	1.69	17.77	11.08	1.20	83214.13
19	6.59	12.24	51.25	2.11	16.52	11.20	1.22	83463.63
20	6.75	12.35	60.49	2.26	15.81	11.47	1.23	81414.04
21	9.90	11.71	60.32	2.20	17.46	11.21	1.22	82260.99
22	12.58	11.57	56.14	2.80	15.94	11.35	1.23	82107.28
23	7.05	12.89	60.51	2.38	15.72	11.41	1.21	81579.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.03	12.50	59.71	2.55	15.89	11.58	1.22	80037.53
最 大 值	13.45	14.89	67.59	3.68	17.77	11.99	1.25	83463.63
發生時間	16	7	4	6	18	4		19
最 小 值	5.80	10.25	48.95	1.69	14.13	11.08	1.19	75721.37
發生時間	18	5	3	18	15	18		3
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	-0.01 %		0.03		0.10 %
全幅偏移(率)	0.00 %	0.23 %	0.18 %	0.11 %		0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.10	10.81	51.39	2.66	18.26	8.91	1.36	79413.64
1	7.94	11.33	55.40	2.90	19.25	9.05	1.38	79343.26
2	9.39	10.80	49.37	3.05	19.37	8.62	1.41	79859.92
3	9.40	11.16	50.38	2.97	18.37	8.81	1.40	78937.91
4	8.50	11.52	53.98	3.06	17.22	9.04	1.40	77553.10
5	8.37	10.85	55.10	2.91	18.38	9.07	1.41	77653.83
6	9.64	11.57	45.49	3.18	18.38	8.62	1.41	78422.41
7	10.12	13.31	58.76	3.18	18.37	8.98	1.38	80441.24
8	9.39	10.49	51.55	3.08	17.94	8.99	1.41	79586.76
9	9.05	10.55	57.15	2.94	17.61	9.14	1.37	78968.47
10	10.58	11.05	56.16	3.33	16.92	9.12	1.40	78442.39
11	11.12	10.59	57.33	3.37	16.94	9.14	1.38	78302.76
12	9.23	10.91	54.27	3.23	17.06	9.15	1.40	78745.74
13	8.51	11.41	50.37	3.02	16.45	9.16	1.39	78667.64
14	9.56	10.98	56.98	3.37	17.59	9.05	1.37	78797.71
15	7.14	10.96	54.96	2.92	18.75	8.72	1.36	81291.62
16	9.59	12.24	56.89	2.97	17.91	9.02	1.36	80135.66
17	7.88	13.48	59.54	3.00	19.51	9.43	1.36	78098.28
18	8.40	13.31	55.70	2.82	19.00	9.19	1.40	79727.61
19	7.16	11.83	47.75	2.59	19.01	8.61	1.39	77914.48
20	6.37	12.66	50.49	1.99	19.08	7.92	1.38	76741.31
21	12.32	11.31	60.87	2.05	18.18	8.63	1.36	83670.11
22	10.66	11.54	61.28	1.46	18.17	9.07	1.36	83279.96
23	9.42	11.15	62.37	2.67	17.43	9.00	1.36	80898.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.99	11.49	54.73	2.86	18.13	8.93	1.38	79370.58
最 大 值	12.32	13.48	62.37	3.37	19.51	9.43	1.43	83670.11
發生時間	21	17	23	11	17	17		21
最 小 值	6.10	10.49	45.49	1.46	16.45	7.92	1.35	76741.31
發生時間	0	8	6	22	13	20		20
零點偏移(率)	-0.07 %	-0.04 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.25 %	-0.01 %	0.18 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								