

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.09	2.67	51.05	2.16	19.09	11.47	1.41	74287.53
1	12.59	1.64	47.93	2.36	18.92	11.88	1.37	71979.77
2	12.50	1.97	51.57	2.34	18.95	11.58	1.41	73404.85
3	11.27	3.17	50.18	2.58	17.71	11.89	1.41	72860.37
4	10.95	2.72	54.17	2.50	18.08	11.79	1.38	73337.87
5	9.38	3.69	51.66	2.71	17.69	12.32	1.34	68285.79
6	10.89	4.52	57.59	2.62	17.71	12.17	1.40	71001.28
7	11.13	3.94	54.76	2.53	18.09	11.85	1.40	73434.07
8	10.05	4.55	48.06	2.57	17.52	11.80	1.40	74437.08
9	12.62	7.76	45.48	2.88	17.16	11.99	1.39	72242.04
10	10.53	6.50	52.60	2.69	17.24	12.01	1.40	72949.34
11	8.85	2.89	64.04	2.26	18.52	11.80	1.41	73416.24
12	10.24	4.73	51.54	2.45	17.68	11.89	1.41	73618.28
13	9.26	7.89	37.91	2.54	17.53	11.90	1.41	73302.96
14	9.72	3.33	49.89	2.40	18.04	11.84	1.39	73768.71
15	10.29	3.70	51.05	2.45	17.85	11.77	1.37	74529.52
16	9.00	5.02	45.89	2.46	17.67	11.76	1.35	74094.59
17	8.52	3.86	50.23	2.40	17.89	11.82	1.36	74148.35
18	9.75	4.48	50.16	2.44	18.19	11.52	1.39	75600.31
19	12.54	3.71	50.15	2.46	18.10	11.58	1.40	75383.86
20	9.24	3.87	50.69	2.35	18.03	11.63	1.40	75195.02
21	9.90	3.58	49.21	2.48	17.86	11.62	1.40	75648.03
22	10.24	2.57	52.57	2.22	18.82	11.37	1.40	77296.20
23	10.18	4.18	48.96	2.46	17.69	11.93	1.37	73649.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.45	4.04	50.72	2.47	18.00	11.80	1.39	73661.32
最大值	12.62	7.89	64.04	2.88	19.09	12.32	1.43	77296.20
發生時間	9	13	11	9	0	5		22
最小值	8.52	1.64	37.91	2.16	17.16	11.37	1.33	68285.79
發生時間	17	1	13	0	9	22		5
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	-0.33 %	-0.85 %	-0.23 %	0.01 %		0.07	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.77	2.66	54.91	2.56	15.75	11.03	1.38	62889.71
1	10.94	0.85	59.13	2.17	17.49	10.88	1.34	64644.36
2	11.32	3.02	50.15	2.70	15.80	10.88	1.33	62810.29
3	10.31	3.35	55.05	2.37	16.99	10.49	1.37	63491.71
4	11.40	1.78	48.10	2.85	15.71	10.75	1.38	62216.58
5	10.03	1.02	55.77	2.48	16.43	10.74	1.35	63532.37
6	15.01	1.59	57.31	3.25	15.68	10.89	1.33	60614.94
7	11.41	2.33	59.11	2.74	16.33	10.80	1.36	63987.04
8	9.94	3.40	48.34	2.55	16.32	10.59	1.38	61399.32
9	10.67	4.56	62.30	2.19	17.69	9.91	1.38	65015.80
10	10.49	1.39	53.99	2.64	15.84	10.80	1.38	62300.28
11	10.64	1.51	42.95	2.74	15.75	10.48	1.39	62013.77
12	10.51	1.89	52.90	2.84	15.72	10.70	1.39	62629.28
13	11.15	8.21	52.95	2.87	15.18	10.72	1.38	62323.18
14	10.05	3.93	43.68	2.55	17.04	10.06	1.38	59738.08
15	10.74	7.12	43.37	2.45	17.60	9.31	1.38	63292.71
16	11.28	3.26	48.07	2.74	16.20	9.87	1.36	65431.00
17	10.17	2.52	54.52	2.80	16.24	10.47	1.35	66165.81
18	10.89	3.65	45.92	3.39	16.29	10.26	1.33	62749.69
19	10.29	1.70	50.58	2.57	16.11	10.30	1.33	61880.77
20	10.57	1.51	49.51	2.66	16.15	10.31	1.34	62903.00
21	10.22	1.51	50.03	2.44	16.40	10.46	1.37	62617.78
22	10.64	0.93	55.59	2.02	17.36	10.35	1.39	66099.62
23	10.14	1.89	50.34	2.43	15.83	10.85	1.38	62228.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.82	2.73	51.86	2.63	16.33	10.50	1.36	63040.66
最大值	15.01	8.21	62.30	3.39	17.69	11.03	1.40	66165.81
發生時間	6	13	9	18	9	0		17
最小值	9.94	0.85	42.95	2.02	15.18	9.31	1.33	59738.08
發生時間	8	1	11	22	13	15		14
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-1.14 %	-0.75 %	-0.74 %	-0.06 %		0.02	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.03	3.87	49.77	2.53	15.95	10.42	1.71	80917.90
1	12.71	2.35	51.15	2.81	15.24	10.83	1.72	79678.07
2	14.33	0.98	54.37	2.66	16.78	10.37	1.70	83573.42
3	14.58	2.26	54.65	3.03	15.21	10.82	1.70	82859.67
4	16.10	1.54	55.94	2.92	15.21	11.14	1.69	83100.42
5	15.23	3.35	55.74	2.93	14.78	11.19	1.68	81660.53
6	13.86	1.87	55.07	2.97	15.42	10.81	1.68	84485.44
7	11.10	3.91	57.54	2.89	15.82	10.78	1.72	84390.57
8	11.80	4.25	55.31	2.80	14.20	11.15	1.72	82605.31
9	11.46	2.99	60.95	2.60	15.55	11.02	1.73	84545.13
10	9.88	4.63	57.26	2.60	15.10	11.06	1.73	83055.48
11	10.36	4.61	56.16	2.65	15.46	10.96	1.73	84301.67
12	11.32	6.59	58.37	2.69	15.97	10.74	1.75	85846.70
13	12.17	7.72	52.40	4.42	14.41	10.90	1.74	82812.36
14	9.98	1.66	54.57	3.11	15.00	10.95	1.73	83310.31
15	10.85	4.38	56.13	2.68	15.15	10.83	1.71	84226.26
16	11.81	5.13	56.11	2.84	14.50	11.10	1.69	82543.98
17	13.31	10.18	59.41	2.88	15.29	11.02	1.71	84253.93
18	12.61	1.71	56.68	3.02	15.30	10.84	1.72	84763.19
19	10.57	5.22	58.57	2.85	14.75	11.23	1.72	81872.93
20	12.37	3.15	57.38	2.67	15.61	10.88	1.72	84072.35
21	16.98	1.88	57.55	2.81	16.17	10.83	1.72	84638.17
22	13.33	3.54	53.18	3.65	15.42	10.70	1.71	87522.39
23	11.35	3.14	56.73	3.29	15.21	11.25	1.67	80903.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	12.63	3.79	55.87	2.93	15.31	10.91	1.71	83414.15
最大值	16.98	10.18	60.95	4.42	16.78	11.25	1.76	87522.39
發生時間	21	17	9	13	2	23		22
最小值	9.88	0.98	49.77	2.53	14.20	10.37	1.67	79678.07
發生時間	10	2	0	0	8	2		1
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.55 %	-0.27 %	-0.15 %	0.15 %		-0.04	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								