

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月03日

報表日期: 113年02月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.66	2.69	46.47	1.05	17.04	11.42	1.03	84325.12
1	9.90	3.99	45.00	1.36	16.30	11.53	1.04	83642.06
2	8.94	3.50	40.55	2.24	13.94	12.27	1.04	79724.20
3	7.67	3.02	52.06	1.05	15.96	12.04	1.06	79791.01
4	9.57	4.09	30.04	1.74	14.97	11.70	1.05	83133.71
5	5.98	10.38	47.15	4.31	12.67	12.88	1.04	77858.62
6	10.41	3.65	41.26	2.54	14.69	12.07	1.04	80110.72
7	10.63	5.79	40.94	2.53	13.79	12.32	1.04	78426.98
8	9.55	2.89	55.22	1.29	15.88	12.10	1.04	78837.31
9	9.39	2.87	52.53	1.62	15.31	12.03	1.02	79948.74
10	12.09	2.90	51.91	2.17	14.35	11.72	1.02	83247.26
11	11.41	7.23	43.56	2.33	15.02	11.88	1.02	82236.54
12	10.85	5.56	40.71	2.00	14.56	11.85	1.03	82910.64
13	8.82	8.25	57.10	1.60	14.49	12.49	1.00	76814.90
14	9.48	6.54	60.30	1.36	14.84	11.84	1.02	81453.99
15	10.58	7.73	63.01	1.66	14.76	11.66	1.01	82868.39
16	8.71	6.87	53.32	2.55	13.04	12.15	1.00	80613.33
17	8.63	6.12	49.50	3.15	13.17	12.46	1.04	78319.55
18	11.36	8.92	39.93	2.53	13.80	12.19	1.04	79994.01
19	8.46	7.97	46.39	1.42	15.01	12.04	1.02	80134.20
20	9.93	8.29	41.26	2.04	14.53	11.88	1.02	82095.26
21	9.28	12.13	46.07	2.48	14.25	12.35	1.02	77804.90
22	8.03	9.54	60.11	1.15	15.25	12.23	1.02	78562.07
23	9.22	10.97	52.72	1.03	16.24	11.36	1.02	85219.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.52	6.33	48.21	1.97	14.74	12.02	1.03	80753.04
最 大 值	12.09	12.13	63.01	4.31	17.04	12.88	1.06	85219.50
發生時間	10	21	15	5	0	5		23
最 小 值	5.98	2.69	30.04	1.03	12.67	11.36	0.99	76814.90
發生時間	5	0	4	23	5	23		13
零點偏移(率)	-0.04 %	-0.02 %	-0.04 %	0.00 %		-0.02		0.10 %
全幅偏移(率)	0.02 %	-0.07 %	-0.07 %	0.16 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月03日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.35	1.84	41.71	2.14	14.86	11.29	1.06	80323.79
1	5.45	1.76	42.55	2.44	14.20	11.77	1.06	76572.29
2	3.62	1.67	49.15	1.60	15.06	11.50	1.06	78596.32
3	9.48	1.46	44.81	2.42	14.84	11.24	1.06	80891.87
4	10.53	1.55	44.61	2.36	14.80	11.42	1.06	79348.93
5	8.92	1.52	44.42	2.52	14.15	11.54	1.06	79047.64
6	4.95	4.80	44.32	1.93	15.66	11.20	1.06	77173.99
7	8.35	2.70	46.79	2.77	13.54	12.02	1.06	75347.17
8	8.08	3.00	47.68	2.59	14.45	11.64	1.04	77797.08
9	7.69	2.75	48.74	2.61	13.95	11.93	1.03	75524.74
10	10.20	2.26	48.46	2.47	14.81	11.34	1.03	79876.51
11	8.46	4.25	49.31	3.16	12.76	12.13	1.06	75212.82
12	9.26	3.63	48.26	2.44	13.91	11.63	1.06	77871.83
13	9.64	3.56	46.45	2.80	13.15	11.91	1.04	76206.67
14	9.89	3.71	44.38	2.91	13.66	11.71	1.06	77914.22
15	8.79	6.69	43.31	3.08	12.65	12.00	1.05	75304.14
16	13.30	6.85	48.86	3.26	13.00	11.78	1.03	77476.05
17	7.44	1.62	43.26	2.99	11.94	12.08	1.06	76100.97
18	7.64	3.97	47.45	2.94	12.30	12.30	1.06	74293.08
19	7.77	3.87	48.62	2.59	12.97	12.14	1.06	74950.85
20	7.34	3.05	52.36	1.55	15.06	11.71	1.06	76397.51
21	9.32	3.68	48.46	2.52	13.99	11.65	1.06	77045.62
22	8.52	4.28	43.76	2.32	14.47	11.68	1.06	76613.22
23	11.28	3.68	51.25	1.99	15.51	11.28	1.06	80138.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.51	3.26	46.62	2.52	13.99	11.70	1.05	77334.42
最 大 值	13.30	6.85	52.36	3.26	15.66	12.30	1.08	80891.87
發生時間	16	16	20	16	6	18		3
最 小 值	3.62	1.46	41.71	1.55	11.94	11.20	1.02	74293.08
發生時間	2	3	0	20	17	6		18
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.00 %	-2.10 %	-0.30 %	-0.31 %		-0.17		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月03日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.94	2.71	54.00	1.47	15.86	10.80	1.09	81682.98
1	2.02	3.79	52.14	1.43	14.81	11.52	1.09	79376.93
2	5.18	2.18	58.84	1.18	15.65	11.07	1.09	80463.45
3	13.43	2.83	54.30	2.02	16.22	10.37	1.10	83512.24
4	9.43	1.92	53.51	2.32	15.81	10.44	1.10	83532.01
5	9.07	2.45	56.05	4.09	14.65	10.66	1.10	79838.77
6	8.21	2.87	57.02	4.24	14.39	10.67	1.10	77984.48
7	10.95	3.00	65.07	1.63	14.55	10.99	1.10	75515.25
8	8.19	2.54	62.31	1.85	14.56	10.99	1.10	76979.80
9	11.21	2.21	60.02	2.07	14.72	10.89	1.11	77763.88
10	12.20	2.65	61.09	2.85	13.47	10.98	1.11	78264.80
11	9.16	4.39	63.69	1.91	14.32	10.96	1.10	76668.50
12	5.55	5.98	54.27	2.18	13.46	10.63	1.11	77753.42
13	3.02	4.77	62.97	2.03	13.37	10.96	1.11	73967.06
14	2.80	3.74	58.46	1.53	14.39	10.66	1.11	76316.66
15	9.70	6.92	59.49	3.12	12.97	11.13	1.10	73247.70
16	11.55	4.60	66.19	3.67	12.31	11.52	1.10	71936.17
17	3.81	2.14	60.44	2.99	12.73	11.31	1.10	72958.27
18	4.52	6.91	64.18	2.60	13.08	11.37	1.10	75659.51
19	3.24	6.32	60.81	2.18	13.53	11.14	1.10	76124.38
20	2.55	9.41	58.83	2.67	12.62	11.42	1.10	73178.97
21	6.52	2.39	61.06	2.15	15.11	10.69	1.10	80036.34
22	8.04	7.36	60.19	1.94	15.67	10.65	1.10	78548.66
23	11.05	6.96	54.51	2.87	14.30	10.81	1.10	77139.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.47	4.21	59.14	2.37	14.27	10.94	1.10	77435.42
最 大 值	13.43	9.41	66.19	4.24	16.22	11.52	1.13	83532.01
發生時間	3	20	16	6	3	1		4
最 小 值	2.02	1.92	52.14	1.18	12.31	10.37	1.08	71936.17
發生時間	1	4	1	2	16	3		16
零點偏移(率)	-0.07 %	-0.00 %	-0.02 %	0.00 %		0.03		-0.10 %
全幅偏移(率)	0.02 %	-0.56 %	0.03 %	0.04 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								