

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.93	12.52	57.58	1.26	19.78	11.62	1.23	69183.01
1	9.99	12.01	53.30	1.01	21.60	10.66	1.23	74684.70
2	9.75	11.80	50.96	1.50	19.83	10.62	1.23	76915.30
3	9.99	11.98	47.59	1.85	18.85	10.98	1.24	75555.99
4	10.21	12.30	48.94	3.02	16.67	11.40	1.25	73969.29
5	7.43	11.60	43.56	2.07	19.14	10.81	1.23	72449.71
6	7.33	11.59	52.96	2.12	19.14	10.62	1.23	77540.28
7	7.70	11.83	54.34	2.10	18.57	11.20	1.24	73597.70
8	7.55	11.75	45.64	2.23	18.38	11.03	1.24	74543.88
9	7.77	11.94	51.74	2.32	17.37	11.46	1.24	72854.46
10	7.75	11.90	52.78	2.19	17.96	11.36	1.25	72778.70
11	7.48	11.66	49.15	2.05	18.93	10.92	1.25	75438.14
12	7.56	12.52	47.22	2.27	17.74	11.14	1.24	74856.22
13	7.70	12.82	52.07	2.66	17.16	11.38	1.24	73140.72
14	7.58	13.17	51.87	2.17	18.21	11.08	1.25	74503.30
15	7.90	13.43	48.00	3.04	15.78	11.67	1.23	70568.59
16	7.76	13.12	49.96	1.78	17.20	11.45	1.24	73443.60
17	7.72	11.70	50.62	1.10	17.63	11.40	1.25	72776.25
18	7.68	11.63	52.87	0.94	17.98	11.32	1.25	73119.70
19	7.61	11.59	52.95	1.12	18.42	11.17	1.25	73827.86
20	7.56	12.06	44.62	1.48	17.57	11.15	1.25	74869.71
21	6.63	11.84	44.39	1.74	17.24	11.34	1.25	73620.61
22	6.47	11.75	54.15	1.56	16.83	11.46	1.23	72784.34
23	6.62	12.06	59.95	1.14	18.56	11.52	1.23	71659.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.99	12.11	50.72	1.86	18.19	11.20	1.24	73695.06
最大值	10.21	13.43	59.95	3.04	21.60	11.67	1.25	77540.28
發生時間	4	15	23	15	1	15		6
最小值	6.47	11.59	43.56	0.94	15.78	10.62	1.22	69183.01
發生時間	22	6	5	18	15	2		0
零點偏移(率)	-0.03 %	-0.00 %	-0.27 %	0.00 %		-0.09	-0.01	0.20 %
全幅偏移(率)	0.11 %	-0.24 %	-0.06 %	0.11 %		-0.05	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.28	13.12	60.72	0.64	19.01	10.51	0.94	84820.04
1	10.17	12.66	55.63	1.03	19.23	10.74	0.94	82181.25
2	9.57	12.39	59.33	0.97	18.93	10.23	0.94	82504.69
3	9.36	12.54	51.59	0.50	19.99	9.95	0.94	83713.07
4	9.55	13.26	55.58	0.71	19.44	10.29	0.94	85767.02
5	9.82	12.60	52.86	1.10	17.98	10.88	0.94	81939.44
6	8.69	12.47	49.08	1.62	17.40	10.94	0.98	85151.01
7	8.54	12.73	59.40	0.96	18.65	10.57	0.99	83346.32
8	8.21	11.60	56.30	0.84	19.25	9.92	0.99	83023.29
9	8.13	11.64	49.90	0.86	18.44	10.05	0.97	79709.21
10	8.33	14.43	59.44	1.40	16.58	10.69	0.97	77208.10
11	8.66	15.60	60.12	1.85	15.53	11.10	0.97	78164.78
12	8.27	12.40	57.60	1.47	17.08	10.40	0.97	78842.67
13	8.43	12.23	59.85	1.15	18.02	10.61	0.99	73972.97
14	8.32	12.70	57.24	1.03	18.35	10.50	0.99	77929.90
15	7.97	14.86	41.56	1.34	18.05	9.96	0.96	77894.93
16	7.90	12.19	47.18	1.08	17.71	10.01	0.96	79120.25
17	9.18	12.02	44.72	1.09	17.76	10.33	0.94	80868.47
18	7.57	11.69	43.26	0.62	18.34	10.27	0.94	79626.75
19	7.00	12.35	32.14	1.53	18.12	10.16	0.94	79062.31
20	7.22	12.15	61.16	0.76	19.26	10.30	0.94	78455.27
21	6.30	11.85	56.56	0.92	19.15	10.23	0.96	81454.08
22	6.19	12.26	64.64	0.96	18.23	10.67	0.97	77886.99
23	6.15	12.42	51.50	0.91	17.97	10.82	0.97	76939.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.28	12.67	53.64	1.06	18.27	10.42	0.96	80399.25
最大值	10.17	15.60	64.64	1.85	19.99	11.10	1.01	85767.02
發生時間	1	11	22	11	3	11		4
最小值	6.15	11.60	32.14	0.50	15.53	9.92	0.94	73972.97
發生時間	23	8	19	3	11	8		13
零點偏移(率)	-0.09 %	-0.00 %	-0.03 %	0.00 %		-0.09	-0.01	-0.10 %
全幅偏移(率)	1.29 %	-0.20 %	0.46 %	0.04 %		0.03	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.70	12.26	57.09	3.18	18.33	9.96	1.39	72500.85
1	6.07	12.69	55.69	3.13	18.61	10.09	1.36	74679.82
2	9.60	12.44	56.28	2.98	18.18	9.72	1.36	77069.60
3	9.55	12.24	51.43	2.17	18.96	9.62	1.36	76033.20
4	9.15	12.39	55.53	3.14	18.71	9.76	1.36	75970.61
5	5.37	12.65	50.75	3.31	18.57	9.64	1.36	77270.53
6	4.59	13.04	57.84	3.31	17.87	10.07	1.36	76957.17
7	5.60	11.27	54.79	3.07	17.85	10.02	1.36	80211.47
8	4.85	11.25	51.72	3.20	18.20	9.92	1.38	76979.78
9	5.04	12.59	58.97	3.54	17.00	10.94	1.41	77215.84
10	5.79	11.91	54.47	3.34	17.48	10.61	1.35	75597.36
11	5.51	11.86	60.31	3.37	17.92	10.61	1.37	75809.06
12	6.39	12.10	54.61	3.54	16.84	10.87	1.39	75016.79
13	7.08	11.98	54.61	3.36	17.01	10.44	1.37	75760.30
14	4.24	11.44	60.02	3.03	17.56	10.21	1.35	74994.89
15	4.96	11.35	58.22	3.02	17.42	10.19	1.38	75431.64
16	4.10	11.52	56.02	3.06	16.82	10.37	1.35	74546.59
17	3.69	11.79	54.72	3.09	16.41	10.41	1.35	73899.67
18	4.92	11.78	52.63	3.06	16.18	10.32	1.37	73369.12
19	6.59	11.48	56.20	2.99	17.61	10.09	1.38	73225.41
20	6.62	11.44	54.24	3.07	18.49	9.73	1.38	76143.63
21	6.19	12.22	53.15	2.89	16.23	10.29	1.36	74591.31
22	7.02	12.16	58.08	0.72	15.39	10.75	1.35	73452.68
23	7.62	12.66	60.23	2.08	16.36	10.57	1.35	75025.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.05	12.02	55.73	2.99	17.50	10.22	1.37	75489.71
最大值	9.60	13.04	60.31	3.54	18.96	10.94	1.41	80211.47
發生時間	2	6	11	9	3	9		7
最小值	3.69	11.25	50.75	0.72	15.39	9.62	1.34	72500.85
發生時間	17	8	5	22	22	3		0
零點偏移(率)	-0.03 %	-0.02 %	-0.01 %	-0.00 %		-0.11	-0.01	-0.20 %
全幅偏移(率)	2.22 %	-0.92 %	-0.25 %	0.20 %		0.28	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								