

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.13	7.18	55.09	0.57	18.63	12.21	1.00	67411.60
1	0.11	8.11	50.83	0.85	19.39	11.87	0.99	68927.93
2	0.11	6.83	46.34	0.88	19.23	11.56	0.99	71392.25
3	0.35	5.91	51.32	0.68	19.53	11.32	0.99	74309.40
4	1.05	5.91	46.55	0.81	18.54	11.56	1.00	72560.78
5	1.37	10.32	49.46	0.85	17.70	11.43	1.00	74038.49
6	2.05	10.22	42.88	1.32	17.49	11.27	1.01	74646.41
7	4.22	11.27	49.62	1.65	17.05	11.76	1.00	71907.76
8	3.37	11.67	46.85	1.30	17.62	11.42	1.00	73726.80
9	3.33	6.70	53.67	0.67	17.66	11.60	1.04	72884.14
10	5.83	8.38	42.72	2.09	15.77	11.89	1.03	71257.55
11	8.05	8.30	43.92	2.73	15.97	11.85	1.00	71876.17
12	7.39	6.81	49.97	1.45	17.09	11.83	1.00	70840.84
13	7.56	6.92	46.15	1.55	17.12	11.50	1.01	73483.04
14	7.29	6.82	46.50	1.20	17.86	11.43	1.00	73549.61
15	6.49	8.19	46.51	1.05	17.92	11.50	1.02	73326.23
16	2.62	8.46	55.21	0.85	17.70	11.92	1.01	70410.47
17	2.18	10.25	59.97	0.38	18.89	11.83	1.04	70220.55
18	6.59	8.50	40.63	0.69	17.46	11.49	1.03	73588.73
19	7.12	8.89	50.82	1.09	17.71	11.58	1.04	72921.49
20	5.98	12.62	47.62	1.79	15.63	12.07	1.02	70517.01
21	2.60	5.20	49.71	2.09	14.99	12.22	1.03	70189.40
22	4.85	7.76	54.68	1.62	15.52	12.05	1.03	71255.66
23	5.17	6.57	55.55	0.72	17.08	11.39	1.05	74752.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.99	8.24	49.27	1.20	17.48	11.69	1.01	72083.11
最大值	8.05	12.62	59.97	2.73	19.53	12.22	1.05	74752.37
發生時間	11	20	17	11	3	21		23
最小值	0.11	5.20	40.63	0.38	14.99	11.27	0.99	67411.60
發生時間	1	21	18	17	21	6		0
零點偏移(率)	-0.04 %	-0.01 %	-0.01 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	0.15 %	0.49 %	0.01 %		0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.15	4.43	46.42	0.80	19.08	10.07	0.99	85428.33
1	0.10	3.84	42.56	1.06	19.89	10.27	0.99	82781.12
2	0.10	4.36	49.62	0.86	18.65	10.44	0.99	83337.84
3	0.11	2.78	41.02	1.16	17.97	10.25	1.00	85818.10
4	0.09	1.59	47.00	0.81	18.62	10.23	0.99	85119.99
5	1.22	10.62	51.01	1.31	18.36	9.90	0.99	88144.95
6	0.31	9.77	41.28	0.46	19.14	9.86	1.02	82865.72
7	0.87	6.52	42.71	1.48	17.45	10.05	1.02	86814.90
8	2.28	2.28	47.93	1.88	17.27	10.23	1.02	86265.77
9	3.47	6.17	50.94	2.20	16.96	10.41	1.02	85257.46
10	7.94	8.73	51.62	2.53	16.22	10.61	1.02	84268.72
11	5.77	13.60	43.71	1.81	17.35	10.17	1.02	86420.08
12	8.00	10.36	50.57	2.63	16.56	10.14	1.02	87179.32
13	6.04	6.42	47.34	1.67	17.45	10.33	1.02	85139.58
14	7.10	9.04	47.00	1.71	17.50	10.14	1.00	86735.97
15	9.03	7.99	51.83	1.60	17.75	10.06	1.00	87188.88
16	9.25	5.26	56.96	1.47	18.17	9.88	1.00	87934.52
17	9.75	5.46	54.89	1.76	17.07	9.89	0.99	87791.56
18	7.82	4.34	53.84	2.42	15.42	10.67	0.99	84520.85
19	8.39	6.59	53.76	2.46	15.83	10.44	1.01	86115.40
20	8.63	2.69	47.04	2.43	14.40	10.84	0.99	83395.66
21	12.15	3.53	47.48	5.13	14.11	10.56	1.00	84161.03
22	6.60	6.50	52.65	2.15	14.46	10.99	1.02	82707.63
23	4.75	4.44	54.82	1.66	14.90	10.75	1.03	84484.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.00	6.14	48.92	1.81	17.11	10.30	1.01	85411.57
最大值	12.15	13.60	56.96	5.13	19.89	10.99	1.04	88144.95
發生時間	21	11	16	21	1	22		5
最小值	0.09	1.59	41.02	0.46	14.11	9.86	0.99	82707.63
發生時間	4	4	3	6	21	6		22
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.00 %		0.01		-0.20 %
全幅偏移(率)	0.04 %	0.09 %	0.36 %	0.16 %		-0.01		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.49	4.53	54.02	0.98	16.01	11.42	0.94	72164.75
1	0.11	6.47	49.93	1.11	17.02	11.32	0.94	74955.57
2	0.08	5.36	52.41	0.86	16.70	11.33	0.94	75029.36
3	0.08	4.43	53.26	0.74	16.72	11.32	0.94	75585.32
4	0.24	5.95	46.36	0.81	16.75	10.77	0.94	80031.10
5	1.15	7.13	45.03	1.43	15.31	10.73	0.94	80160.10
6	0.89	8.53	48.80	1.37	15.23	10.94	0.94	76859.23
7	0.60	4.30	47.93	0.95	15.95	10.88	0.94	75555.57
8	1.30	6.29	51.18	1.58	14.86	10.96	0.95	79028.43
9	4.58	8.01	54.20	2.42	14.34	11.10	0.98	78795.96
10	3.40	4.66	52.05	1.75	14.75	11.03	0.98	77696.55
11	3.61	4.65	58.82	1.43	15.16	11.39	0.94	77701.52
12	4.50	10.87	47.96	1.60	15.28	10.92	0.94	77838.83
13	4.47	5.80	48.13	1.49	15.38	10.81	0.94	77540.84
14	2.22	10.33	40.11	1.02	16.09	10.43	0.93	75896.41
15	2.02	4.26	53.89	1.22	16.14	10.48	0.94	76844.45
16	3.02	5.31	50.03	1.07	17.00	10.23	0.92	76320.66
17	3.89	6.73	47.35	1.47	18.45	8.87	0.91	80440.31
18	6.88	4.05	52.57	1.91	15.43	9.86	0.93	77082.34
19	4.04	3.26	47.61	1.85	13.88	10.84	0.91	71627.86
20	5.54	6.87	48.10	2.09	13.67	10.89	0.91	75448.20
21	11.19	9.78	53.10	2.88	12.85	10.97	0.92	73698.88
22	8.45	7.99	51.50	2.45	13.47	10.91	0.91	73316.73
23	6.97	5.86	42.86	1.38	15.89	9.58	0.91	74522.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.32	6.31	49.88	1.49	15.51	10.75	0.94	76422.57
最大值	11.19	10.87	58.82	2.88	18.45	11.42	0.99	80440.31
發生時間	21	12	11	21	17	0		17
最小值	0.08	3.26	40.11	0.74	12.85	8.87	0.90	71627.86
發生時間	2	19	14	3	21	17		19
零點偏移(率)	-0.04 %	-0.05 %	-0.02 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.00 %	-0.48 %	0.17 %		0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								