

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月27日

報表日期: 113年03月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.46	6.57	67.69	0.90	15.75	12.28	1.01	74870.13
1	4.56	6.19	48.87	1.22	16.64	11.62	1.01	81690.49
2	7.63	5.31	45.80	2.06	14.98	12.03	1.02	79483.13
3	7.40	5.23	48.55	1.89	15.05	12.17	1.02	77006.33
4	7.24	7.88	45.64	1.13	15.51	11.95	1.02	79567.93
5	7.92	9.55	51.00	2.40	14.40	11.84	1.02	80501.20
6	8.72	6.61	60.36	1.55	15.35	12.09	1.02	78019.89
7	8.55	6.33	57.17	1.67	15.28	12.07	1.02	78090.81
8	6.76	6.22	62.87	1.09	15.91	11.98	1.04	78747.53
9	0.84	5.98	46.15	1.23	15.31	11.55	1.00	82271.80
10	1.69	5.96	45.97	1.68	14.66	11.91	1.02	78108.13
11	8.68	6.98	52.66	2.38	14.81	11.63	1.04	81673.62
12	13.89	6.09	48.79	3.73	13.49	11.91	1.00	78533.66
13	6.95	4.29	44.94	2.37	13.61	11.81	1.01	77844.78
14	6.31	5.49	64.34	1.38	15.07	12.32	1.04	73494.67
15	5.73	4.85	44.31	0.34	17.25	11.16	1.05	83455.28
16	8.49	3.52	48.38	1.26	16.66	11.43	1.05	82562.48
17	8.63	9.66	33.41	3.72	19.22	9.77	1.04	90339.34
18	10.71	2.35	34.04	1.30	15.99	10.41	1.02	80324.34
19	11.75	6.42	49.24	2.99	14.56	11.67	1.00	76410.58
20	10.22	1.57	65.98	1.17	17.31	11.37	0.99	80800.11
21	9.56	1.32	42.17	1.14	17.84	11.18	0.99	84019.27
22	8.55	1.47	28.65	1.91	15.53	11.75	0.98	78868.56
23	7.61	1.27	37.56	1.17	16.24	11.82	0.97	76919.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.54	5.30	48.94	1.74	15.68	11.65	1.02	79733.46
最 大 值	13.89	9.66	67.69	3.73	19.22	12.32	1.07	90339.34
發生時間	12	17	0	12	17	14		17
最 小 值	0.84	1.27	28.65	0.34	13.49	9.77	0.97	73494.67
發生時間	9	23	22	15	12	17		14
零點偏移(率)	0.00 %	-0.03 %	-0.02 %	-0.01 %		-0.04		0.10 %
全幅偏移(率)	0.00 %	0.54 %	0.14 %	0.09 %		0.19		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月27日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.30	3.76	34.23	2.17	16.60	11.17	1.03	81007.57
1	1.45	3.68	51.25	2.53	15.56	11.65	1.03	77432.03
2	0.62	4.25	57.42	3.02	15.16	11.68	1.03	77466.63
3	1.42	3.17	52.83	2.02	15.92	11.35	1.04	79687.91
4	4.02	3.23	48.83	2.41	15.49	11.29	1.04	79939.69
5	5.31	3.67	51.61	2.41	15.57	11.28	1.04	80087.00
6	9.77	7.58	59.71	2.65	15.61	11.38	1.03	77485.91
7	5.70	4.27	48.04	3.22	14.36	11.69	1.04	77854.13
8	7.14	3.82	57.80	2.12	16.34	11.40	1.05	78495.71
9	6.87	3.52	54.82	2.57	15.43	11.50	1.02	78161.22
10	7.86	3.80	52.16	2.86	14.85	11.65	1.03	77708.09
11	7.77	4.57	50.07	2.98	14.83	11.44	1.05	79221.73
12	3.31	2.90	56.03	2.76	14.34	11.35	1.02	79945.16
13	2.17	4.00	60.69	3.39	13.75	12.02	1.03	74967.52
14	3.53	3.56	59.79	2.76	15.45	11.69	1.06	76407.63
15	4.17	3.89	51.51	2.54	15.72	11.56	1.06	77146.52
16	8.79	12.37	44.55	2.83	16.20	10.97	1.06	81513.88
17	8.80	1.95	46.84	3.11	17.31	10.53	1.06	83385.80
18	9.60	2.26	37.97	2.63	18.17	10.47	1.05	82961.38
19	9.18	3.97	43.23	2.56	17.25	10.82	1.03	81370.52
20	5.30	1.84	43.65	1.62	17.82	11.10	1.03	78072.26
21	6.91	3.56	45.26	3.16	16.74	10.67	1.03	82891.82
22	1.62	4.74	49.69	2.59	15.16	12.06	1.03	73509.88
23	7.11	3.99	46.94	2.78	15.59	11.79	1.04	74964.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.49	4.10	50.21	2.65	15.80	11.35	1.04	78820.19
最 大 值	9.77	12.37	60.69	3.39	18.17	12.06	1.09	83385.80
發生時間	6	16	13	13	18	22		17
最 小 值	0.62	1.84	34.23	1.62	13.75	10.47	1.02	73509.88
發生時間	2	20	0	20	13	18		22
零點偏移(率)	-0.07 %	0.01 %	-0.04 %	0.00 %		-0.02		0.00 %
全幅偏移(率)	0.04 %	-0.20 %	-0.04 %	0.12 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

