

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.99	5.19	57.41	1.76	15.16	11.67	1.02	83419.53
1	4.68	6.92	70.87	1.44	15.91	12.58	1.03	74876.27
2	5.67	7.54	44.51	1.08	16.81	11.60	1.05	82862.39
3	9.41	7.14	29.15	2.56	14.46	12.10	1.03	80580.50
4	8.87	4.92	53.57	2.44	15.23	11.61	1.02	84099.45
5	12.87	10.81	47.88	2.24	15.34	11.37	1.05	84208.60
6	8.56	3.83	47.66	1.19	15.22	12.20	1.06	79007.58
7	8.37	2.74	59.34	1.22	14.91	11.80	1.06	82845.50
8	9.48	3.51	39.14	1.68	14.95	12.02	1.06	80522.69
9	8.57	3.60	41.37	1.22	15.52	12.02	1.07	80009.67
10	9.22	2.79	38.79	1.76	15.37	11.62	1.06	83985.15
11	7.77	3.23	50.43	1.21	15.11	11.91	1.06	81471.77
12	8.85	3.13	47.83	1.88	14.42	11.79	1.06	82011.11
13	6.62	3.49	43.04	2.34	14.56	11.90	1.04	81404.24
14	9.07	4.73	52.28	2.21	14.02	11.89	1.02	82093.05
15	7.26	4.72	66.19	2.19	13.90	13.16	1.03	70958.85
16	6.39	8.23	44.61	0.86	15.48	11.91	1.03	80926.62
17	8.09	9.79	56.66	0.65	17.68	11.04	1.03	86414.29
18	9.88	7.13	49.67	1.47	16.24	11.31	1.02	85408.77
19	9.98	7.59	49.18	1.54	15.81	11.49	1.02	83881.84
20	10.42	8.57	52.80	1.23	16.00	11.50	1.04	83623.74
21	11.95	9.09	52.82	1.15	15.90	11.47	1.06	83749.16
22	11.88	7.31	57.03	1.74	15.95	11.67	1.06	81971.15
23	8.28	6.86	57.30	0.75	16.79	11.95	1.06	79652.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.84	5.95	50.40	1.58	15.45	11.82	1.04	81666.02
最 大 值	12.87	10.81	70.87	2.56	17.68	13.16	1.11	86414.29
發生時間	5	5	1	3	17	15		17
最 小 值	4.68	2.74	29.15	0.65	13.90	11.04	1.02	70958.85
發生時間	1	7	3	17	15	17		15
零點偏移(率)	0.00 %	0.01 %	-0.00 %	0.00 %		-0.05		0.30 %
全幅偏移(率)	0.00 %	0.90 %	-0.20 %	0.22 %		0.39		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月26日

[illegible]