

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.21	11.85	41.78	2.88	18.95	10.86	1.34	82593.84
1	5.94	12.35	57.44	2.30	19.89	11.23	1.34	79346.12
2	9.44	12.25	54.53	3.54	18.94	10.88	1.34	82960.89
3	9.89	12.16	57.13	2.21	19.46	11.27	1.34	79963.26
4	9.69	12.43	60.67	2.51	20.32	10.71	1.34	83440.69
5	9.20	12.10	52.33	4.44	19.19	10.22	1.33	88376.29
6	9.95	12.22	60.25	1.41	18.42	10.65	1.34	85597.95
7	10.62	12.58	59.24	2.70	16.76	11.20	1.31	81824.36
8	10.37	13.22	58.41	2.74	19.05	11.36	1.31	79645.92
9	9.35	12.37	61.06	2.56	18.86	10.31	1.34	88189.07
10	9.80	12.81	49.22	2.70	18.30	10.74	1.33	83884.82
11	9.62	12.63	59.66	2.05	18.44	10.77	1.30	83481.55
12	9.74	12.44	55.67	2.39	17.62	10.85	1.30	82480.95
13	9.93	12.64	57.51	1.99	17.49	11.16	1.29	80329.68
14	9.85	12.51	61.97	1.89	17.92	10.99	1.30	81822.74
15	9.90	12.65	60.09	1.55	18.03	11.13	1.29	80648.53
16	7.69	16.43	46.63	1.32	21.04	10.10	1.29	86556.93
17	7.05	11.39	61.30	1.64	18.69	10.42	1.29	87175.41
18	7.49	11.15	42.35	1.78	18.72	10.80	1.30	84252.36
19	8.88	11.21	42.11	2.77	18.04	10.95	1.31	83617.34
20	9.46	11.28	52.85	2.76	18.36	11.03	1.31	80627.80
21	9.18	11.16	53.31	2.87	18.06	10.90	1.31	82749.98
22	8.97	11.08	59.29	2.93	16.87	11.08	1.31	81440.93
23	4.69	11.45	45.41	3.05	17.18	11.09	1.31	81220.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.70	12.27	54.59	2.46	18.53	10.86	1.32	83009.49
最大值	10.62	16.43	61.97	4.44	21.04	11.36	1.34	88376.29
發生時間	7	16	14	5	16	8		5
最小值	2.21	11.08	41.78	1.32	16.76	10.10	1.28	79346.12
發生時間	0	22	0	16	7	16		1
零點偏移(率)	0.00 %	-0.02 %	-0.07 %	-0.05 %		-0.07	-0.01	0.30 %
全幅偏移(率)	0.07 %	-0.04 %	-0.79 %	0.42 %		-0.14	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.33	12.24	49.85	1.35	19.15	9.74	1.02	76539.36
1	8.24	12.16	55.74	2.14	19.35	9.87	1.02	79844.87
2	9.40	11.89	65.34	1.52	18.66	10.34	1.02	80037.93
3	8.12	11.79	55.19	1.49	19.26	10.05	1.02	79486.45
4	8.98	11.69	53.26	1.17	19.46	9.96	1.02	80809.80
5	9.28	12.32	46.71	1.48	20.05	9.50	1.02	79843.20
6	2.89	12.05	52.57	1.63	19.32	9.80	1.02	85646.38
7	5.48	11.81	54.48	1.14	19.11	9.89	1.03	78382.89
8	9.32	11.69	45.66	1.78	17.95	9.97	1.02	76894.48
9	9.03	13.18	46.97	1.86	18.57	9.61	1.03	78702.87
10	9.70	14.05	51.84	2.23	18.72	9.87	1.02	79302.40
11	8.25	11.93	53.76	1.43	18.21	10.30	1.02	79086.44
12	10.74	11.94	56.63	1.97	18.85	10.10	1.04	79424.81
13	11.04	11.96	42.67	2.19	18.54	9.65	1.03	77850.23
14	8.67	12.09	46.43	1.36	19.06	9.67	1.02	78304.80
15	8.45	11.27	46.50	1.68	18.39	9.64	1.02	79753.85
16	8.81	11.49	38.36	1.02	19.15	9.64	1.04	78980.29
17	7.88	12.96	48.36	2.07	18.19	9.87	1.04	79873.82
18	8.19	11.57	46.48	1.10	20.25	9.63	1.02	80853.36
19	9.02	11.45	50.14	1.18	19.23	9.82	1.02	80872.86
20	11.11	11.44	46.07	1.54	18.94	9.63	1.02	78254.05
21	6.75	11.58	43.44	1.67	17.66	9.74	1.02	77031.77
22	10.02	11.57	53.61	2.41	16.83	10.14	1.02	77814.02
23	9.73	11.66	41.32	1.57	17.55	10.01	1.03	79484.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.64	11.99	49.64	1.62	18.77	9.85	1.02	79294.81
最大值	11.11	14.05	65.34	2.41	20.25	10.34	1.06	85646.38
發生時間	20	10	2	22	18	2		6
最小值	2.89	11.27	38.36	1.02	16.83	9.50	1.02	76539.36
發生時間	6	15	16	16	22	5		0
零點偏移(率)	-0.12 %	-0.01 %	-0.06 %	-0.01 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-4.80 %	0.72 %	0.62 %	0.32 %		-0.19	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.49	12.56	68.15	1.74	17.18	10.98	1.46	71389.96
1	4.74	12.41	58.98	1.69	19.07	10.09	1.44	75937.74
2	4.78	12.43	56.65	1.76	18.37	10.28	1.44	74433.71
3	6.32	11.85	60.42	1.91	18.63	10.21	1.44	77010.10
4	4.11	12.15	60.80	1.73	17.98	10.57	1.45	74294.53
5	3.68	12.01	57.61	1.68	17.87	10.46	1.45	75617.37
6	6.14	12.25	56.74	1.97	16.77	10.76	1.43	73962.16
7	7.66	11.10	58.18	2.44	16.60	11.06	1.41	72550.16
8	8.96	11.15	56.73	3.22	15.11	11.02	1.42	72785.30
9	6.78	11.03	55.10	2.61	15.85	10.87	1.42	71402.59
10	8.33	10.74	46.61	2.47	17.02	10.43	1.43	73293.77
11	8.00	10.64	50.04	1.89	17.27	10.47	1.42	72595.16
12	10.25	10.63	48.00	2.02	16.95	10.35	1.40	73124.43
13	4.56	10.47	48.26	1.50	17.63	10.26	1.43	74175.69
14	8.08	10.67	51.08	1.68	17.27	10.57	1.40	72464.00
15	7.66	10.65	55.50	1.89	18.10	10.48	1.43	73150.09
16	8.56	12.17	48.71	1.78	17.66	10.41	1.40	73350.26
17	10.30	12.85	50.03	2.11	17.52	10.35	1.37	74317.59
18	6.35	13.06	54.50	1.81	16.72	10.71	1.40	71976.23
19	4.67	12.74	48.21	1.51	18.01	10.10	1.42	73272.28
20	4.85	13.24	49.98	1.67	16.60	10.70	1.43	70295.28
21	5.45	13.29	52.21	1.95	16.82	10.41	1.43	71402.95
22	6.10	12.87	50.19	1.69	16.46	10.56	1.43	71666.95
23	6.88	12.83	52.73	1.85	16.93	10.42	1.42	73383.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.61	11.91	53.98	1.94	17.27	10.52	1.42	73243.82
最大值	10.30	13.29	68.15	3.22	19.07	11.06	1.47	77010.10
發生時間	17	21	0	8	1	7		3
最小值	3.68	10.47	46.61	1.50	15.11	10.09	1.36	70295.28
發生時間	5	13	10	13	8	1		20
零點偏移(率)	-0.08 %	0.01 %	-0.02 %	-0.01 %		-0.29	-0.01	0.00 %
全幅偏移(率)	1.08 %	1.01 %	0.14 %	1.14 %		-0.06	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								