

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月28日

報表日期: 114年10月28日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.00	15.28	54.67	1.37	16.86	12.07	1.26	68458.64
1	4.28	14.43	47.97	1.88	19.03	11.06	1.24	75452.40
2	9.12	13.92	31.30	2.88	16.19	11.60	1.23	71599.47
3	4.71	13.77	43.60	1.90	16.18	11.98	1.23	68226.63
4	5.24	12.80	51.48	2.16	17.00	11.27	1.23	72621.95
5	5.24	12.49	44.00	2.11	17.49	10.95	1.21	72053.46
6	6.39	13.16	49.35	2.34	16.78	11.53	1.20	70997.43
7	6.67	13.34	53.17	3.91	16.34	11.20	1.20	73359.25
8	12.27	13.61	51.89	2.89	16.89	11.52	1.20	71430.28
9	7.86	13.62	57.01	3.48	16.80	11.09	1.20	74265.72
10	7.09	13.22	48.75	2.96	16.68	11.48	1.22	71137.85
11	5.74	13.47	57.51	3.33	15.89	11.73	1.23	70175.42
12	7.50	13.01	58.99	3.39	15.90	11.48	1.23	71847.27
13	6.59	14.91	58.66	2.70	15.72	12.15	1.23	67406.19
14	5.24	13.99	49.60	1.84	16.91	12.01	1.23	67380.88
15	4.07	13.43	45.74	2.05	16.40	11.48	1.23	71584.70
16	3.72	13.79	57.15	1.47	17.07	11.56	1.23	72801.80
17	4.30	14.82	60.56	1.71	16.51	12.43	1.23	67345.84
18	8.71	13.38	52.47	3.11	16.81	11.54	1.23	74261.93
19	12.70	13.09	47.29	3.42	16.28	11.35	1.23	75605.42
20	10.48	13.14	51.75	3.12	15.78	11.43	1.23	75271.17
21	14.49	12.97	61.12	3.75	16.43	11.38	1.22	75451.05
22	15.95	14.86	56.80	4.09	15.85	11.45	1.21	74798.75
23	6.34	13.52	62.41	2.88	16.42	11.72	1.20	72682.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.45	13.67	52.22	2.70	16.59	11.56	1.22	71925.68
最 大 值	15.95	15.28	62.41	4.09	19.03	12.43	1.27	75605.42
發生時間	22	0	23	22	1	17		19
最 小 值	3.72	12.49	31.30	1.37	15.72	10.95	1.19	67345.84
發生時間	16	5	2	0	13	5		17
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	0.00 %		0.02	-0.01	0.30 %
全幅偏移(率)	-0.45 %	-1.53 %	-0.44 %	-0.48 %		0.42	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月28日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.55	12.84	52.03	0.84	20.17	9.60	1.38	80342.28
1	11.58	12.57	54.82	1.98	18.72	9.87	1.39	78713.42
2	11.39	12.59	54.79	2.13	17.42	9.67	1.39	82258.31
3	10.67	11.55	50.91	1.80	17.58	9.69	1.36	75348.37
4	11.24	11.02	48.63	2.06	18.81	9.57	1.37	79022.96
5	12.22	12.16	55.11	1.67	18.44	10.13	1.37	78707.71
6	10.85	11.15	51.72	0.39	18.33	9.62	1.36	78193.62
7	14.71	11.60	52.73	1.90	18.01	9.83	1.37	78488.09
8	12.38	12.72	57.25	1.94	17.39	10.08	1.37	78992.21
9	10.97	11.76	40.49	1.75	17.90	9.46	1.37	76073.86
10	9.02	15.17	46.04	2.80	17.83	9.21	1.40	76165.39
11	6.03	12.13	55.54	1.88	18.35	9.84	1.39	75797.76
12	12.75	12.54	47.14	2.18	15.91	10.47	1.40	79895.32
13	5.58	11.42	55.44	1.65	18.49	9.78	1.40	81517.80
14	9.19	11.46	56.03	1.84	18.02	9.82	1.39	79439.30
15	11.10	12.59	63.96	1.77	16.85	10.88	1.37	73485.25
16	11.80	12.21	51.47	1.95	18.73	10.43	1.36	81027.99
17	14.30	11.20	41.10	2.16	19.14	9.37	1.36	78581.84
18	10.65	11.06	48.13	1.84	19.50	9.06	1.36	80632.62
19	11.89	12.79	57.63	1.92	18.68	9.47	1.37	79913.28
20	13.27	11.28	58.59	2.23	17.17	9.57	1.36	80266.09
21	13.42	11.41	54.00	2.27	18.64	8.88	1.37	79527.24
22	13.19	11.62	65.24	1.97	19.25	9.40	1.38	84182.18
23	11.49	11.30	62.32	1.92	18.48	9.65	1.38	86285.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.30	12.01	53.38	1.87	18.24	9.72	1.38	79285.75
最 大 值	14.71	15.17	65.24	2.80	20.17	10.88	1.41	86285.02
發生時間	7	10	22	10	0	15		23
最 小 值	5.58	11.02	40.49	0.39	15.91	8.88	1.36	73485.25
發生時間	13	4	9	6	12	21		15
零點偏移(率)	-0.07 %	-0.00 %	-0.02 %	-0.00 %		-0.03	-0.01	0.20 %
全幅偏移(率)	0.08 %	0.95 %	-0.03 %	-0.15 %		0.33	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								