

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.58	12.38	59.16	2.36	18.54	11.28	1.18	71502.92
1	3.17	11.83	58.64	2.29	19.41	11.08	1.19	72681.36
2	5.49	11.18	56.15	2.92	19.82	10.62	1.20	76827.69
3	8.63	11.22	56.00	2.99	20.21	10.60	1.20	76057.26
4	4.83	12.03	56.27	3.13	18.79	10.99	1.20	74564.17
5	7.11	12.73	52.60	2.65	19.27	10.78	1.18	70703.36
6	9.74	12.81	54.93	3.47	18.08	11.22	1.18	72666.99
7	8.54	12.75	56.24	3.61	17.48	11.21	1.18	73460.94
8	14.11	12.76	59.51	2.57	19.05	11.05	1.18	73162.89
9	9.00	12.72	55.25	2.79	17.99	11.16	1.18	73614.57
10	13.51	12.63	56.62	2.86	18.54	10.99	1.18	74479.06
11	8.04	12.84	60.02	3.10	18.12	11.23	1.18	72937.51
12	8.92	12.82	54.69	2.65	18.21	11.17	1.18	73398.12
13	9.74	12.70	56.80	2.26	19.13	10.98	1.18	74001.16
14	10.45	13.42	45.10	2.44	18.69	11.01	1.17	74211.08
15	10.15	12.75	51.22	2.17	18.30	10.97	1.17	74640.44
16	8.62	12.65	51.69	2.02	17.74	11.14	1.18	74007.49
17	12.68	12.65	56.40	2.38	18.29	11.04	1.18	73951.74
18	4.11	12.33	61.50	3.09	19.29	10.64	1.18	76121.94
19	7.98	12.67	56.46	2.54	20.02	10.39	1.18	76818.90
20	8.54	13.55	52.88	1.56	18.32	10.83	1.18	74803.64
21	10.73	12.49	51.64	2.52	18.48	11.02	1.17	73377.60
22	8.39	12.85	55.48	2.40	17.76	11.33	1.15	71476.84
23	5.96	13.17	57.71	2.75	15.94	11.71	1.16	70161.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.71	12.58	55.54	2.65	18.56	11.02	1.18	73734.55
最 大 值	14.11	13.55	61.50	3.61	20.21	11.71	1.22	76827.69
發生時間	8	20	18	7	3	23		2
最 小 值	3.17	11.18	45.10	1.56	15.94	10.39	1.14	70161.65
發生時間	1	2	14	20	23	19		23
零點偏移(率)	-0.01 %	-0.00 %	0.00 %	-0.07 %		-0.02	-0.01	0.10 %
全幅偏移(率)	0.95 %	0.76 %	-0.35 %	-0.51 %		-0.32	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.70	12.48	53.23	1.46	18.84	10.92	0.97	82386.32
1	3.45	12.46	58.09	1.27	18.76	10.88	0.99	83351.60
2	3.99	12.26	54.29	1.28	19.01	10.75	0.98	84464.32
3	5.69	12.28	60.23	1.31	19.33	10.74	0.98	84358.76
4	10.71	12.40	52.60	1.74	19.29	10.71	0.99	84741.75
5	5.25	12.78	49.21	2.08	16.72	11.44	0.98	80729.66
6	4.62	12.71	48.19	1.52	16.89	11.40	1.00	82809.61
7	9.41	12.74	58.93	1.47	17.56	11.34	1.02	80856.82
8	11.42	12.60	54.67	1.55	17.58	11.20	1.00	81407.68
9	13.94	12.82	55.06	1.68	17.29	11.22	1.00	81430.91
10	7.35	12.71	55.07	1.87	17.38	11.23	0.99	81572.90
11	6.98	12.63	55.67	1.12	18.08	11.12	1.01	82004.74
12	4.88	12.68	65.45	1.15	18.75	10.77	1.02	83986.71
13	9.92	13.31	54.74	2.28	17.05	11.22	1.01	81877.13
14	6.41	12.69	58.99	2.05	16.80	11.16	1.00	82252.87
15	3.87	12.65	63.81	1.44	17.02	11.19	0.99	82712.34
16	6.43	12.65	51.66	1.80	17.10	11.22	0.98	81317.50
17	4.82	12.70	61.40	0.96	18.89	10.92	1.00	82486.05
18	3.53	12.77	49.87	1.69	19.27	10.37	1.01	86158.38
19	7.45	12.48	60.60	1.32	18.70	10.56	1.02	85414.39
20	6.12	12.38	56.18	1.14	19.80	10.31	0.99	86329.64
21	6.20	12.17	61.59	0.95	19.52	10.40	0.99	85782.00
22	4.11	12.52	53.28	1.80	17.89	11.02	0.98	82750.45
23	1.79	12.85	56.07	1.94	16.53	11.43	0.99	81032.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.38	12.61	56.20	1.54	18.09	10.98	1.00	83008.96
最 大 值	13.94	13.31	65.45	2.28	19.80	11.44	1.02	86329.64
發生時間	9	13	12	13	20	5		20
最 小 值	1.79	12.17	48.19	0.95	16.53	10.31	0.97	80729.66
發生時間	23	21	6	21	23	20		5
零點偏移(率)	-0.06 %	-0.01 %	-0.05 %	-0.01 %		0.01	-0.01	-0.10 %
全幅偏移(率)	0.73 %	-0.51 %	0.08 %	-0.21 %		0.27	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	11.20	12.80	58.91	2.90	19.68	10.03	1.27	74329.18
1	5.79	13.00	49.86	2.28	20.38	9.52	1.26	77550.58
2	11.07	12.78	60.60	2.85	18.44	10.14	1.23	74182.15
3	6.42	12.87	57.13	2.48	18.40	10.29	1.23	74839.60
4	12.62	12.83	58.06	3.48	18.51	10.22	1.23	74614.21
5	9.67	13.20	53.55	3.29	17.88	10.55	1.23	73631.55
6	10.02	12.80	51.99	2.83	17.89	10.22	1.23	76336.35
7	10.72	11.57	57.96	2.77	18.11	10.16	1.23	74849.58
8	9.60	11.62	59.82	2.73	18.02	10.07	1.23	74610.07
9	11.60	11.43	58.31	3.78	18.27	9.98	1.25	75844.68
10	10.97	11.51	58.51	3.90	17.42	9.98	1.26	74686.02
11	10.95	11.54	58.96	3.99	18.35	9.80	1.26	77920.20
12	9.04	13.55	57.17	4.43	17.30	10.45	1.27	74989.74
13	9.45	11.86	56.05	2.75	19.20	9.49	1.28	79193.33
14	10.34	11.38	62.09	1.98	17.69	9.91	1.27	76249.12
15	8.35	11.56	57.69	1.73	17.96	10.01	1.23	76147.94
16	9.75	12.24	57.89	1.64	16.33	10.72	1.23	74428.41
17	9.65	12.14	60.66	1.36	16.74	10.79	1.23	72844.82
18	9.25	11.95	59.16	1.26	16.97	10.50	1.23	73032.57
19	9.62	12.02	62.64	1.33	17.91	10.60	1.23	72684.16
20	13.49	12.24	56.56	3.01	17.48	10.74	1.23	75414.85
21	8.75	11.82	59.55	2.96	17.95	10.39	1.27	78329.42
22	10.66	11.73	56.54	2.95	17.62	10.38	1.27	76211.24
23	8.46	11.56	54.79	2.74	17.81	10.21	1.25	77667.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.89	12.17	57.69	2.73	18.01	10.21	1.25	75441.14
最 大 值	13.49	13.55	62.64	4.43	20.38	10.79	1.29	79193.33
發生時間	20	12	19	12	1	17		13
最 小 值	5.79	11.38	49.86	1.26	16.33	9.49	1.23	72684.16
發生時間	1	14	1	18	16	13		19
零點偏移(率)	-0.11 %	-0.01 %	-0.03 %	0.01 %		-0.01	-0.01	-0.20 %
全幅偏移(率)	1.15 %	0.18 %	0.46 %	0.33 %		0.23	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								