

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月02日

報表日期: 114年10月02日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	5.69	13.31	44.48	1.61	15.51	11.60	1.25	73871.44
1	6.83	13.92	53.35	1.97	16.66	11.62	1.25	74486.20
2	11.95	12.48	38.42	3.00	16.61	10.80	1.25	83165.41
3	8.46	12.04	51.22	3.13	14.99	11.25	1.25	80936.41
4	10.39	13.10	44.95	3.62	15.61	11.17	1.25	79316.01
5	9.38	12.57	44.22	2.77	15.55	11.25	1.22	76100.07
6	5.94	12.95	52.62	2.56	15.86	10.97	1.22	82497.86
7	4.55	13.87	50.96	3.12	14.30	11.60	1.23	74897.04
8	5.36	14.05	61.18	3.07	15.51	12.16	1.22	74743.76
9	10.93	13.17	51.89	4.46	15.92	11.47	1.21	83793.81
10	8.14	14.03	54.40	1.47	16.54	12.06	1.18	76281.15
11	7.80	14.10	64.72	1.91	16.01	11.45	1.18	80196.69
12	12.75	15.23	59.33	3.15	14.25	11.94	1.18	78375.59
13	13.62	14.71	53.80	3.28	14.43	12.03	1.18	78686.41
14	5.07	14.46	65.16	2.15	14.52	12.50	1.18	72591.88
15	10.81	13.19	54.87	2.11	15.68	11.02	1.19	81110.57
16	11.96	13.33	56.23	1.97	15.44	11.13	1.21	82956.59
17	4.21	14.00	45.77	1.35	15.62	11.68	1.20	76978.77
18	8.23	12.67	53.41	1.38	16.02	10.93	1.22	84502.98
19	8.40	13.36	46.28	1.99	15.02	11.58	1.23	80228.73
20	13.92	13.63	47.01	1.77	15.84	11.61	1.23	79140.70
21	8.71	14.58	46.84	1.72	15.14	11.52	1.20	80893.07
22	8.15	13.31	51.24	1.30	15.79	11.64	1.22	78772.18
23	7.08	13.12	57.00	1.14	16.15	11.44	1.23	80125.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.68	13.55	52.06	2.33	15.54	11.52	1.22	78943.72
最 大 值	13.92	15.23	65.16	4.46	16.66	12.50	1.26	84502.98
發生時間	20	12	14	9	1	14		18
最 小 值	4.21	12.04	38.42	1.14	14.25	10.80	1.18	72591.88
發生時間	17	3	2	23	12	2		14
零點偏移(率)	-0.02 %	-0.00 %	-0.03 %	-0.01 %		0.06		0.10 %
全幅偏移(率)	-0.42 %	0.54 %	-0.46 %	-0.49 %		0.38		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月02日

報表日期: 114年10月02日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.81	13.13	40.94	0.98	16.27	9.71	1.35	70725.69
1	8.83	12.79	45.55	0.81	18.03	9.48	1.39	73161.16
2	9.06	11.67	46.72	0.87	17.75	9.22	1.41	74239.01
3	9.13	11.14	45.79	0.67	18.08	9.09	1.38	73887.87
4	10.18	11.32	42.08	0.61	17.38	9.13	1.36	72699.73
5	10.03	12.11	38.13	0.86	16.94	8.90	1.36	73752.54
6	8.70	11.15	44.78	0.71	16.72	9.43	1.36	74330.46
7	8.34	10.88	43.15	0.73	16.88	9.30	1.39	73682.70
8	10.48	11.03	46.48	0.83	17.61	9.21	1.40	75857.44
9	5.26	13.34	57.48	0.86	15.27	11.52	1.40	59878.02
10	3.61	14.11	47.31	0.83	15.14	11.92	1.40	56170.24
11	8.70	12.73	44.34	0.50	18.68	9.37	1.41	78912.61
12	10.18	12.82	51.32	1.18	17.15	9.29	1.38	81488.75
13	9.63	11.86	63.19	1.34	15.24	10.26	1.35	75548.37
14	8.74	11.48	62.76	0.85	16.34	10.31	1.35	75709.80
15	12.55	11.33	55.35	1.33	16.90	9.82	1.35	79681.27
16	11.77	11.21	57.37	1.32	17.31	9.71	1.40	81606.17
17	6.40	12.03	59.89	1.13	16.72	10.26	1.42	82409.18
18	6.73	11.48	61.58	0.47	18.61	9.91	1.39	84845.82
19	6.93	12.98	51.55	0.94	17.28	9.50	1.35	80059.23
20	10.57	11.69	51.49	1.53	16.05	9.93	1.40	72767.44
21	10.30	12.16	51.44	1.28	17.56	9.24	1.37	78148.61
22	9.79	11.06	50.55	0.70	18.28	9.24	1.36	79377.44
23	5.98	10.77	54.93	0.38	18.54	9.30	1.36	78577.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.70	11.93	50.59	0.90	17.11	9.71	1.38	75313.20
最 大 值	12.55	14.11	63.19	1.53	18.68	11.92	1.44	84845.82
發生時間	15	10	13	20	11	10		18
最 小 值	3.61	10.77	38.13	0.38	15.14	8.90	1.34	56170.24
發生時間	10	23	5	23	10	5		10
零點偏移(率)	-0.09 %	-0.03 %	-0.06 %	-0.01 %		-0.03		-0.10 %
全幅偏移(率)	-0.25 %	0.53 %	-0.09 %	-0.20 %		0.40		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								