

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.08	12.71	42.50	2.36	19.02	10.67	1.34	80509.65
1	8.52	13.55	43.83	2.32	18.88	10.63	1.33	81596.06
2	8.73	13.29	47.14	3.34	18.69	10.78	1.34	81529.79
3	9.39	13.29	52.43	2.81	15.64	11.23	1.34	78205.58
4	9.15	13.26	57.42	1.93	16.61	11.11	1.34	79006.28
5	13.60	12.49	53.56	2.66	15.95	11.31	1.34	81164.85
6	8.84	12.66	58.60	2.23	15.61	11.40	1.34	76494.75
7	9.53	12.55	51.39	2.25	16.13	11.23	1.34	78161.57
8	10.12	12.71	52.31	2.09	16.21	11.22	1.34	77314.76
9	9.11	12.85	51.61	2.43	15.79	11.12	1.34	79674.32
10	10.69	11.48	51.71	2.37	15.89	11.39	1.34	79141.67
11	8.88	11.46	55.47	2.09	16.12	11.37	1.34	78514.83
12	9.05	12.04	47.10	1.43	17.88	11.35	1.34	77562.83
13	8.95	13.42	46.24	1.65	17.66	11.33	1.34	79302.23
14	9.60	12.12	46.95	1.70	17.69	11.22	1.34	78247.01
15	9.47	11.31	45.29	2.30	16.75	11.05	1.34	80083.43
16	9.42	11.38	53.25	2.37	17.02	11.08	1.34	81355.56
17	9.04	11.41	53.75	2.62	16.37	11.21	1.34	80649.88
18	7.74	12.30	54.32	1.64	17.56	11.71	1.34	75512.32
19	9.42	11.44	46.75	2.06	19.24	10.51	1.34	85366.82
20	9.17	11.67	56.57	1.84	19.41	10.74	1.34	83216.34
21	9.32	11.69	48.73	1.90	20.03	10.58	1.34	83368.52
22	8.89	11.82	47.52	2.18	18.09	11.27	1.34	78665.82
23	7.04	12.48	56.26	2.18	17.99	11.85	1.34	74740.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.24	12.31	50.86	2.20	17.34	11.14	1.34	79557.70
最大值	13.60	13.55	58.60	3.34	20.03	11.85	1.35	85366.82
發生時間	5	1	6	2	21	23		19
最小值	7.04	11.31	42.50	1.43	15.61	10.51	1.31	74740.04
發生時間	23	15	0	12	6	19		23
零點偏移(率)	-0.28 %	0.00 %	-0.03 %	-0.00 %		-0.05	-0.01	0.30 %
全幅偏移(率)	-0.71 %	-0.87 %	-0.60 %	-0.32 %		0.38	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.08	9.06	51.07	0.56	18.85	10.58	0.84	78363.36
1	10.17	10.39	59.08	0.81	18.76	10.69	0.83	79685.44
2	8.95	9.76	57.89	1.18	18.54	11.45	0.83	73948.00
3	9.11	8.46	62.82	0.54	19.83	10.45	0.83	79284.58
4	10.68	9.12	57.00	0.59	18.79	10.88	0.83	79466.46
5	9.02	10.32	53.61	0.78	18.29	10.92	0.83	79344.94
6	8.77	10.49	57.50	1.19	18.15	10.88	0.83	81486.86
7	10.06	9.70	56.44	1.16	17.60	11.39	0.83	74416.03
8	8.77	8.02	56.52	1.00	17.45	11.36	0.83	73663.21
9	9.65	8.54	51.27	1.24	17.23	11.19	0.83	76132.05
10	9.68	7.98	54.93	0.99	17.37	11.44	0.83	75333.08
11	9.76	8.23	52.62	1.01	17.44	11.31	0.83	74370.97
12	10.90	8.77	52.90	1.17	17.33	11.51	0.84	74818.52
13	8.82	8.73	57.28	1.39	17.10	11.40	0.83	75043.09
14	8.58	8.15	55.49	1.61	16.38	11.54	0.84	75527.69
15	10.44	8.22	54.56	1.49	16.19	11.53	0.84	76903.86
16	11.83	10.55	58.20	2.13	15.60	11.84	0.84	74366.29
17	8.61	23.79	64.43	1.73	16.46	11.86	0.85	68503.18
18	9.68	9.57	56.75	0.87	17.61	10.91	0.84	73638.61
19	11.43	8.30	62.43	0.61	18.62	10.73	0.84	77744.14
20	10.77	9.02	47.38	0.90	17.96	10.70	0.85	79093.08
21	9.22	9.77	60.92	0.64	18.47	11.24	0.85	71966.98
22	9.77	9.71	53.22	0.54	19.13	10.80	0.85	77777.54
23	8.64	11.32	52.16	1.07	18.06	11.70	0.84	68240.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.72	9.83	56.10	1.05	17.80	11.18	0.84	75796.61
最大值	11.83	23.79	64.43	2.13	19.83	11.86	0.89	81486.86
發生時間	16	17	17	16	3	17		6
最小值	8.58	7.98	47.38	0.54	15.60	10.45	0.83	68240.65
發生時間	14	10	20	3	16	3		23
零點偏移(率)	-0.05 %	-0.01 %	-0.05 %	-0.01 %		-0.10	-0.06	-0.10 %
全幅偏移(率)	-0.92 %	1.35 %	0.26 %	0.08 %		-0.09	0.31	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.41	10.22	55.28	2.77	18.25	9.96	1.36	74555.39
1	9.66	10.40	58.44	2.67	17.93	10.16	1.35	75023.25
2	8.55	10.38	60.35	3.19	19.00	9.96	1.34	76890.29
3	8.98	10.04	56.80	2.94	18.19	9.71	1.34	75486.04
4	9.21	10.14	53.58	3.13	18.34	9.84	1.34	74603.84
5	8.89	10.19	51.71	2.80	17.62	10.00	1.34	73203.47
6	9.75	10.00	59.01	2.92	17.60	9.82	1.33	74839.17
7	7.28	10.06	53.53	3.16	17.34	9.81	1.36	77173.34
8	9.33	10.66	55.40	3.01	17.80	10.08	1.36	73805.17
9	9.57	10.74	47.95	2.18	18.12	9.87	1.36	76243.79
10	9.03	11.29	48.25	1.96	17.42	9.84	1.36	76982.99
11	9.17	11.39	50.00	1.87	18.04	10.00	1.36	75498.49
12	9.49	12.18	47.66	1.67	18.17	9.99	1.36	75804.93
13	9.88	11.13	54.55	1.52	18.53	9.81	1.36	79636.02
14	9.03	11.50	56.14	1.50	17.02	10.37	1.36	76164.02
15	8.84	12.00	57.65	2.55	16.46	10.75	1.36	74211.02
16	9.77	13.06	55.36	3.24	16.37	10.61	1.36	78331.06
17	8.67	12.55	56.82	2.98	16.55	10.75	1.36	78006.59
18	9.72	12.44	56.45	3.10	16.95	10.60	1.36	77554.78
19	8.78	12.30	58.24	2.94	17.68	10.42	1.36	77549.89
20	9.54	12.19	59.95	3.12	19.67	10.06	1.36	80534.08
21	10.02	12.36	54.89	3.08	18.71	10.33	1.36	79980.18
22	9.11	12.68	52.81	3.11	18.86	10.61	1.36	76681.57
23	9.07	11.54	53.04	2.91	19.09	9.86	1.36	77767.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.16	11.31	54.74	2.68	17.90	10.13	1.36	76521.97
最大值	10.02	13.06	60.35	3.24	19.67	10.75	1.37	80534.08
發生時間	21	16	2	16	20	15		20
最小值	7.28	10.00	47.66	1.50	16.37	9.71	1.32	73203.47
發生時間	7	6	12	14	16	3		5
零點偏移(率)	-0.03 %	-0.00 %	-0.03 %	0.00 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-0.83 %	0.00 %	0.06 %	0.13 %		0.19	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								