

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月17日

報表日期: 115年07月17日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.44	12.66	61.12	1.26	20.14	10.95	1.26	81457.14
1	9.54	12.93	47.51	1.82	21.39	10.11	1.26	86769.04
2	8.66	12.81	58.91	2.24	18.36	11.09	1.26	82917.33
3	10.65	12.44	55.47	2.17	17.92	10.95	1.26	84435.43
4	8.00	12.66	60.85	1.67	18.79	10.93	1.27	83748.12
5	9.18	10.93	53.53	2.82	18.50	10.60	1.25	86629.50
6	9.53	11.01	56.07	2.68	18.72	10.50	1.25	87090.13
7	9.96	11.14	59.31	3.19	17.98	10.82	1.25	84891.13
8	6.95	11.25	60.35	1.73	18.81	10.62	1.25	86103.27
9	10.61	11.16	50.05	2.08	18.79	10.60	1.25	86136.14
10	8.33	11.79	58.60	1.88	17.78	10.90	1.25	84403.46
11	9.86	11.32	60.21	2.29	18.50	10.87	1.25	83735.71
12	11.39	11.15	54.73	2.37	17.38	10.96	1.25	84177.73
13	13.71	12.00	53.36	2.60	16.59	11.34	1.25	81962.55
14	7.42	11.72	55.75	1.47	17.94	11.10	1.25	82573.43
15	9.49	11.22	65.78	1.47	18.91	10.84	1.25	83299.91
16	9.93	11.62	42.84	2.09	17.65	10.71	1.25	85544.92
17	8.97	11.71	55.76	1.88	17.24	11.28	1.25	81636.32
18	9.63	11.57	52.51	2.14	16.99	11.32	1.25	81236.29
19	7.87	13.10	49.36	2.51	15.81	12.06	1.25	76148.50
20	9.50	10.90	47.15	1.67	19.11	10.32	1.25	87792.56
21	9.37	10.93	47.14	1.94	18.12	10.62	1.26	86170.08
22	9.73	11.17	40.16	2.35	16.97	10.82	1.25	86082.82
23	9.36	11.06	51.63	1.71	19.44	10.11	1.26	88868.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.25	11.68	54.09	2.08	18.24	10.85	1.25	84325.41
最 大 值	13.71	13.10	65.78	3.19	21.39	12.06	1.28	88868.26
發生時間	13	19	15	7	1	19		23
最 小 值	4.44	10.90	40.16	1.26	15.81	10.11	1.25	76148.50
發生時間	0	20	22	0	19	1		19
零點偏移(率)	-0.06 %	-0.17 %	-0.02 %	-0.01 %		-0.03	-0.01	0.10 %
全幅偏移(率)	1.19 %	0.48 %	0.71 %	0.68 %		-0.15	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.27	12.27	57.80	2.33	19.62	10.56	1.27	78478.09
1	2.94	13.08	58.72	2.66	20.51	11.08	1.30	72999.85
2	4.22	12.77	57.93	2.62	20.28	9.97	1.31	80035.15
3	3.57	12.97	63.92	2.67	19.86	10.18	1.31	80208.37
4	7.87	12.73	58.16	2.85	19.90	9.95	1.30	81730.47
5	6.00	13.01	56.58	2.74	19.52	10.24	1.28	80980.43
6	9.73	12.81	52.68	2.82	19.52	10.07	1.29	81739.71
7	5.77	11.35	54.50	1.93	18.65	10.03	1.31	79187.78
8	8.56	11.51	59.37	2.75	18.93	10.02	1.31	81184.18
9	4.27	11.72	62.41	2.40	17.54	10.37	1.29	79371.41
10	10.20	11.73	62.03	2.62	17.51	10.42	1.27	79415.73
11	5.55	11.61	63.34	2.33	17.56	10.32	1.29	80075.63
12	9.03	12.00	58.59	2.54	17.70	10.57	1.31	76931.79
13	8.58	11.78	60.23	2.49	17.31	10.31	1.28	78591.80
14	9.80	11.98	61.92	2.52	19.62	10.20	1.27	78375.57
15	7.05	11.69	59.41	2.48	18.41	10.26	1.28	78094.82
16	9.80	11.89	60.99	3.03	19.10	10.32	1.31	78469.48
17	8.02	12.25	60.94	2.48	17.41	10.66	1.30	78123.14
18	7.70	12.11	58.91	2.31	17.50	10.59	1.27	76223.54
19	8.85	12.68	57.73	2.90	16.20	10.35	1.27	77052.88
20	8.97	4.54	56.99	1.68	17.13	10.06	1.27	79955.47
21	8.41	1.13	52.97	0.24	18.16	9.76	1.27	77752.74
22	9.75	9.79	55.60	2.30	17.72	9.73	1.30	78367.16
23	9.45	11.52	58.31	2.59	18.05	9.96	1.29	78225.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.60	11.29	58.75	2.43	18.49	10.25	1.29	78815.46
最 大 值	10.20	13.08	63.92	3.03	20.51	11.08	1.34	81739.71
發生時間	10	1	3	16	1	1		6
最 小 值	2.94	1.13	52.68	0.24	16.20	9.73	1.26	72999.85
發生時間	1	21	6	21	19	22		1
零點偏移(率)	-0.14 %	-0.03 %	-0.04 %	0.00 %		-0.07	-0.01	0.10 %
全幅偏移(率)	2.00 %	0.90 %	1.60 %	1.57 %		0.30	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								