

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.96	2.18	50.80	2.12	19.56	10.56	1.38	72715.40
1	6.97	2.18	58.81	1.94	19.74	11.01	1.38	69172.99
2	2.63	2.23	59.79	1.79	19.90	10.82	1.38	71262.22
3	8.89	2.49	41.76	2.44	18.53	10.73	1.36	73543.96
4	4.89	2.44	40.25	2.31	17.72	11.07	1.35	71400.65
5	4.33	3.60	47.93	3.04	18.29	11.12	1.36	68935.89
6	5.09	2.45	53.80	2.95	19.11	11.20	1.36	69065.75
7	3.56	2.33	45.67	2.54	19.33	10.80	1.38	72260.27
8	3.50	2.40	45.35	2.59	19.23	11.02	1.37	69664.40
9	0.10	2.35	40.22	1.87	20.45	10.17	1.37	73129.70
10	0.06	2.38	35.06	2.35	18.66	10.80	1.37	68406.93
11	0.36	3.05	39.35	2.65	17.49	10.89	1.35	68903.00
12	7.03	4.01	41.78	3.20	17.27	10.98	1.35	68718.59
13	7.76	2.76	43.15	3.21	17.66	11.00	1.34	69027.15
14	8.13	2.51	48.62	3.23	19.72	10.88	1.35	69207.92
15	9.74	2.45	37.09	2.99	19.42	10.30	1.36	73767.76
16	9.74	2.64	37.09	3.05	18.36	10.48	1.37	73121.34
17	3.39	2.63	44.92	2.65	18.00	11.06	1.37	69854.04
18	10.62	2.09	48.45	2.92	18.72	10.47	1.37	72945.97
19	8.51	2.11	46.87	2.74	19.27	10.38	1.36	72450.40
20	12.29	3.54	38.40	3.74	16.65	10.82	1.37	70380.29
21	9.79	4.06	39.69	3.05	17.62	10.78	1.38	70010.88
22	8.02	2.05	46.99	2.70	18.53	10.74	1.36	71333.85
23	4.33	2.78	62.25	2.71	18.41	11.99	1.37	63755.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.15	2.65	45.59	2.70	18.65	10.84	1.36	70543.11
最大值	12.29	4.06	62.25	3.74	20.45	11.99	1.40	73767.76
發生時間	20	21	23	20	9	23		15
最小值	0.06	2.05	35.06	1.79	16.65	10.17	1.33	63755.27
發生時間	10	22	10	2	20	9		23
零點偏移(率)	-0.06 %	0.00 %	-0.03 %	-0.02 %		0.06	0.00	0.00 %
全幅偏移(率)	0.39 %	-2.94 %	-0.18 %	-1.35 %		-0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.12	2.70	40.82	0.61	20.36	9.80	1.41	82592.89
1	0.77	2.52	60.63	0.34	21.98	10.16	1.41	80150.18
2	5.86	2.97	42.60	1.04	20.06	9.79	1.41	83867.87
3	4.94	2.54	45.81	1.55	17.87	10.58	1.41	79279.00
4	3.66	2.57	42.45	1.12	18.91	9.92	1.41	83527.51
5	5.56	5.80	50.38	1.13	19.95	9.93	1.41	83983.93
6	3.14	4.04	39.40	0.99	20.57	9.57	1.43	86846.85
7	2.48	4.06	45.29	1.11	19.57	10.15	1.43	80890.50
8	2.79	5.65	46.18	0.98	20.00	9.96	1.44	82847.08
9	8.27	8.94	47.58	1.24	21.89	9.08	1.44	87909.62
10	8.27	3.99	46.68	2.12	18.78	9.33	1.43	85597.52
11	8.64	4.90	48.93	1.79	17.93	9.52	1.44	80868.64
12	9.85	5.17	32.97	3.85	17.02	9.68	1.44	75845.04
13	8.04	2.76	41.21	1.90	18.62	9.68	1.44	79108.08
14	9.11	4.02	46.25	1.33	20.21	9.31	1.45	83227.74
15	7.64	4.10	35.89	1.40	18.84	9.47	1.44	82273.20
16	9.43	2.91	35.90	1.80	17.94	9.54	1.44	81705.69
17	9.86	4.49	39.79	1.44	20.33	8.93	1.44	86064.64
18	8.48	3.13	48.60	1.28	19.66	9.25	1.43	82543.31
19	9.41	3.40	39.19	1.82	17.92	9.50	1.42	81014.73
20	9.00	3.95	42.43	2.05	16.51	9.78	1.43	79667.60
21	10.15	2.23	44.38	2.06	17.29	9.54	1.43	80036.58
22	7.61	2.26	56.24	1.07	19.95	9.43	1.41	81344.88
23	5.76	2.48	44.42	1.06	19.98	9.24	1.41	79712.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.66	3.82	44.33	1.46	19.26	9.63	1.43	82121.06
最大值	10.15	8.94	60.63	3.85	21.98	10.58	1.46	87909.62
發生時間	21	9	1	12	1	3		9
最小值	0.77	2.23	32.97	0.34	16.51	8.93	1.40	75845.04
發生時間	1	21	12	1	20	17		12
零點偏移(率)	-0.04 %	-0.01 %	-0.04 %	0.00 %		-0.02	0.00	-0.10 %
全幅偏移(率)	-0.18 %	-0.47 %	-0.55 %	-0.11 %		0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.62	1.97	62.01	2.53	18.05	10.36	1.30	83083.82
1	3.62	1.88	61.54	2.62	18.99	10.32	1.30	83437.86
2	5.60	5.77	52.94	2.64	18.00	10.12	1.29	85587.41
3	7.97	2.13	57.74	2.94	17.01	10.23	1.27	84479.30
4	6.72	1.96	55.53	2.82	16.60	10.65	1.27	82882.69
5	7.81	1.97	52.10	3.07	16.82	10.45	1.25	82079.89
6	7.38	3.68	48.85	2.94	17.13	10.32	1.27	83251.81
7	9.38	3.73	56.12	3.53	18.06	10.22	1.30	80029.68
8	6.94	5.18	40.74	3.00	17.44	9.91	1.28	80334.45
9	7.44	2.96	50.22	3.17	17.73	10.11	1.31	84058.73
10	5.33	1.62	51.19	3.02	16.74	10.43	1.29	82018.78
11	8.59	1.58	56.78	3.46	15.52	10.66	1.33	79744.08
12	7.43	1.93	64.10	3.33	16.07	10.68	1.33	82592.26
13	3.74	1.65	65.43	3.19	15.51	10.99	1.34	79927.18
14	5.30	1.73	66.13	3.08	17.19	10.74	1.33	80857.28
15	7.15	4.22	55.93	3.18	16.31	10.37	1.33	84897.68
16	5.28	3.05	59.88	3.27	15.40	10.67	1.35	81695.00
17	7.78	3.78	61.86	3.58	15.29	10.75	1.34	80939.84
18	5.85	1.84	62.47	3.15	16.02	10.64	1.31	82211.40
19	9.34	2.44	59.02	3.63	14.71	10.84	1.28	81211.66
20	9.43	3.41	62.74	4.08	13.99	10.96	1.25	78884.03
21	9.49	2.58	61.07	3.78	15.18	10.77	1.25	79669.62
22	8.95	3.17	66.42	3.36	17.22	10.53	1.30	80642.45
23	6.83	1.88	63.52	3.02	17.69	10.62	1.30	80980.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.96	2.75	58.10	3.18	16.61	10.51	1.30	81895.73
最大值	9.49	5.77	66.42	4.08	18.99	10.99	1.36	85587.41
發生時間	21	2	22	20	1	13		2
最小值	3.62	1.58	40.74	2.53	13.99	9.91	1.24	78884.03
發生時間	0	11	8	0	20	8		20
零點偏移(率)	-0.02 %	-0.02 %	-0.02 %	-0.01 %		0.06	0.00	0.00 %
全幅偏移(率)	-4.57 %	-3.44 %	-1.31 %	-0.60 %		0.39	0.02	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								