

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.33	11.82	55.44	2.76	16.74	11.23	1.25	82052.69
1	7.38	11.86	57.69	1.89	17.89	11.24	1.25	81015.17
2	11.67	11.89	53.05	3.00	15.88	11.54	1.24	80236.12
3	8.21	11.85	59.89	2.24	17.09	11.38	1.24	80943.96
4	11.92	11.87	49.76	3.12	16.26	11.19	1.23	83090.74
5	12.25	11.74	42.87	2.05	16.20	11.35	1.23	81678.63
6	6.14	11.59	55.62	2.15	16.80	11.36	1.23	81095.91
7	9.28	12.18	60.72	3.15	15.87	11.94	1.24	77355.04
8	10.71	11.79	49.07	3.34	15.29	11.74	1.23	79545.03
9	9.70	12.66	53.30	2.96	17.28	11.14	1.20	82845.92
10	6.37	11.65	50.74	3.11	15.23	11.80	1.22	78851.37
11	13.08	11.42	57.60	2.90	16.10	11.49	1.21	80937.56
12	5.62	11.50	57.46	2.50	15.84	11.61	1.23	79927.64
13	9.55	11.39	51.77	3.24	15.91	11.52	1.21	80365.46
14	7.43	11.39	59.26	2.05	17.47	11.35	1.21	80183.56
15	7.61	11.29	51.11	2.49	16.34	11.38	1.21	81230.55
16	8.90	11.37	64.32	1.98	18.03	11.25	1.21	80965.08
17	8.02	11.15	46.82	2.63	16.45	11.20	1.21	82775.57
18	8.49	12.52	58.68	1.50	14.86	12.34	1.19	75015.20
19	9.75	11.54	62.41	1.22	16.32	11.46	1.22	81204.64
20	10.15	11.23	63.65	1.09	17.45	11.03	1.24	83267.29
21	11.22	10.98	61.35	1.07	18.61	10.66	1.24	85046.07
22	9.33	11.31	52.96	1.42	16.97	10.76	1.23	85428.34
23	5.81	11.66	61.71	1.59	17.81	11.34	1.23	80114.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.08	11.65	55.72	2.31	16.61	11.39	1.22	81048.82
最大值	13.08	12.66	64.32	3.34	18.61	12.34	1.25	85428.34
發生時間	11	9	16	8	21	18		22
最小值	5.62	10.98	42.87	1.07	14.86	10.66	1.18	75015.20
發生時間	12	21	5	21	18	21		18
零點偏移(率)	-0.08 %	-0.02 %	-0.01 %	0.00 %		-0.02	-0.01	0.10 %
全幅偏移(率)	-0.96 %	-1.10 %	0.22 %	-0.59 %		0.08	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.67	12.16	51.36	1.76	17.90	10.39	1.01	79419.84
1	0.57	11.97	53.81	1.55	18.34	10.46	1.02	80443.25
2	0.48	12.11	46.38	1.16	17.96	10.14	1.02	80603.15
3	0.39	11.82	50.06	1.47	17.51	10.37	1.02	81435.20
4	1.06	11.84	58.55	1.67	16.90	10.59	1.02	80534.69
5	1.13	12.74	57.99	1.09	18.08	10.50	1.02	81367.37
6	0.61	11.98	46.59	1.17	18.55	10.49	1.02	80692.06
7	0.39	11.92	47.03	1.04	18.23	10.55	1.02	81459.38
8	0.23	11.86	54.79	0.64	18.46	10.47	1.02	80305.65
9	0.11	11.80	48.70	0.94	17.38	10.60	1.02	79265.75
10	0.15	12.18	53.67	0.79	18.43	10.49	1.02	80944.24
11	0.10	12.23	51.56	1.57	16.31	10.85	1.01	79051.75
12	0.10	12.09	51.74	1.55	17.25	10.78	1.03	79021.34
13	0.10	11.72	50.96	1.47	17.09	10.49	1.02	78469.67
14	0.20	12.68	46.40	1.19	18.63	10.29	1.02	78664.52
15	0.16	12.07	48.04	0.73	18.73	10.36	1.00	79693.94
16	0.14	11.93	50.13	0.92	18.69	10.42	1.01	81830.08
17	0.10	12.20	50.40	1.71	17.03	10.90	1.02	79302.04
18	0.10	13.07	58.05	1.58	16.77	11.57	1.01	71894.61
19	0.13	12.99	62.15	0.66	18.33	11.39	0.99	75738.34
20	0.14	11.77	49.72	1.04	18.63	10.31	0.99	82535.27
21	0.19	11.87	50.94	0.66	18.89	10.32	1.00	82845.16
22	0.16	11.97	47.38	1.28	18.87	10.37	0.99	81105.15
23	0.18	12.66	60.95	1.03	19.07	11.03	1.00	77772.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	0.32	12.15	51.97	1.19	18.00	10.59	1.01	79766.44
最大值	1.13	13.07	62.15	1.76	19.07	11.57	1.06	82845.16
發生時間	5	18	19	0	23	18		21
最小值	0.10	11.72	46.38	0.64	16.31	10.14	0.97	71894.61
發生時間	11	13	2	8	11	2		18
零點偏移(率)	-0.03 %	-0.02 %	-0.11 %	-0.09 %		0.00	-0.01	-0.20 %
全幅偏移(率)	2.56 %	-0.68 %	0.15 %	-1.53 %		0.11	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.04	11.45	46.15	2.77	19.83	8.86	1.30	74486.24
1	9.50	11.98	44.86	2.85	19.49	9.15	1.31	74137.12
2	9.36	11.88	49.28	2.99	17.66	9.23	1.31	74046.06
3	10.75	12.48	52.13	3.51	17.65	9.29	1.32	72270.69
4	6.43	12.33	59.51	2.85	18.54	9.03	1.34	72594.81
5	8.05	11.90	58.44	3.01	17.48	8.86	1.34	73594.70
6	6.15	12.40	60.78	2.86	18.64	9.05	1.32	73017.72
7	5.38	13.44	45.54	2.83	18.54	9.38	1.35	70217.12
8	4.90	11.26	48.19	2.64	18.72	9.02	1.36	73879.79
9	5.97	11.23	50.20	2.58	18.77	9.26	1.37	73548.12
10	5.56	11.05	49.44	2.62	18.35	9.33	1.36	74474.33
11	6.16	10.98	43.84	2.38	17.88	9.47	1.38	74100.74
12	6.84	11.08	48.81	2.46	18.20	9.75	1.33	75381.99
13	3.39	10.84	53.26	2.53	18.04	9.56	1.35	74519.60
14	4.35	11.14	41.23	2.21	17.83	9.82	1.34	72195.07
15	2.53	11.16	43.56	2.24	18.40	9.84	1.33	68950.42
16	3.00	10.83	39.08	2.31	18.26	9.31	1.34	75203.98
17	2.54	11.00	39.71	2.35	18.56	9.54	1.35	73085.42
18	2.06	11.59	43.13	2.40	15.74	10.46	1.34	65215.51
19	2.07	12.06	41.39	2.58	19.10	9.11	1.35	75144.65
20	2.79	10.95	45.50	2.41	16.93	9.68	1.36	76711.30
21	3.62	10.70	48.25	2.69	19.95	9.07	1.36	76102.57
22	5.77	10.78	43.02	2.79	19.93	8.86	1.36	77467.38
23	3.68	10.81	50.58	2.44	21.03	8.84	1.36	78502.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.37	11.47	47.75	2.64	18.48	9.32	1.34	73701.99
最大值	10.75	13.44	60.78	3.51	21.03	10.46	1.40	78502.44
發生時間	3	7	6	3	23	18		23
最小值	2.06	10.70	39.08	2.21	15.74	8.84	1.29	65215.51
發生時間	18	21	16	14	18	23		18
零點偏移(率)	-0.08 %	-0.03 %	-0.04 %	0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	1.50 %	0.00 %	1.63 %	0.18 %		0.31	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								