

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.82	7.60	66.63	0.92	17.68	12.32	1.09	74259.81
1	4.16	8.21	60.47	1.01	17.95	12.15	1.08	75712.33
2	4.96	8.32	64.14	0.95	17.67	11.13	1.06	84621.85
3	4.06	7.18	48.59	1.73	16.75	11.67	1.04	81239.40
4	3.62	6.19	51.42	1.30	16.22	12.08	1.06	78021.09
5	2.18	7.89	46.59	1.76	15.44	12.11	1.06	78531.15
6	4.70	7.14	59.92	1.96	15.92	12.32	1.04	75911.65
7	5.11	5.99	58.39	1.18	16.95	12.03	1.06	78747.30
8	5.35	6.11	57.85	1.25	17.03	11.77	1.07	81037.95
9	4.91	5.73	50.80	1.52	17.03	11.50	1.03	86349.24
10	6.23	5.80	50.39	1.90	16.43	11.91	1.05	83407.03
11	4.06	5.40	45.93	2.03	15.38	12.01	1.06	82711.81
12	2.86	7.83	47.61	1.58	15.72	11.88	1.04	83267.31
13	3.26	12.97	56.70	1.83	16.19	12.17	1.06	80069.94
14	2.44	6.89	60.98	1.16	16.93	11.88	1.04	82291.65
15	8.03	8.03	42.97	2.86	15.96	11.96	1.06	82522.88
16	9.98	7.58	55.97	1.77	17.20	11.80	1.06	82823.63
17	8.94	6.62	55.76	1.63	16.80	11.74	1.05	83796.29
18	8.76	7.22	57.92	1.57	17.15	11.42	1.06	84114.70
19	4.55	6.90	59.85	0.79	17.30	11.73	1.06	80094.59
20	6.94	6.82	51.32	0.95	18.65	10.83	1.06	86522.42
21	7.92	6.71	46.49	1.47	16.83	11.46	1.06	82179.82
22	4.67	6.92	61.33	0.98	17.21	11.94	1.06	77609.90
23	3.78	7.16	64.79	0.74	17.84	11.46	1.06	81699.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.26	7.22	55.12	1.45	16.84	11.80	1.06	81147.64
最大值	9.98	12.97	66.63	2.86	18.65	12.32	1.09	86522.42
發生時間	16	13	0	15	20	0		20
最小值	2.18	5.40	42.97	0.74	15.38	10.83	1.02	74259.81
發生時間	5	11	15	23	11	20		0
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.00 %	-0.60 %	0.01 %	0.03 %		0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.21	5.43	55.50	1.03	18.80	11.28	1.05	76123.22
1	2.85	6.57	47.37	1.84	18.67	10.28	1.04	84076.20
2	3.00	6.07	60.35	2.11	16.82	11.85	1.04	73974.02
3	2.82	4.09	47.26	1.81	17.75	11.19	1.00	78434.25
4	3.17	4.52	50.79	1.79	16.70	11.37	1.02	77860.31
5	3.10	6.31	54.42	2.30	16.43	10.92	1.03	82613.41
6	2.43	4.06	48.76	1.73	18.08	10.86	1.04	78935.05
7	2.24	3.78	43.26	1.97	16.61	11.12	1.03	79701.55
8	1.12	4.05	62.91	2.72	14.74	12.02	1.02	74719.48
9	1.01	4.34	46.28	1.77	17.40	10.73	1.02	81640.53
10	5.02	4.13	36.85	2.92	14.93	11.19	1.04	79571.22
11	1.81	3.42	60.86	2.71	14.48	11.52	1.03	78563.88
12	0.40	5.21	58.54	2.27	14.77	11.61	1.03	77001.10
13	0.60	7.54	58.00	2.48	14.82	11.62	1.04	77355.41
14	0.13	7.54	66.17	1.94	14.91	11.88	1.06	74893.66
15	0.12	7.58	66.53	1.62	16.20	11.78	1.04	74489.16
16	0.41	7.74	42.44	1.98	16.73	10.77	1.03	82027.56
17	2.49	4.56	58.59	2.75	15.42	10.97	1.04	82226.25
18	2.56	2.76	61.82	1.83	17.04	10.74	1.04	82085.77
19	3.59	2.97	59.44	1.28	18.00	10.41	1.04	83280.04
20	11.54	3.40	50.21	2.20	16.97	10.86	1.02	80465.10
21	8.02	3.41	45.28	1.76	17.42	10.75	1.02	81369.86
22	3.87	3.05	66.84	1.25	17.77	11.22	1.04	77553.79
23	6.31	4.05	47.75	1.60	17.81	10.80	1.02	80307.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.95	4.86	54.01	1.99	16.64	11.16	1.03	79136.16
最大值	11.54	7.74	66.84	2.92	18.80	12.02	1.06	84076.20
發生時間	20	16	22	10	0	8		1
最小值	0.12	2.76	36.85	1.03	14.48	10.28	0.99	73974.02
發生時間	15	18	10	0	11	1		2
零點偏移(率)	-0.12 %	-0.00 %	-0.03 %	-0.02 %		-0.04		-0.10 %
全幅偏移(率)	0.14 %	-0.35 %	0.56 %	0.21 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.95	5.63	56.17	0.75	16.55	10.51	1.04	78830.10
1	2.38	4.05	56.06	0.59	18.11	10.37	1.04	79868.19
2	2.34	5.24	57.18	0.81	15.65	10.68	1.03	77640.78
3	2.46	4.88	56.33	0.59	16.91	10.62	1.01	74808.07
4	2.54	4.92	51.65	0.67	16.33	10.25	1.01	76243.16
5	2.38	4.11	57.67	0.42	17.24	10.57	1.03	75923.34
6	3.05	4.49	58.81	0.60	16.94	10.38	1.03	78152.68
7	0.49	6.68	51.30	0.80	15.76	10.52	1.02	78730.92
8	0.28	8.46	53.36	0.69	16.03	10.40	1.03	78475.07
9	1.41	6.39	54.68	0.73	16.67	10.34	1.03	80249.90
10	0.52	5.66	49.96	0.70	15.22	10.56	1.03	78061.60
11	1.17	5.13	55.22	1.47	13.75	10.96	1.04	74526.48
12	1.15	5.11	57.37	1.47	13.95	10.87	1.02	75967.33
13	1.21	5.08	59.66	1.12	14.64	10.96	1.04	76175.23
14	1.16	5.00	59.35	0.54	15.83	10.73	1.03	78655.11
15	1.21	5.60	61.35	0.65	16.65	10.68	1.02	80977.33
16	1.21	5.51	60.37	0.69	16.60	10.49	1.04	82500.61
17	2.86	8.56	57.40	1.78	14.36	10.87	1.03	79479.35
18	1.55	7.90	61.63	1.37	15.12	11.02	1.00	78028.08
19	1.13	3.24	57.78	0.61	17.10	10.49	0.99	81318.52
20	2.38	4.19	58.80	0.57	17.85	10.10	1.01	83472.10
21	2.14	3.91	54.53	0.72	16.72	10.35	1.02	81158.43
22	1.97	4.00	63.73	0.59	16.92	10.71	1.03	78198.76
23	4.22	4.97	53.73	0.75	17.27	10.22	1.02	82217.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.80	5.36	56.84	0.82	16.17	10.57	1.02	78735.78
最大值	4.22	8.56	63.73	1.78	18.11	11.02	1.05	83472.10
發生時間	23	17	22	17	1	18		20
最小值	0.28	3.24	49.96	0.42	13.75	10.10	0.99	74526.48
發生時間	8	19	10	5	11	20		11
零點偏移(率)	-0.06 %	-0.00 %	-0.01 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	-0.56 %	-0.02 %	0.10 %		-0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								