

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.66	7.30	51.88	0.77	19.32	11.55	1.00	76653.14
1	3.62	8.44	61.02	1.05	19.30	11.53	1.04	76629.75
2	8.23	9.92	46.09	1.79	17.11	11.74	1.02	75854.39
3	3.54	8.13	68.89	0.52	20.01	11.16	1.02	79269.03
4	6.98	9.94	36.18	1.37	17.91	11.26	1.02	77843.70
5	5.23	10.65	60.33	0.59	20.07	11.25	1.04	75237.31
6	9.17	13.11	40.74	1.61	19.35	10.26	1.03	82266.65
7	8.27	6.27	32.03	2.30	15.54	11.69	1.03	72958.11
8	8.60	6.01	37.28	1.78	16.93	11.52	1.05	73293.09
9	8.44	10.04	44.00	2.48	17.24	11.25	1.03	75605.50
10	7.10	19.89	37.86	2.31	17.43	10.89	1.06	76269.67
11	3.36	6.19	44.12	2.54	15.09	11.79	1.03	71721.71
12	9.53	9.49	57.88	2.44	17.54	11.37	1.05	77724.29
13	8.97	6.82	41.86	2.83	16.35	11.52	1.03	74473.91
14	3.53	10.60	60.65	1.95	17.04	11.80	1.05	74303.45
15	5.68	10.15	46.32	2.58	15.79	11.45	1.06	74345.22
16	7.33	7.28	57.01	2.42	16.33	11.82	1.06	73914.30
17	7.55	9.66	51.44	2.25	16.28	11.74	1.06	77773.80
18	2.64	8.49	67.41	1.18	18.90	11.42	1.10	78310.88
19	4.76	9.37	53.99	1.58	18.51	11.24	1.06	79618.52
20	0.23	7.86	68.91	1.20	17.95	11.92	1.05	74840.90
21	2.55	7.02	56.89	1.62	18.32	11.11	1.03	81331.21
22	2.98	8.90	64.39	2.01	17.38	11.45	1.02	79118.43
23	1.19	9.31	53.74	2.49	17.08	11.57	1.02	78269.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.46	9.20	51.70	1.82	17.62	11.43	1.04	76567.78
最大值	9.53	19.89	68.91	2.83	20.07	11.92	1.18	82266.65
發生時間	12	10	20	13	5	20		6
最小值	0.23	6.01	32.03	0.52	15.09	10.26	0.99	71721.71
發生時間	20	8	7	3	11	6		11
零點偏移(率)	-0.01 %	-0.05 %	-0.08 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	-1.13 %	-0.48 %	-0.03 %	0.03 %		-0.17		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.93	12.57	51.22	2.32	17.76	10.37	0.99	84628.89
1	2.85	8.19	54.52	3.25	16.45	10.56	0.99	84311.63
2	4.53	4.65	49.96	1.94	18.16	10.22	0.97	86833.11
3	3.70	8.24	57.83	1.68	18.82	10.29	0.97	85082.26
4	3.51	7.06	62.82	1.72	18.26	10.43	0.97	84619.46
5	6.47	8.37	44.68	1.86	18.65	9.95	0.97	87793.94
6	11.23	6.54	55.38	3.10	16.35	10.96	0.99	79361.93
7	9.07	5.80	39.66	2.99	17.77	10.38	0.99	85716.78
8	7.89	8.39	44.44	2.13	18.40	10.22	1.00	85210.27
9	9.38	5.55	47.63	1.86	17.90	10.26	1.00	85666.09
10	6.83	3.50	54.26	1.20	18.53	10.05	1.00	85841.65
11	8.94	3.00	41.35	1.90	18.58	10.09	1.01	85370.81
12	9.30	5.89	43.00	1.84	17.56	10.36	1.01	84289.55
13	5.78	3.80	47.16	1.46	17.35	10.63	1.00	82968.38
14	2.55	5.14	52.74	1.35	16.94	10.65	0.99	83286.31
15	2.64	7.28	55.08	1.25	16.93	10.57	0.99	84854.01
16	1.40	8.56	44.58	1.71	16.84	10.65	0.99	84016.06
17	0.22	8.99	41.58	1.22	18.33	10.53	0.99	83138.04
18	0.04	7.58	51.39	0.68	19.59	10.54	0.99	82019.75
19	0.08	8.72	40.90	1.70	19.15	9.82	0.99	88585.56
20	0.09	1.75	46.48	2.16	17.61	10.35	0.99	85670.43
21	0.53	2.33	54.83	2.20	17.83	10.35	0.99	85380.26
22	1.51	3.67	51.57	2.07	17.77	10.40	0.99	84974.50
23	2.36	4.45	57.22	1.64	18.42	10.26	0.99	85208.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.24	6.25	49.59	1.88	17.91	10.37	0.99	84784.52
最大值	11.23	12.57	62.82	3.25	19.59	10.96	1.02	88585.56
發生時間	6	0	4	1	18	6		19
最小值	0.04	1.75	39.66	0.68	16.35	9.82	0.97	79361.93
發生時間	18	20	7	18	6	19		6
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	-0.07 %		0.00		-0.20 %
全幅偏移(率)	0.04 %	0.00 %	-0.35 %	0.00 %		-0.15		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.66	3.09	31.65	1.24	16.81	10.19	1.00	76396.72
1	5.36	7.52	39.44	1.34	16.63	10.79	1.02	76688.37
2	6.05	4.67	63.82	1.39	18.05	10.33	1.03	80185.49
3	9.98	7.58	46.02	2.31	17.43	9.88	1.01	86280.81
4	5.40	5.67	53.19	1.91	15.42	11.12	0.99	75658.25
5	8.81	4.45	69.83	1.78	16.81	10.54	0.99	80210.48
6	8.41	5.20	52.69	1.83	16.35	10.32	0.99	79062.20
7	9.72	4.63	55.16	2.59	16.98	9.67	1.05	85093.03
8	8.17	5.64	53.68	2.19	14.61	10.73	1.04	74215.27
9	8.23	9.99	48.85	1.87	16.89	10.09	1.07	77267.66
10	9.48	3.86	52.74	2.37	16.07	10.14	1.03	73082.65
11	8.91	5.35	40.26	2.00	15.89	9.85	1.05	73754.55
12	9.65	4.32	40.87	1.75	15.77	10.09	1.07	71543.98
13	7.26	3.50	48.47	1.79	14.62	10.65	1.06	70184.29
14	7.67	5.87	49.91	1.06	16.14	10.47	1.03	73853.33
15	6.99	6.15	47.19	1.62	14.84	10.34	1.02	74207.31
16	6.66	3.50	45.07	2.01	13.75	10.83	1.04	70529.17
17	3.29	3.73	44.80	0.99	15.69	10.66	1.06	73160.67
18	3.64	3.19	50.62	1.32	15.26	10.25	1.07	77183.59
19	6.55	3.46	56.08	1.17	16.11	10.67	1.08	81911.85
20	2.14	3.55	62.66	0.83	16.19	11.59	1.06	76426.80
21	3.98	3.08	47.47	0.94	17.10	10.39	1.04	89111.56
22	7.96	6.53	57.28	1.41	15.76	11.21	1.04	81189.48
23	6.56	7.55	48.33	1.76	14.96	11.07	1.03	78946.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.02	5.09	50.25	1.64	16.01	10.49	1.04	77339.33
最大值	9.98	9.99	69.83	2.59	18.05	11.59	1.10	89111.56
發生時間	3	9	5	7	2	20		21
最小值	2.14	3.08	31.65	0.83	13.75	9.67	0.99	70184.29
發生時間	20	21	0	20	16	7		13
零點偏移(率)	-0.07 %	0.00 %	-0.09 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.04 %	-0.58 %	-0.67 %	-0.10 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								