

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年12月23日

報表日期: 114年12月23日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	13.51	14.79	69.96	1.31	16.23	12.70	1.25	71685.78
1	8.11	15.09	60.16	2.88	16.02	12.84	1.25	70950.05
2	7.93	13.29	47.70	3.52	17.21	11.51	1.26	81015.95
3	11.32	13.57	43.30	3.97	14.57	11.96	1.27	79223.26
4	2.45	14.67	56.76	1.41	15.78	12.66	1.27	71868.44
5	7.61	14.76	65.20	3.32	14.38	12.95	1.29	73894.88
6	12.46	13.82	44.74	2.64	16.18	12.16	1.29	75698.88
7	10.15	13.28	40.24	3.34	17.02	11.44	1.29	80889.73
8	11.37	11.75	50.75	4.27	16.33	11.64	1.30	79968.61
9	4.83	12.13	62.53	0.94	16.44	11.89	1.29	77303.73
10	5.08	12.12	53.60	1.57	16.19	11.05	1.28	84822.46
11	4.57	12.19	45.84	1.31	15.39	11.50	1.29	81272.71
12	7.94	11.63	42.75	1.31	16.74	11.21	1.26	82682.89
13	13.16	11.29	48.77	1.90	16.14	11.26	1.28	82466.38
14	2.70	13.07	64.50	0.77	16.46	12.54	1.29	71846.05
15	7.34	12.09	56.66	1.57	18.18	11.62	1.27	78297.28
16	12.64	11.20	39.56	2.25	19.20	10.45	1.27	86107.79
17	13.11	12.40	40.40	3.27	19.38	10.23	1.25	87796.12
18	13.64	12.46	45.29	3.40	18.03	10.72	1.27	85310.41
19	12.78	12.52	44.72	4.28	17.70	10.86	1.27	85062.90
20	12.68	12.71	53.21	3.86	17.72	11.14	1.27	84047.65
21	13.22	13.46	50.71	3.46	15.39	11.66	1.27	83344.02
22	12.42	13.66	54.41	2.55	15.95	11.98	1.28	79018.10
23	13.04	13.80	63.92	2.29	16.90	11.89	1.29	78906.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.75	12.99	51.90	2.56	16.65	11.66	1.28	79728.37
最 大 值	13.64	15.09	69.96	4.28	19.38	12.95	1.31	87796.12
發生時間	18	1	0	19	17	5		17
最 小 值	2.45	11.20	39.56	0.77	14.38	10.23	1.25	70950.05
發生時間	4	16	16	14	5	17		1
零點偏移(率)	-0.03 %	-0.01 %	-0.01 %	0.00 %		-0.05	-0.01	0.30 %
全幅偏移(率)	-0.98 %	0.68 %	-1.23 %	-1.01 %		-0.02	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月23日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.05	11.88	37.78	1.25	18.41	10.29	1.02	76498.75
1	9.69	12.04	38.53	1.28	19.70	9.99	1.02	78125.95
2	11.60	12.11	34.43	2.08	17.75	10.15	1.02	79142.21
3	8.50	12.92	38.68	1.70	18.42	10.09	1.02	79548.84
4	10.40	11.54	50.58	2.02	17.32	10.26	1.04	81168.54
5	9.64	11.41	53.46	1.44	17.53	10.26	1.05	81064.95
6	11.36	10.90	36.01	1.15	18.32	9.65	1.06	83728.36
7	12.34	11.39	32.24	1.46	17.23	10.14	1.06	80455.97
8	10.07	11.91	46.41	1.69	17.00	10.64	1.06	77831.69
9	9.49	12.18	54.71	1.77	16.85	10.68	1.06	78895.40
10	10.66	12.33	56.31	1.75	16.88	10.66	1.06	78732.89
11	9.27	11.99	45.24	1.45	17.75	10.34	1.06	79761.99
12	8.30	11.82	41.27	1.30	17.27	10.43	1.06	75345.63
13	12.47	11.50	35.95	1.18	19.34	9.71	1.06	79307.17
14	11.64	11.93	48.09	1.31	17.86	10.50	1.06	78423.64
15	12.91	11.80	38.98	1.89	18.70	10.19	1.06	76582.82
16	10.91	11.90	44.33	1.72	17.38	10.39	1.06	81024.88
17	11.98	12.45	50.37	1.30	18.73	10.24	1.07	82804.39
18	11.74	12.67	47.67	1.10	18.32	10.20	1.06	81779.19
19	12.00	12.66	47.65	1.87	17.43	10.08	1.05	81959.63
20	11.59	12.61	34.80	1.45	17.93	10.00	1.03	79325.50
21	10.99	13.00	32.31	1.82	18.74	9.50	1.03	81653.93
22	11.49	13.51	33.21	2.68	17.61	9.85	1.03	79610.26
23	12.94	13.35	53.74	1.85	17.89	10.36	1.05	81741.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.88	12.16	43.03	1.60	17.93	10.19	1.05	79771.41
最 大 值	12.94	13.51	56.31	2.68	19.70	10.68	1.09	83728.36
發生時間	23	22	10	22	1	9		6
最 小 值	8.30	10.90	32.24	1.10	16.85	9.50	1.01	75345.63
發生時間	12	6	7	18	9	21		12
零點偏移(率)	-0.13 %	-0.02 %	-0.04 %	-0.05 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-1.35 %	-0.86 %	-0.08 %	-1.34 %		-0.06	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月23日

[illegible]