

報表日期: 113年03月12日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.64	10.67	53.81	1.63	15.69	11.89	1.05	80108.02
1	8.91	10.74	63.30	1.27	17.56	11.48	1.05	82400.63
2	6.19	4.44	57.28	1.55	16.65	11.45	1.03	80208.71
3	6.55	8.37	56.21	1.95	15.52	11.66	1.03	79142.41
4	8.14	7.64	58.14	1.53	16.09	11.52	1.04	81134.21
5	4.70	7.18	55.67	1.52	15.57	11.78	1.03	79729.36
6	1.18	7.11	60.01	1.06	17.05	11.69	1.02	80229.07
7	6.20	6.68	55.66	1.05	17.89	11.32	1.02	82930.19
8	7.91	7.51	62.53	1.01	17.24	11.77	1.05	78372.28
9	8.83	7.10	65.85	0.87	18.64	11.32	1.02	82386.68
10	8.19	6.84	58.51	1.36	17.01	11.31	1.03	84129.16
11	8.79	11.00	51.14	3.79	13.95	11.71	1.04	80758.48
12	12.71	3.10	55.07	2.83	15.74	11.28	1.01	81602.21
13	8.81	5.17	62.76	1.68	16.19	11.34	1.03	82701.03
14	9.29	4.05	45.42	1.57	16.24	11.47	1.05	82144.81
15	8.71	4.91	39.57	2.57	14.56	11.77	1.03	79654.36
16	7.65	4.33	41.78	2.50	14.96	11.48	1.04	80185.67
17	8.64	4.12	47.33	1.66	15.59	11.40	1.04	81461.36
18	7.97	7.78	48.42	1.89	14.91	11.52	1.01	81282.06
19	9.34	9.27	48.88	2.07	14.75	11.65	1.03	82402.61
20	9.89	8.36	48.20	2.19	14.56	11.73	1.04	81871.81
21	8.34	9.21	47.96	1.83	14.75	11.78	1.01	81356.43
22	9.07	9.05	48.14	2.08	14.74	11.75	1.00	80678.69
23	7.56	8.39	65.44	1.30	15.69	11.99	1.03	79399.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.01	7.21	54.05	1.78	15.90	11.59	1.03	81094.57
最 大 值	12.71	11.00	65.85	3.79	18.64	11.99	1.06	84129.16
發生時間	12	11	9	11	9	23		10
最 小 值	1.18	3.10	39.57	0.87	13.95	11.28	0.98	78372.28
發生時間	6	12	15	9	11	12		8
零點偏移(率)	-0.05 %	-0.01 %	-0.11 %	0.00 %		0.01		0.10 %
全幅偏移(率)	0.00 %	-0.57 %	-0.15 %	-0.11 %		-0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月12日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	4.62	4.01	59.35	1.98	16.46	11.38	1.02	78304.03
1	2.74	4.34	50.42	2.50	16.54	11.12	1.02	80107.29
2	2.24	6.36	63.53	3.52	14.80	11.98	1.03	74644.96
3	3.05	3.45	52.96	2.82	15.38	10.97	1.04	83062.94
4	4.88	4.82	56.51	2.51	15.56	11.23	1.04	80985.94
5	6.65	7.61	53.05	2.64	15.44	11.33	1.06	79903.59
6	8.38	3.71	58.00	2.13	14.75	11.65	1.06	78195.40
7	6.28	5.49	59.44	2.04	16.94	11.17	1.06	79890.53
8	5.92	5.66	51.64	2.50	15.80	11.30	1.03	79473.75
9	7.77	5.49	53.13	2.31	16.62	11.12	1.03	80184.81
10	6.00	5.45	52.30	2.31	15.86	11.45	1.06	78544.65
11	4.62	6.11	43.39	3.01	15.25	11.69	1.02	76632.48
12	9.12	5.24	40.13	3.63	14.68	11.31	1.02	80694.37
13	7.02	0.79	42.71	3.27	14.22	11.46	1.04	79823.32
14	9.83	3.08	37.47	3.75	14.12	11.34	1.04	80597.31
15	8.86	2.64	39.66	2.82	15.91	10.95	1.02	82360.01
16	5.88	2.28	38.59	2.71	14.91	11.15	1.02	81892.34
17	4.20	2.30	43.44	2.48	14.32	11.32	1.03	80654.03
18	5.89	6.91	48.83	2.61	14.81	11.21	1.03	81549.96
19	9.59	4.57	52.18	3.21	13.76	11.41	1.01	80711.04
20	8.62	5.82	52.69	2.82	14.76	11.21	1.03	81010.17
21	10.30	4.27	49.08	2.52	14.83	11.08	1.03	82167.79
22	9.04	3.94	49.50	2.50	14.64	11.35	1.00	80465.19
23	8.70	3.86	55.81	2.06	15.54	11.23	1.01	80915.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.67	4.51	50.16	2.69	15.25	11.31	1.03	80115.49
最 大 值	10.30	7.61	63.53	3.75	16.94	11.98	1.06	83062.94
發生時間	21	5	2	14	7	2		3
最 小 值	2.24	0.79	37.47	1.98	13.76	10.95	0.99	74644.96
發生時間	2	13	14	0	19	15		2
零點偏移(率)	-0.05 %	0.01 %	-0.03 %	0.01 %		-0.01		0.00 %
全幅偏移(率)	2.01 %	0.95 %	0.63 %	0.14 %		-0.23		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月12日

報表日期: 113年03月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.81	5.26	62.59	0.51	16.50	10.29	1.09	76501.96
1	0.05	5.62	58.30	0.51	17.33	10.18	1.08	77149.47
2	0.39	6.17	58.24	1.26	14.70	10.56	1.08	73092.63
3	0.06	8.89	62.25	0.48	16.68	9.97	1.07	76589.73
4	0.01	6.52	58.90	0.63	15.91	10.16	1.07	76068.61
5	0.48	3.92	54.97	0.67	15.66	10.17	1.08	76188.11
6	2.18	5.97	63.09	0.90	15.11	10.49	1.08	73991.62
7	1.00	5.42	46.50	0.47	16.40	10.23	1.12	77470.04
8	3.08	5.17	47.81	0.68	15.72	10.46	1.14	76440.80
9	2.60	5.11	50.58	0.66	15.69	10.49	1.14	76075.13
10	2.39	4.98	49.77	0.42	16.58	10.37	1.15	76992.83
11	2.78	5.22	48.08	0.48	17.37	10.01	1.15	81332.90
12	3.14	6.18	41.75	1.16	14.80	10.42	1.15	77285.37
13	3.56	5.01	51.61	0.95	15.39	10.55	1.15	76530.82
14	4.96	5.15	46.14	1.09	15.49	10.21	1.15	78107.37
15	4.53	6.11	47.67	1.64	14.16	10.71	1.14	74866.37
16	5.75	4.89	50.62	0.98	15.81	10.27	1.14	79664.89
17	2.32	2.57	55.84	1.03	14.59	10.70	1.15	77958.75
18	3.40	8.10	57.47	1.43	14.34	10.73	1.14	77029.87
19	3.58	6.78	50.99	1.30	14.53	10.52	1.14	77427.31
20	4.92	5.94	53.37	1.33	14.32	10.72	1.12	75895.27
21	2.74	5.16	56.16	0.95	15.09	10.53	1.11	78856.16
22	3.61	5.73	55.01	0.96	15.18	10.55	1.11	78615.32
23	1.47	5.23	58.60	0.96	15.02	10.52	1.10	76993.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.49	5.63	53.60	0.89	15.52	10.41	1.12	76963.54
最 大 值	5.75	8.89	63.09	1.64	17.37	10.73	1.15	81332.90
發生時間	16	3	6	15	11	18		11
最 小 值	0.01	2.57	41.75	0.42	14.16	9.97	1.06	73092.63
發生時間	4	17	12	10	15	3		2
零點偏移(率)	-0.02 %	-0.04 %	-0.04 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.44 %	-0.12 %	-0.03 %		0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								