

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年02月04日

報表日期: 114年02月04日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 4.34     | 4.22     | 49.35    | 0.69     | 18.03    | 11.69    | 1.25     | 79524.44  |
| 1                 | 4.49     | 2.98     | 67.81    | 0.65     | 19.79    | 12.60    | 1.30     | 70639.94  |
| 2                 | 3.88     | 2.66     | 49.27    | 0.62     | 18.84    | 10.75    | 1.30     | 87030.98  |
| 3                 | 5.72     | 3.07     | 42.32    | 0.77     | 17.85    | 10.77    | 1.29     | 88096.29  |
| 4                 | 5.95     | 2.49     | 57.62    | 0.75     | 17.55    | 11.31    | 1.29     | 83199.57  |
| 5                 | 1.83     | 1.48     | 62.79    | 0.38     | 17.25    | 11.58    | 1.29     | 88267.97  |
| 6                 | 4.90     | 3.02     | 50.59    | 0.57     | 17.44    | 11.22    | 1.29     | 84461.22  |
| 7                 | 9.27     | 3.58     | 44.54    | 1.49     | 15.62    | 11.17    | 1.29     | 85748.77  |
| 8                 | 11.48    | 3.75     | 49.96    | 1.85     | 14.55    | 11.75    | 1.28     | 78505.83  |
| 9                 | 8.53     | 3.22     | 59.45    | 0.80     | 16.11    | 11.59    | 1.26     | 81281.37  |
| 10                | 8.87     | 2.93     | 56.10    | 0.69     | 16.02    | 11.69    | 1.28     | 81462.72  |
| 11                | 8.03     | 3.50     | 59.90    | 1.23     | 15.88    | 11.62    | 1.29     | 82393.48  |
| 12                | 6.28     | 2.99     | 58.04    | 0.67     | 16.46    | 11.44    | 1.25     | 83539.14  |
| 13                | 7.39     | 2.69     | 55.55    | 0.68     | 16.67    | 11.31    | 1.25     | 84164.92  |
| 14                | 6.04     | 2.85     | 64.25    | 0.95     | 16.36    | 11.59    | 1.27     | 82393.75  |
| 15                | 7.69     | 3.09     | 56.70    | 0.94     | 16.30    | 11.37    | 1.26     | 83676.10  |
| 16                | 7.49     | 2.95     | 53.87    | 0.59     | 16.17    | 11.43    | 1.29     | 83487.30  |
| 17                | 10.19    | 5.38     | 47.01    | 1.05     | 16.15    | 11.52    | 1.30     | 82850.27  |
| 18                | 9.34     | 3.29     | 45.00    | 0.62     | 16.17    | 11.62    | 1.28     | 81754.41  |
| 19                | 7.60     | 2.77     | 49.35    | 0.69     | 16.02    | 11.79    | 1.27     | 80859.02  |
| 20                | 7.57     | 3.04     | 47.40    | 0.49     | 17.52    | 11.13    | 1.26     | 84950.78  |
| 21                | 8.31     | 5.94     | 40.42    | 0.71     | 17.20    | 10.94    | 1.27     | 86588.92  |
| 22                | 9.67     | 4.76     | 38.02    | 1.59     | 14.81    | 11.56    | 1.26     | 83952.71  |
| 23                | 10.00    | 2.71     | 53.25    | 0.79     | 16.40    | 11.40    | 1.26     | 84119.42  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 7.29     | 3.31     | 52.44    | 0.84     | 16.72    | 11.45    | 1.28     | 83039.55  |
| 最 大 值             | 11.48    | 5.94     | 67.81    | 1.85     | 19.79    | 12.60    | 1.34     | 88267.97  |
| 發生時間              | 8        | 21       | 1        | 8        | 1        | 1        |          | 5         |
| 最 小 值             | 1.83     | 1.48     | 38.02    | 0.38     | 14.55    | 10.75    | 1.24     | 70639.94  |
| 發生時間              | 5        | 5        | 22       | 5        | 8        | 2        |          | 1         |
| 零點偏移(率)           | -0.03 %  | -0.06 %  | -0.02 %  | -0.00 %  |          | -0.03    |          | 0.30 %    |
| 全幅偏移(率)           | 0.00 %   | 0.26 %   | 0.40 %   | 0.00 %   |          | 0.03     |          | 0.30 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月04日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 3.66     | 2.58     | 60.01    | 1.42     | 17.39    | 10.70    | 1.09     | 84761.70  |
| 1                 | 4.07     | 1.78     | 63.86    | 1.32     | 18.98    | 10.03    | 1.09     | 89039.36  |
| 2                 | 8.90     | 5.70     | 52.60    | 2.44     | 15.23    | 10.80    | 1.11     | 85114.74  |
| 3                 | 10.96    | 3.76     | 46.79    | 2.52     | 15.63    | 10.79    | 1.11     | 85291.29  |
| 4                 | 14.21    | 1.70     | 46.73    | 2.61     | 15.33    | 11.02    | 1.10     | 86551.60  |
| 5                 | 9.86     | 1.15     | 52.11    | 1.40     | 14.52    | 11.52    | 1.10     | 85390.55  |
| 6                 | 9.77     | 2.24     | 52.85    | 2.24     | 14.02    | 11.75    | 1.08     | 79821.89  |
| 7                 | 11.01    | 1.97     | 44.29    | 2.38     | 13.26    | 11.78    | 1.09     | 84003.81  |
| 8                 | 6.52     | 1.28     | 63.04    | 1.52     | 13.40    | 11.82    | 1.08     | 83809.68  |
| 9                 | 7.73     | 1.20     | 67.63    | 1.18     | 13.61    | 12.11    | 1.07     | 81355.67  |
| 10                | 7.46     | 2.14     | 61.72    | 0.52     | 17.25    | 11.66    | 1.10     | 81894.55  |
| 11                | 7.39     | 6.80     | 52.53    | 1.61     | 18.26    | 9.95     | 1.10     | 92758.68  |
| 12                | 3.29     | 1.17     | 59.92    | 1.92     | 13.61    | 11.41    | 1.10     | 83532.74  |
| 13                | 3.99     | 1.73     | 42.04    | 1.90     | 14.40    | 11.29    | 1.09     | 83919.98  |
| 14                | 4.83     | 2.62     | 63.07    | 1.82     | 13.91    | 11.17    | 1.09     | 85713.09  |
| 15                | 6.16     | 1.31     | 62.72    | 1.93     | 14.13    | 11.28    | 1.10     | 83719.87  |
| 16                | 9.34     | 2.36     | 42.52    | 2.30     | 13.21    | 11.37    | 1.10     | 80587.86  |
| 17                | 16.29    | 2.29     | 46.01    | 2.11     | 15.65    | 10.95    | 1.10     | 85445.79  |
| 18                | 10.65    | 4.07     | 40.66    | 2.60     | 15.55    | 10.76    | 1.09     | 87173.96  |
| 19                | 10.54    | 2.66     | 47.47    | 1.61     | 16.78    | 10.59    | 1.08     | 87673.00  |
| 20                | 12.66    | 2.18     | 40.98    | 2.15     | 15.82    | 10.72    | 1.07     | 87418.76  |
| 21                | 13.24    | 2.26     | 44.93    | 2.37     | 15.41    | 10.79    | 1.06     | 87137.98  |
| 22                | 15.21    | 2.36     | 41.54    | 3.17     | 13.24    | 11.37    | 1.06     | 83457.45  |
| 23                | 7.08     | 2.31     | 46.28    | 1.89     | 15.22    | 11.32    | 1.06     | 82726.00  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.95     | 2.48     | 51.76    | 1.96     | 15.16    | 11.12    | 1.09     | 84929.17  |
| 最 大 值             | 16.29    | 6.80     | 67.63    | 3.17     | 18.98    | 12.11    | 1.12     | 92758.68  |
| 發生時間              | 17       | 11       | 9        | 22       | 1        | 9        |          | 11        |
| 最 小 值             | 3.29     | 1.15     | 40.66    | 0.52     | 13.21    | 9.95     | 1.06     | 79821.89  |
| 發生時間              | 12       | 5        | 18       | 10       | 16       | 11       |          | 6         |
| 零點偏移(率)           | -0.46 %  | -0.02 %  | -0.10 %  | 0.00 %   |          | -0.03    |          | 0.00 %    |
| 全幅偏移(率)           | 0.14 %   | -0.01 %  | 0.97 %   | 0.27 %   |          | 0.06     |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月04日

| 項目<br>單位<br>小時\限標 | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 9.20     | 3.67     | 57.02    | 0.42     | 18.31    | 10.35    | 1.49     | 82871.52  |
| 1                 | 7.32     | 4.47     | 54.86    | 0.46     | 17.91    | 10.54    | 1.48     | 82002.23  |
| 2                 | 5.55     | 3.78     | 59.96    | 0.65     | 16.91    | 10.72    | 1.49     | 82005.38  |
| 3                 | 6.37     | 3.17     | 57.34    | 0.73     | 15.96    | 11.39    | 1.48     | 75836.39  |
| 4                 | 7.11     | 4.75     | 50.26    | 0.72     | 17.53    | 10.30    | 1.48     | 83825.15  |
| 5                 | 8.42     | 3.79     | 46.67    | 0.61     | 16.18    | 10.64    | 1.48     | 82608.06  |
| 6                 | 7.19     | 3.70     | 51.75    | 0.63     | 16.20    | 10.83    | 1.48     | 80933.62  |
| 7                 | 6.76     | 1.58     | 48.16    | 0.28     | 16.08    | 10.93    | 1.52     | 78424.65  |
| 8                 | 11.96    | 3.35     | 49.05    | 0.41     | 16.37    | 10.70    | 1.52     | 82291.41  |
| 9                 | 9.18     | 2.14     | 49.46    | 0.29     | 16.65    | 10.64    | 1.52     | 82451.84  |
| 10                | 8.03     | 1.65     | 47.93    | 0.44     | 15.77    | 10.94    | 1.52     | 81140.65  |
| 11                | 7.05     | 1.50     | 50.59    | 0.71     | 14.60    | 11.22    | 1.52     | 79307.50  |
| 12                | 2.30     | 2.84     | 53.47    | 0.36     | 15.23    | 11.22    | 1.52     | 79473.97  |
| 13                | 8.93     | 3.41     | 48.01    | 0.48     | 15.52    | 11.02    | 1.51     | 80582.16  |
| 14                | 6.50     | 9.54     | 45.42    | 1.14     | 14.20    | 11.18    | 1.51     | 78665.26  |
| 15                | 9.60     | 5.21     | 45.56    | 0.61     | 15.27    | 10.86    | 1.52     | 76490.30  |
| 16                | 7.13     | 3.30     | 63.27    | 0.55     | 14.77    | 11.29    | 1.51     | 79613.72  |
| 17                | 11.15    | 3.46     | 59.21    | 0.26     | 17.36    | 10.33    | 1.52     | 84592.16  |
| 18                | 6.16     | 5.03     | 63.98    | 0.43     | 17.94    | 10.00    | 1.52     | 85940.03  |
| 19                | 6.92     | 3.39     | 58.62    | 0.63     | 17.17    | 10.25    | 1.52     | 84935.46  |
| 20                | 9.74     | 2.74     | 61.73    | 0.90     | 15.62    | 10.64    | 1.53     | 81894.94  |
| 21                | 8.20     | 1.27     | 63.00    | 1.08     | 15.55    | 10.66    | 1.51     | 82103.39  |
| 22                | 8.58     | 1.66     | 63.87    | 0.84     | 14.88    | 11.00    | 1.51     | 77413.75  |
| 23                | 6.86     | 1.68     | 59.03    | 0.46     | 15.89    | 11.02    | 1.52     | 77633.14  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 7.76     | 3.38     | 54.51    | 0.59     | 16.16    | 10.78    | 1.51     | 80959.86  |
| 最 大 值             | 11.96    | 9.54     | 63.98    | 1.14     | 18.31    | 11.39    | 1.60     | 85940.03  |
| 發生時間              | 8        | 14       | 18       | 14       | 0        | 3        |          | 18        |
| 最 小 值             | 2.30     | 1.27     | 45.42    | 0.26     | 14.20    | 10.00    | 1.48     | 75836.39  |
| 發生時間              | 12       | 21       | 14       | 17       | 14       | 18       |          | 3         |
| 零點偏移(率)           | -0.07 %  | -0.01 %  | -0.12 %  | -0.01 %  |          | -0.10    |          | 0.00 %    |
| 全幅偏移(率)           | -0.03 %  | 0.12 %   | 0.65 %   | 0.22 %   |          | -0.03    |          | 0.00 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |