

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月17日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.15	4.09	43.56	0.51	18.03	11.26	0.98	83534.74
1	9.78	5.51	39.08	1.23	17.49	10.82	0.97	87177.95
2	9.14	6.34	49.77	1.90	16.10	12.21	0.97	76955.36
3	8.96	8.61	44.29	1.45	16.09	11.66	0.97	82064.08
4	8.20	8.43	49.95	0.96	17.19	11.97	0.97	78188.65
5	6.51	9.28	40.14	1.01	16.79	11.80	0.98	82309.21
6	8.73	9.31	45.39	0.96	17.25	11.56	0.98	81633.57
7	10.45	10.42	39.87	2.01	15.17	11.62	1.01	82933.02
8	9.57	9.47	39.72	1.44	16.11	11.96	1.02	79088.83
9	9.01	7.02	47.42	0.85	16.61	11.56	1.03	82025.87
10	8.30	3.01	47.53	1.66	15.69	11.86	1.03	80173.73
11	5.57	2.87	43.49	1.31	15.93	12.29	1.04	76430.87
12	6.26	2.36	54.80	0.63	17.89	11.06	1.04	85454.89
13	7.38	2.92	42.88	0.89	17.35	11.71	1.04	80048.78
14	7.13	3.37	55.34	0.58	17.35	12.37	1.04	74897.57
15	8.86	2.67	27.08	0.65	18.88	10.79	1.01	86013.73
16	8.80	2.82	41.70	1.42	15.83	11.45	1.00	83145.08
17	6.86	2.29	48.17	2.69	14.07	12.38	1.02	76784.08
18	9.45	4.42	46.47	0.81	17.05	11.85	1.02	79429.92
19	8.55	3.34	44.72	0.72	16.96	11.55	1.01	81975.25
20	7.33	6.49	40.41	1.51	15.74	11.87	0.99	80083.11
21	3.83	8.18	42.03	0.69	17.52	11.37	1.00	82955.30
22	10.00	5.37	37.56	1.57	16.46	11.59	1.00	81830.21
23	7.49	9.27	46.63	1.40	15.74	12.15	1.03	77691.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.89	5.74	44.08	1.20	16.64	11.70	1.01	80951.06
最 大 值	10.45	10.42	55.34	2.69	18.88	12.38	1.06	87177.95
發生時間	7	7	14	17	15	17		1
最 小 值	3.15	2.29	27.08	0.51	14.07	10.79	0.97	74897.57
發生時間	0	17	15	0	17	15		14
零點偏移(率)	-0.02 %	0.01 %	-0.05 %	-0.03 %		-0.04		0.10 %
全幅偏移(率)	0.00 %	-0.03 %	-0.05 %	-0.04 %		-0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月17日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	4.46	3.85	45.12	1.79	17.01	10.95	1.04	81514.27
1	5.91	3.24	45.16	2.64	15.25	11.39	1.04	79506.47
2	8.46	2.92	52.83	2.18	15.81	11.15	1.04	80393.36
3	8.25	6.04	46.72	2.71	15.09	11.34	1.04	80413.57
4	7.59	5.43	49.52	2.24	15.94	11.18	1.04	80421.38
5	3.36	5.98	56.30	1.82	15.41	11.70	1.04	77100.71
6	2.36	6.85	60.54	4.30	12.53	12.24	1.02	78869.73
7	2.11	1.36	53.59	2.90	13.81	12.01	1.03	75214.30
8	1.23	1.67	49.83	2.36	14.08	11.86	1.04	76242.73
9	2.37	1.75	46.90	2.51	15.17	11.42	1.06	79477.19
10	1.69	1.84	48.44	2.69	13.43	12.08	1.04	75464.59
11	2.63	6.20	63.09	2.24	14.52	12.29	1.08	71696.66
12	3.65	1.58	39.53	1.85	16.93	10.88	1.06	81527.85
13	3.73	2.28	67.36	1.58	16.44	11.89	1.06	73907.05
14	3.48	2.24	40.02	1.46	17.07	11.24	1.06	78386.86
15	4.56	1.99	41.49	2.43	16.16	10.91	1.05	81758.09
16	6.40	2.48	48.10	3.04	13.57	11.72	1.04	77540.37
17	7.10	2.27	60.00	2.76	14.63	11.85	1.05	76296.75
18	5.29	2.77	47.29	2.25	15.70	11.13	1.04	81291.88
19	5.05	4.16	47.81	2.62	15.46	11.16	1.04	80775.88
20	5.50	5.85	52.14	1.82	16.18	11.08	1.04	80461.84
21	7.85	6.19	45.13	2.23	16.61	10.92	1.02	81311.17
22	7.96	2.75	51.15	2.23	15.91	11.27	1.03	79008.70
23	7.08	3.99	48.85	1.89	16.06	11.22	1.05	79909.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.92	3.57	50.29	2.36	15.37	11.45	1.04	78687.10
最 大 值	8.46	6.85	67.36	4.30	17.07	12.29	1.12	81758.09
發生時間	2	6	13	6	14	11		15
最 小 值	1.23	1.36	39.53	1.46	12.53	10.88	1.02	71696.66
發生時間	8	7	12	14	6	12		11
零點偏移(率)	-0.35 %	0.00 %	-0.04 %	0.00 %		0.04		0.10 %
全幅偏移(率)	0.02 %	1.48 %	0.49 %	0.19 %		-0.24		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月17日

報表日期: 113年02月17日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.51	4.37	61.15	0.52	16.23	10.96	1.04	76341.34
1	3.92	5.10	55.92	0.76	17.14	10.77	1.04	79511.83
2	6.02	13.13	57.71	1.18	15.68	10.98	1.04	79164.15
3	9.00	3.12	58.68	1.03	16.07	10.89	1.04	79595.37
4	5.08	3.50	56.43	0.63	17.28	10.59	1.04	80885.17
5	2.71	8.43	55.54	0.55	16.90	10.61	1.04	80487.47
6	2.96	9.41	51.89	0.70	16.44	10.53	1.04	80480.66
7	3.19	5.49	61.56	0.78	16.29	11.40	1.01	84217.78
8	9.21	5.52	38.72	1.13	16.62	10.46	1.03	82851.49
9	9.02	4.26	40.86	0.92	15.96	10.76	1.04	80734.72
10	7.72	5.65	38.85	1.08	15.31	10.99	1.04	78665.52
11	7.29	4.66	50.49	0.82	16.13	10.96	1.04	78340.13
12	9.17	3.67	48.62	1.09	16.47	10.58	1.04	81408.57
13	5.87	3.73	55.61	0.54	16.86	11.06	1.04	77101.43
14	2.36	4.32	53.06	0.53	17.46	10.62	1.05	79981.13
15	4.54	6.56	40.92	0.72	15.91	11.01	1.04	78543.30
16	6.41	5.75	44.54	2.05	13.64	11.41	1.04	76491.28
17	3.85	3.10	47.62	2.28	13.55	11.36	1.04	73598.10
18	4.02	2.11	51.07	0.84	16.76	10.83	1.04	78396.12
19	2.13	3.47	49.58	0.93	15.28	11.27	1.04	75880.59
20	2.92	3.51	54.29	0.87	15.72	10.78	1.04	79048.54
21	3.93	5.21	62.68	0.89	15.88	11.11	1.04	76701.98
22	2.39	5.67	61.99	0.67	16.36	11.31	1.04	75816.87
23	6.59	6.19	59.90	0.89	16.01	10.84	1.04	80093.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.12	5.25	52.40	0.93	16.08	10.92	1.04	78930.70
最 大 值	9.21	13.13	62.68	2.28	17.46	11.41	1.06	84217.78
發生時間	8	2	21	17	14	16		7
最 小 值	2.13	2.11	38.72	0.52	13.55	10.46	1.00	73598.10
發生時間	19	18	8	0	17	8		17
零點偏移(率)	0.00 %	0.01 %	-0.05 %	-0.05 %		0.07		0.00 %
全幅偏移(率)	0.02 %	0.22 %	-0.01 %	0.05 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								