

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.75	13.97	57.62	1.48	17.09	11.92	1.05	77763.29
1	4.27	9.77	55.58	1.18	18.60	11.66	1.05	79571.48
2	3.26	9.91	48.43	1.17	17.59	11.82	1.05	78872.82
3	6.13	10.35	55.49	1.39	17.42	11.65	1.07	80678.41
4	9.15	14.63	44.62	2.37	15.87	12.01	1.06	77421.79
5	6.48	12.53	61.51	0.94	18.53	11.37	1.03	80328.32
6	7.88	11.09	48.35	1.53	17.46	11.76	1.04	78491.17
7	6.53	10.27	65.83	0.97	18.30	12.14	1.05	75749.40
8	7.71	9.61	52.14	1.09	18.68	11.39	1.05	80369.49
9	9.06	10.74	45.97	1.38	18.55	11.22	1.05	79872.89
10	5.09	12.08	66.69	0.92	18.61	12.24	1.06	70086.68
11	10.17	13.18	43.65	2.81	19.67	10.98	1.05	75514.20
12	7.96	10.87	46.23	1.88	18.56	11.06	1.05	78858.75
13	10.04	15.93	39.86	2.31	16.53	11.40	1.04	75007.88
14	6.35	11.96	64.12	1.59	17.34	12.26	1.04	68230.16
15	8.91	14.26	47.43	1.19	17.89	11.27	1.02	72270.18
16	9.02	19.03	49.00	2.42	15.10	11.79	1.02	71250.96
17	9.32	23.58	42.89	6.62	15.84	11.83	1.01	74154.58
18	8.66	8.31	39.09	3.33	15.37	11.85	1.02	75809.22
19	8.85	5.36	53.17	1.27	18.41	11.44	1.02	80988.83
20	8.52	8.93	60.68	0.63	19.83	11.33	1.02	80101.02
21	8.62	9.90	53.50	1.17	19.26	11.04	1.02	82887.52
22	11.81	15.92	54.60	1.51	19.62	10.87	1.02	84042.84
23	8.42	12.57	53.36	1.09	18.57	11.27	1.02	81866.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.87	12.28	52.08	1.76	17.86	11.57	1.04	77507.87
最大值	11.81	23.58	66.69	6.62	19.83	12.26	1.08	84042.84
發生時間	22	17	10	17	20	14		22
最小值	3.26	5.36	39.09	0.63	15.10	10.87	0.99	68230.16
發生時間	2	19	18	20	16	22		14
零點偏移(率)	-0.21 %	-0.01 %	-0.01 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.11 %	0.01 %	0.10 %		-0.12		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.72	7.17	51.98	1.29	19.53	9.79	1.23	84695.79
1	5.43	11.98	53.06	1.93	19.27	9.85	1.23	84236.74
2	5.95	9.73	56.69	2.17	17.83	9.96	1.23	84992.81
3	7.62	5.65	52.44	1.79	18.57	9.94	1.23	85228.93
4	8.48	8.51	53.57	2.59	17.51	10.11	1.25	85006.31
5	8.01	9.33	57.33	2.79	16.76	10.36	1.25	81925.82
6	0.54	10.06	56.61	3.29	16.03	10.39	1.19	86824.34
7	2.17	7.31	52.17	2.50	16.84	10.20	1.18	81429.53
8	4.79	5.81	50.92	1.42	19.03	9.68	1.19	82386.99
9	11.81	7.17	53.38	1.99	19.23	9.52	1.18	81256.05
10	15.95	10.33	52.30	8.04	17.30	10.43	1.18	83517.99
11	9.35	5.73	55.38	2.89	17.90	10.50	1.17	84744.53
12	10.70	6.88	58.37	3.21	17.48	9.61	1.18	81431.07
13	8.82	5.96	59.77	2.33	17.21	9.92	1.18	80333.57
14	9.69	11.03	53.33	3.49	15.78	10.21	1.18	78563.79
15	10.23	9.54	50.40	2.06	16.30	10.03	1.18	78833.08
16	8.57	6.61	44.34	2.27	15.67	10.10	1.18	78835.07
17	9.50	6.22	43.59	1.88	16.87	9.81	1.18	80863.78
18	6.63	6.08	47.95	1.56	17.66	10.05	1.18	77570.75
19	8.72	5.00	52.58	1.21	18.83	9.66	1.19	80851.49
20	10.76	5.25	48.97	1.87	17.81	9.72	1.19	82727.33
21	8.81	8.49	58.51	1.57	18.11	10.30	1.19	79438.28
22	7.05	8.97	58.30	1.26	18.25	10.71	1.20	76508.21
23	8.34	10.10	46.57	1.58	18.20	9.78	1.20	83485.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.03	7.87	52.85	2.37	17.67	10.03	1.20	81903.65
最大值	15.95	11.98	59.77	8.04	19.53	10.71	1.31	86824.34
發生時間	10	1	13	10	0	22		6
最小值	0.54	5.00	43.59	1.21	15.67	9.52	1.15	76508.21
發生時間	6	19	17	19	16	9		22
零點偏移(率)	-0.02 %	-0.01 %	-0.05 %	-0.07 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.92 %	-0.69 %	0.23 %		-0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.17	9.48	61.96	0.71	17.59	11.06	0.98	80875.24
1	0.65	10.50	58.71	0.71	18.22	10.78	0.97	83535.53
2	0.98	11.54	58.21	0.78	17.00	10.96	0.97	82431.24
3	4.22	11.87	60.17	1.36	16.01	11.11	0.99	82889.63
4	5.38	9.87	60.22	1.47	15.84	11.30	0.99	80993.88
5	2.66	9.38	57.10	1.43	15.88	10.94	0.99	80568.17
6	2.45	8.30	59.00	1.17	16.31	10.91	0.99	81574.78
7	0.62	8.10	50.12	0.71	16.48	10.53	0.99	74086.58
8	2.03	10.61	56.07	1.01	16.40	10.66	1.04	77003.86
9	5.55	7.30	59.98	1.17	17.06	10.56	1.05	78886.86
10	9.78	9.63	50.97	1.70	16.73	10.72	1.03	79600.54
11	8.49	9.24	57.77	1.29	18.10	10.58	1.05	79176.92
12	12.04	11.28	55.51	2.00	15.45	10.74	1.04	77429.53
13	13.39	9.90	51.76	2.23	14.78	10.97	1.03	76638.71
14	9.54	10.94	44.78	1.68	14.94	10.64	1.02	73839.51
15	7.00	10.44	44.82	1.18	16.16	10.47	0.99	75233.07
16	8.58	10.73	53.32	1.22	16.52	10.49	0.99	77909.00
17	14.28	17.93	49.16	4.72	14.24	10.74	0.98	74089.37
18	2.64	7.53	45.03	1.76	14.89	10.54	0.98	74210.88
19	3.41	10.78	54.81	0.66	16.86	10.61	0.99	77640.31
20	4.10	15.27	53.94	0.62	17.86	10.55	0.99	79782.31
21	3.64	11.29	52.93	0.60	17.20	10.56	0.99	80489.96
22	3.54	9.77	59.15	0.72	16.94	10.75	0.99	79661.26
23	2.38	8.68	41.61	3.32	16.27	10.28	0.99	77554.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.31	10.43	54.05	1.43	16.41	10.73	1.00	78587.58
最大值	14.28	17.93	61.96	4.72	18.22	11.30	1.06	83535.53
發生時間	17	17	0	17	1	4		1
最小值	0.17	7.30	41.61	0.60	14.24	10.28	0.97	73839.51
發生時間	0	9	23	21	17	23		14
零點偏移(率)	-0.06 %	-0.04 %	-0.13 %	-0.06 %		-0.03		0.00 %
全幅偏移(率)	1.41 %	0.76 %	-0.84 %	0.29 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								