

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.94	13.51	47.76	1.82	19.72	10.95	1.18	73080.99
1	9.65	12.92	57.52	1.91	20.46	10.80	1.18	74244.10
2	5.97	14.48	51.81	2.25	19.62	10.92	1.18	73842.73
3	5.75	13.43	56.69	2.55	18.18	11.39	1.19	71378.12
4	6.35	13.35	60.39	3.07	16.87	11.69	1.20	70596.10
5	11.85	13.21	57.67	2.25	16.93	11.67	1.23	76011.30
6	11.18	12.91	60.12	3.28	19.03	10.88	1.25	74778.26
7	13.25	13.67	54.15	3.50	18.02	11.12	1.25	73917.26
8	16.58	13.76	55.97	3.71	17.44	11.51	1.24	70812.29
9	4.56	13.18	58.70	3.29	19.50	11.17	1.22	71488.33
10	3.71	13.36	46.39	1.92	19.24	10.92	1.21	73479.26
11	1.59	13.11	52.46	0.92	19.17	11.17	1.23	71743.68
12	6.42	13.34	53.12	1.06	17.92	11.52	1.21	70028.67
13	10.81	14.54	57.59	1.30	18.07	11.32	1.20	71550.59
14	7.66	13.07	56.26	1.10	18.03	11.28	1.18	71696.83
15	10.05	13.22	56.27	1.50	17.44	11.51	1.19	71396.95
16	10.08	13.05	54.46	3.47	17.41	11.38	1.20	71699.94
17	9.14	13.32	51.99	2.94	19.62	10.60	1.21	75779.82
18	9.78	13.14	57.25	3.35	18.22	11.32	1.20	72032.67
19	6.56	14.31	50.21	0.90	18.55	11.03	1.19	73340.64
20	3.08	12.42	49.74	1.38	19.40	10.88	1.18	72888.16
21	7.04	12.35	30.01	2.01	18.21	10.91	1.19	73176.25
22	7.79	12.76	50.85	2.36	20.25	10.39	1.21	75181.79
23	4.37	12.47	48.45	2.03	16.28	11.50	1.21	66966.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.97	13.29	53.16	2.24	18.48	11.16	1.20	72546.28
最大值	16.58	14.54	60.39	3.71	20.46	11.69	1.25	76011.30
發生時間	8	13	4	8	1	4		5
最小值	1.59	12.35	30.01	0.90	16.28	10.39	1.18	66966.08
發生時間	11	21	21	19	23	22		23
零點偏移(率)	-0.01 %	-0.01 %	-0.05 %	-0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	1.59 %	2.68 %	-0.51 %	0.64 %		-0.11	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.40	13.87	56.55	0.86	18.63	10.89	1.04	80665.28
1	8.86	13.88	56.97	1.30	17.74	11.71	1.04	74578.13
2	6.78	14.17	59.72	1.36	16.88	12.07	1.03	73734.85
3	10.48	13.10	53.96	2.00	16.84	11.50	1.02	78729.78
4	10.01	12.81	56.31	2.31	16.89	11.30	1.02	80332.77
5	8.17	13.01	56.38	2.00	16.50	11.50	1.02	78650.43
6	8.68	12.61	56.19	3.38	16.90	11.23	1.02	80178.80
7	10.02	13.41	63.92	2.56	16.73	11.29	1.02	80442.76
8	10.28	12.74	58.19	1.69	17.87	11.14	1.01	79731.94
9	9.15	12.68	58.64	1.61	17.93	11.10	1.02	80512.79
10	6.93	12.74	57.12	1.55	18.20	11.01	1.02	80783.77
11	5.68	13.39	62.59	2.63	15.80	11.78	1.03	76344.37
12	11.09	12.70	58.10	1.15	17.47	11.14	1.02	80081.28
13	6.93	12.62	59.56	1.19	17.72	11.10	1.02	80492.81
14	5.99	12.87	55.57	1.41	17.34	11.26	1.02	79819.98
15	5.33	12.96	51.91	1.82	16.08	11.44	1.02	79004.04
16	8.08	13.41	49.13	2.28	16.31	11.38	1.02	77857.12
17	4.91	13.11	51.31	0.59	17.74	11.50	1.02	77331.72
18	10.05	12.27	55.66	1.04	18.24	10.89	1.02	80832.05
19	6.92	14.02	49.57	2.84	16.49	11.49	1.02	77059.40
20	3.94	12.99	49.71	1.28	17.73	11.34	1.01	78180.83
21	7.78	12.48	54.00	1.78	17.54	11.17	1.01	79733.47
22	9.22	12.32	54.88	1.60	17.12	11.10	1.02	80985.16
23	3.19	12.58	67.40	1.14	17.88	11.14	1.02	80110.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.74	13.03	56.39	1.72	17.27	11.31	1.02	79007.24
最大值	11.09	14.17	67.40	3.38	18.63	12.07	1.05	80985.16
發生時間	12	2	23	6	0	2		22
最小值	3.19	12.27	49.13	0.59	15.80	10.89	0.99	73734.85
發生時間	23	18	16	17	11	0		2
零點偏移(率)	-0.06 %	-0.00 %	-0.07 %	-0.01 %		-0.13	-0.01	-0.20 %
全幅偏移(率)	-0.16 %	2.16 %	0.00 %	0.95 %		-0.24	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.92	12.28	44.71	3.26	19.99	8.94	1.31	71823.77
1	9.77	12.50	43.43	3.02	22.17	8.73	1.31	72136.89
2	9.27	14.27	35.82	3.59	19.65	8.37	1.28	71262.85
3	10.67	11.23	49.82	2.63	19.37	9.11	1.29	72349.63
4	8.38	11.21	41.26	2.25	20.09	9.08	1.31	70833.38
5	9.23	11.69	49.90	3.35	20.32	8.87	1.32	72420.54
6	8.50	11.12	53.09	3.43	20.15	8.42	1.34	70634.56
7	12.24	10.97	41.38	3.57	19.31	8.53	1.33	71153.48
8	9.56	11.75	44.21	3.78	17.71	9.43	1.33	72905.37
9	9.21	10.80	52.24	3.59	18.66	9.41	1.36	73054.99
10	9.07	10.98	50.52	3.57	19.84	9.35	1.35	74370.07
11	8.81	11.02	55.15	3.38	18.73	9.59	1.31	75212.08
12	9.03	11.85	54.11	3.26	17.43	9.79	1.35	73346.17
13	5.09	12.64	56.54	3.21	19.04	9.62	1.33	75009.23
14	4.36	12.06	57.53	3.23	18.99	9.75	1.31	74670.80
15	5.59	12.38	57.79	3.26	17.15	10.17	1.35	73542.32
16	4.84	12.27	41.53	4.17	17.76	9.19	1.33	69879.19
17	7.66	13.07	35.07	2.02	20.92	7.58	1.31	71034.39
18	8.95	11.65	37.18	1.21	21.49	7.88	1.29	69149.17
19	9.30	15.93	32.42	5.09	22.29	5.90	1.29	79065.39
20	8.83	11.04	47.66	0.20	18.88	8.44	1.33	72445.05
21	6.03	12.16	38.40	3.86	21.08	7.79	1.34	69284.91
22	8.16	10.50	40.84	0.69	19.99	8.04	1.32	72908.94
23	5.47	11.56	44.94	3.36	18.98	8.34	1.29	70929.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.12	11.96	46.06	3.04	19.58	8.76	1.32	72475.96
最大值	12.24	15.93	57.79	5.09	22.29	10.17	1.36	79065.39
發生時間	7	19	15	19	19	15		19
最小值	4.36	10.50	32.42	0.20	17.15	5.90	1.27	69149.17
發生時間	14	22	19	20	15	19		18
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	-0.00 %		-0.11	-0.01	0.10 %
全幅偏移(率)	-1.68 %	0.34 %	-0.27 %	0.20 %		0.21	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								