

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.34	13.19	51.09	1.47	16.89	11.71	1.30	80114.51
1	2.66	13.23	58.50	1.14	17.65	11.67	1.31	79826.45
2	2.46	12.83	49.03	2.04	16.78	11.49	1.30	81969.91
3	2.69	12.96	57.05	1.31	16.51	11.59	1.29	81903.28
4	2.70	12.97	44.83	2.56	14.67	11.84	1.27	80981.35
5	2.86	13.94	50.61	3.97	14.19	12.07	1.33	79993.65
6	2.95	13.72	58.74	2.82	14.48	12.28	1.34	77019.09
7	5.60	14.08	64.95	1.89	15.66	12.36	1.34	75864.19
8	7.74	12.95	51.75	1.71	16.17	11.56	1.34	81915.47
9	7.71	13.20	42.41	2.10	16.38	11.50	1.34	82604.70
10	7.87	13.43	52.16	2.03	16.16	11.72	1.32	80891.56
11	8.24	13.78	56.57	2.69	14.50	12.04	1.30	79414.63
12	8.28	13.94	61.82	2.32	15.13	12.23	1.29	76019.24
13	8.02	13.40	51.07	2.57	15.24	11.87	1.29	79819.08
14	8.56	14.38	56.66	1.74	15.80	12.45	1.29	75099.50
15	5.67	13.37	57.58	2.18	16.02	11.76	1.29	80233.54
16	3.40	13.18	61.57	2.06	16.40	11.58	1.29	81856.00
17	0.27	13.23	57.27	1.68	16.18	11.57	1.29	82122.53
18	0.13	13.30	52.38	1.30	17.07	11.29	1.29	83503.95
19	2.13	13.15	50.06	1.27	17.22	11.08	1.29	85041.36
20	10.08	13.49	50.56	1.72	17.06	11.27	1.31	83432.74
21	9.87	12.94	58.43	1.60	17.46	11.25	1.33	83357.14
22	10.48	13.45	57.57	1.91	16.55	11.72	1.34	80263.64
23	7.06	13.57	59.49	1.11	17.49	11.69	1.34	79640.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.53	13.40	54.67	1.97	16.15	11.73	1.31	80536.99
最大值	10.48	14.38	64.95	3.97	17.65	12.45	1.34	85041.36
發生時間	22	14	7	5	1	14		19
最小值	0.13	12.83	42.41	1.11	14.19	11.08	1.26	75099.50
發生時間	18	2	9	23	5	19		14
零點偏移(率)	-0.11 %	-0.01 %	-0.01 %	-0.01 %		-0.06	-0.01	0.30 %
全幅偏移(率)	-0.17 %	1.17 %	-1.05 %	-0.60 %		0.08	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.27	13.17	42.24	0.96	17.84	10.63	1.10	77153.75
1	2.99	13.14	51.84	1.03	18.46	10.53	1.11	76792.12
2	2.74	13.32	55.05	1.42	17.83	10.78	1.11	77569.56
3	2.35	12.88	51.92	0.63	18.64	10.35	1.10	77413.79
4	2.39	13.51	43.19	1.95	16.74	10.53	1.09	76503.01
5	2.86	12.73	42.05	2.01	17.19	10.17	1.10	75774.28
6	5.89	13.51	38.84	1.67	18.71	9.67	1.07	79572.02
7	3.29	11.56	43.60	1.43	17.59	10.08	1.08	76131.39
8	2.70	11.84	50.79	0.95	18.45	10.31	1.09	79409.13
9	2.45	11.81	51.97	1.19	17.90	10.34	1.09	79902.97
10	2.23	11.78	40.56	1.72	17.25	10.28	1.07	76600.14
11	1.86	13.89	40.90	1.93	16.34	10.65	1.06	77267.23
12	1.98	13.83	36.01	2.03	16.03	10.68	1.06	77966.86
13	2.26	11.91	52.77	1.64	17.02	10.81	1.08	76880.48
14	4.77	11.75	46.97	1.06	19.00	10.21	1.09	78966.22
15	7.22	12.07	47.61	1.81	18.06	10.53	1.08	78884.96
16	6.99	12.40	42.69	2.22	17.00	10.63	1.07	78060.07
17	6.21	14.59	41.51	2.46	16.97	10.15	1.06	77602.11
18	7.61	11.88	37.97	2.00	16.48	10.37	1.06	78195.65
19	6.44	11.60	36.09	1.23	18.30	9.77	1.06	77756.35
20	8.98	12.56	36.26	1.84	18.51	9.63	1.06	79610.46
21	13.22	12.05	43.32	2.60	15.96	10.67	1.08	78329.54
22	7.95	11.62	44.88	1.92	17.42	10.23	1.10	79786.74
23	10.09	12.51	55.87	1.85	16.89	10.64	1.10	79949.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.91	12.58	44.79	1.65	17.52	10.36	1.08	78003.26
最大值	13.22	14.59	55.87	2.60	19.00	10.81	1.13	79949.33
發生時間	21	17	23	21	14	13		23
最小值	1.86	11.56	36.01	0.63	15.96	9.63	1.06	75774.28
發生時間	11	7	12	3	21	20		5
零點偏移(率)	-0.10 %	-0.02 %	-0.04 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-1.30 %	-1.81 %	-0.81 %	-1.48 %		-0.06	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.18	12.11	52.54	2.51	16.06	10.86	1.31	75006.70
1	12.00	12.54	59.73	2.31	15.47	11.31	1.32	71720.95
2	11.38	12.02	49.93	2.24	17.47	10.55	1.32	70027.08
3	11.80	11.72	49.16	2.56	16.37	10.51	1.31	73148.00
4	11.64	12.45	48.89	1.88	15.99	10.92	1.32	72323.59
5	12.24	12.28	48.90	2.17	16.00	10.81	1.32	75352.45
6	11.67	12.50	41.23	2.66	15.09	10.68	1.32	72641.15
7	6.58	12.00	61.27	2.22	15.77	10.91	1.37	68822.51
8	10.31	13.31	61.94	2.76	14.59	11.95	1.39	67588.58
9	12.02	12.47	52.78	3.10	14.78	11.07	1.40	74005.43
10	11.73	11.95	56.91	3.19	14.77	10.95	1.39	70953.78
11	11.46	11.63	61.11	2.45	16.79	10.46	1.39	73225.84
12	12.40	11.78	59.93	2.64	17.19	10.52	1.39	72706.97
13	11.62	12.10	46.29	2.69	15.97	10.54	1.39	72656.53
14	11.95	11.96	62.14	2.61	16.43	10.79	1.37	71098.58
15	12.12	11.93	58.46	2.77	16.32	10.74	1.38	71925.42
16	12.06	12.43	59.43	3.10	14.93	10.74	1.39	71527.28
17	12.44	12.25	61.10	3.15	15.27	10.72	1.39	73365.64
18	12.56	12.13	65.99	3.10	14.71	11.09	1.39	72855.06
19	11.51	11.98	54.97	2.41	16.07	10.81	1.38	74240.36
20	12.01	11.80	60.56	2.65	15.76	10.69	1.37	74255.36
21	11.48	12.16	63.04	3.19	14.87	10.94	1.38	72950.36
22	12.26	12.15	49.58	2.28	15.80	11.01	1.40	73089.98
23	12.23	12.48	56.31	2.55	15.35	11.31	1.40	72971.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.65	12.17	55.92	2.63	15.74	10.87	1.37	72435.81
最大值	12.56	13.31	65.99	3.19	17.47	11.95	1.41	75352.45
發生時間	18	8	18	10	2	8		5
最小值	6.58	11.63	41.23	1.88	14.59	10.46	1.31	67588.58
發生時間	7	11	6	4	8	11		8
零點偏移(率)	-0.08 %	-0.03 %	-0.03 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-0.51 %	-1.76 %	0.50 %	-0.68 %		0.07	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								