

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.76	13.49	55.30	2.46	15.76	11.79	1.23	78332.58
1	6.98	13.43	61.42	1.93	18.12	11.48	1.23	78830.99
2	11.94	13.00	48.84	3.48	17.26	11.20	1.24	82041.25
3	9.44	13.29	66.00	2.55	17.69	11.44	1.24	79941.80
4	9.21	12.79	48.77	2.91	18.06	10.97	1.22	83580.96
5	7.51	15.89	65.08	2.68	16.58	11.60	1.20	82232.69
6	8.22	13.15	51.85	2.75	15.94	11.59	1.21	80285.10
7	10.70	13.26	53.80	2.97	15.63	11.46	1.22	81693.97
8	9.52	13.43	54.23	2.08	17.59	11.07	1.24	83347.03
9	8.90	12.81	52.52	2.85	14.95	11.43	1.21	81428.20
10	8.74	13.09	59.68	2.23	16.28	11.52	1.22	80149.88
11	8.99	13.07	53.02	2.69	15.28	11.60	1.21	76696.54
12	9.95	13.58	57.68	2.52	15.49	11.59	1.20	77959.42
13	10.41	13.24	52.28	2.81	14.75	11.66	1.20	78571.82
14	11.65	13.22	51.63	2.90	14.48	11.72	1.20	78020.60
15	6.44	13.93	53.25	2.63	14.47	11.79	1.20	78166.27
16	5.33	13.31	55.16	2.55	14.81	11.78	1.23	79517.60
17	12.05	14.08	55.76	2.73	15.59	11.41	1.21	81988.02
18	12.94	12.34	59.98	2.87	15.64	11.26	1.20	83659.72
19	10.99	12.51	61.46	2.49	15.65	11.38	1.19	81591.46
20	6.47	12.27	53.62	2.37	16.85	10.89	1.19	85401.81
21	7.57	12.53	56.13	2.66	16.72	11.11	1.19	83240.95
22	7.87	13.85	62.15	3.08	15.65	11.57	1.19	80283.27
23	7.74	11.83	58.32	2.41	17.04	11.24	1.19	81990.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.93	13.22	56.16	2.65	16.09	11.44	1.21	80789.67
最 大 值	12.94	15.89	66.00	3.48	18.12	11.79	1.25	85401.81
發生時間	18	5	3	2	1	0		20
最 小 值	4.76	11.83	48.77	1.93	14.47	10.89	1.18	76696.54
發生時間	0	23	4	1	15	20		11
零點偏移(率)	-0.01 %	0.00 %	-0.23 %	-0.08 %		0.02		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月16日

報表日期: 114年09月16日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.02	12.57	47.86	2.72	17.64	9.49	1.37	83191.52
1	7.12	11.33	57.18	2.66	20.15	9.35	1.36	82915.26
2	7.85	11.07	54.31	2.84	19.31	9.08	1.37	82576.57
3	9.11	11.03	56.02	2.90	18.80	9.26	1.40	82632.15
4	10.37	11.14	59.36	2.97	19.51	9.28	1.41	83250.89
5	7.97	11.30	55.59	2.82	19.77	9.36	1.41	85651.22
6	9.43	11.51	61.69	2.86	18.25	9.81	1.42	82854.73
7	6.23	12.92	58.91	2.75	17.82	9.86	1.37	81708.54
8	7.10	13.18	56.21	2.66	17.16	9.87	1.36	82049.41
9	10.36	13.64	58.36	3.02	17.45	9.83	1.35	83256.55
10	9.70	12.66	59.51	2.97	18.08	9.82	1.37	81902.84
11	8.76	13.47	59.75	2.85	18.11	9.84	1.34	81510.04
12	9.98	12.71	55.04	2.94	18.19	9.44	1.32	80965.05
13	7.87	7.91	45.96	3.56	16.86	9.41	1.33	72398.36
14	10.47	6.26	51.91	3.60	15.41	10.07	1.31	74898.12
15	9.43	10.88	54.78	3.07	15.93	10.29	1.32	74464.34
16	5.56	11.73	46.64	2.51	18.12	8.95	1.32	73012.95
17	7.10	12.48	42.87	1.88	18.13	8.46	1.30	74993.02
18	9.18	10.99	47.54	1.72	18.28	8.89	1.35	76222.62
19	8.14	11.46	49.33	2.05	18.17	8.41	1.35	81625.06
20	3.47	11.57	50.72	2.14	18.44	8.50	1.36	80736.27
21	2.99	12.13	46.81	2.38	18.53	8.33	1.35	82271.28
22	4.56	13.29	59.03	2.59	18.58	9.65	1.36	81830.22
23	6.52	11.19	55.46	2.79	18.61	9.84	1.36	81940.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.97	11.60	53.78	2.72	18.14	9.38	1.36	80369.04
最 大 值	12.02	13.64	61.69	3.60	20.15	10.29	1.43	85651.22
發生時間	0	9	6	14	1	15		5
最 小 值	2.99	6.26	42.87	1.72	15.41	8.33	1.27	72398.36
發生時間	21	14	17	18	14	21		13
零點偏移(率)	-0.07 %	-0.04 %	-0.17 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.02 %	-0.07 %	0.02 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								