

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.04	4.80	61.18	0.91	18.51	11.56	1.27	80214.71
1	8.30	4.95	63.39	1.03	20.28	11.12	1.27	81978.93
2	7.51	4.80	63.11	0.99	19.25	11.25	1.28	82370.87
3	9.98	6.12	55.36	2.02	18.85	11.05	1.29	84756.90
4	7.30	5.39	57.96	2.02	16.74	11.87	1.30	79681.84
5	3.22	2.62	54.70	1.36	18.41	11.49	1.29	82459.33
6	6.64	3.91	60.38	0.77	18.78	11.56	1.29	80495.76
7	9.50	5.96	55.75	1.36	17.62	11.62	1.28	80314.84
8	7.95	2.62	62.29	0.93	17.79	11.94	1.25	77921.59
9	8.71	2.96	55.28	1.57	17.09	11.81	1.25	79308.74
10	9.10	4.13	59.17	1.56	17.62	11.65	1.26	80497.32
11	12.34	7.74	53.11	2.30	16.33	11.86	1.28	77020.01
12	8.52	2.17	50.30	2.16	15.93	11.85	1.24	74404.06
13	8.92	2.35	60.56	0.83	17.81	11.85	1.25	75192.98
14	8.59	2.81	52.67	1.25	17.51	11.53	1.25	80041.49
15	7.59	2.91	49.69	1.04	17.85	11.41	1.28	81640.17
16	6.54	2.76	53.24	1.15	17.73	11.26	1.28	83607.46
17	7.31	2.77	57.79	0.98	18.15	11.50	1.29	81123.13
18	4.92	2.79	55.94	0.72	19.14	10.92	1.29	85308.35
19	6.46	4.89	47.13	1.16	18.13	11.14	1.29	83553.39
20	6.20	3.61	51.06	1.25	17.78	11.13	1.29	83632.91
21	9.87	4.26	54.78	2.70	15.31	12.07	1.29	78792.92
22	10.47	4.68	52.99	2.38	15.53	12.11	1.29	78141.00
23	7.31	5.40	45.59	1.89	15.27	12.15	1.29	74963.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.89	4.06	55.56	1.43	17.64	11.57	1.28	80309.24
最 大 值	12.34	7.74	63.39	2.70	20.28	12.15	1.31	85308.35
發生時間	11	11	1	21	1	23		18
最 小 值	3.22	2.17	45.59	0.72	15.27	10.92	1.23	74404.06
發生時間	5	12	23	18	23	18		12
零點偏移(率)	-0.02 %	-0.03 %	-0.01 %	-0.00 %		-0.11		0.30 %
全幅偏移(率)	0.00 %	0.09 %	-0.39 %	-0.04 %		-0.39		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月05日

報表日期: 114年03月05日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	12.40	3.21	61.82	0.50	18.72	10.44	1.54	81751.47
1	11.68	3.93	57.98	0.52	20.23	10.29	1.52	80786.49
2	11.98	5.11	57.06	0.80	18.11	10.64	1.52	80188.96
3	11.92	4.88	60.54	1.30	16.72	11.00	1.53	79622.42
4	11.03	3.36	55.49	0.79	17.80	10.45	1.53	82933.09
5	11.54	2.05	58.36	0.84	16.85	11.16	1.54	77799.59
6	10.62	2.74	57.67	0.97	16.76	11.00	1.54	78774.73
7	9.88	2.97	52.61	0.49	16.33	11.26	1.52	78005.23
8	10.02	4.72	55.70	0.63	16.45	11.23	1.52	76262.54
9	10.09	2.80	55.83	0.65	16.47	11.05	1.52	77210.77
10	9.94	2.93	51.04	1.03	15.99	11.01	1.52	77424.12
11	13.61	1.90	58.35	1.04	16.20	11.09	1.52	76289.22
12	15.03	6.94	60.04	1.22	16.09	11.14	1.52	77306.74
13	12.94	7.74	59.05	1.44	15.29	11.38	1.52	78204.57
14	8.93	1.56	56.06	0.72	15.79	11.40	1.52	76346.28
15	11.90	2.04	55.54	0.83	15.99	11.10	1.52	79179.93
16	10.56	3.07	57.52	0.74	16.23	10.78	1.52	81907.20
17	15.34	7.62	55.53	1.03	16.27	10.75	1.52	81821.66
18	11.65	4.68	56.75	1.21	15.55	10.96	1.52	80853.05
19	15.79	6.31	55.65	1.03	17.06	10.50	1.52	83094.79
20	11.10	4.55	58.60	1.03	16.07	10.79	1.52	82298.06
21	14.60	7.52	60.38	2.55	15.29	11.09	1.52	80104.66
22	8.93	2.51	61.25	1.38	15.35	11.36	1.52	77390.44
23	12.38	4.20	62.03	1.18	15.39	11.28	1.53	76080.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.83	4.14	57.54	1.00	16.54	10.96	1.52	79234.85
最 大 值	15.79	7.74	62.03	2.55	20.23	11.40	1.58	83094.79
發生時間	19	13	23	21	1	14		19
最 小 值	8.93	1.56	51.04	0.49	15.29	10.29	1.51	76080.41
發生時間	14	14	10	7	13	1		23
零點偏移(率)	-0.02 %	-0.05 %	-0.03 %	0.00 %		-0.14		-0.10 %
全幅偏移(率)	0.02 %	-0.05 %	-0.41 %	-0.04 %		-0.28		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								