

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月13日

報表日期: 114年04月13日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.17	7.12	54.05	1.08	18.59	10.62	1.26	80977.58
1	4.11	4.92	52.89	1.27	19.16	10.61	1.27	80177.28
2	4.74	8.14	54.03	1.70	17.43	10.30	1.26	86142.24
3	6.88	4.45	53.79	2.36	15.93	10.80	1.27	81663.69
4	3.91	5.80	56.95	1.38	17.14	10.45	1.30	82056.56
5	1.98	4.66	47.46	1.18	17.15	10.60	1.29	80755.77
6	8.73	3.69	48.63	1.30	17.13	10.54	1.28	81189.57
7	5.28	5.01	56.17	1.43	17.26	10.81	1.29	79759.70
8	2.99	5.61	48.03	1.71	15.54	10.84	1.28	79192.36
9	4.79	3.36	53.88	1.37	17.01	10.40	1.29	81849.28
10	5.78	3.67	52.33	0.89	18.51	10.21	1.28	83547.83
11	6.25	3.28	55.48	0.43	18.82	10.48	1.25	81577.81
12	9.23	3.63	50.99	0.92	18.76	10.19	1.24	86868.85
13	8.62	3.71	50.59	1.05	18.33	10.37	1.26	84975.82
14	3.62	3.15	56.83	0.62	18.34	10.37	1.28	85153.43
15	3.63	3.60	50.98	0.77	18.25	10.31	1.29	85790.00
16	4.12	4.77	54.87	0.68	18.25	10.60	1.29	81747.72
17	1.03	1.65	51.56	0.54	18.14	10.46	1.29	82344.89
18	4.42	3.09	44.41	0.95	17.83	10.03	1.28	83813.15
19	4.43	5.88	43.59	1.83	15.94	10.38	1.25	82274.97
20	6.32	3.50	47.86	1.89	16.33	10.64	1.23	81989.48
21	6.54	2.64	52.47	1.35	17.10	10.35	1.23	82121.76
22	7.97	2.46	40.99	1.30	15.86	10.44	1.23	79948.22
23	4.57	1.79	50.52	0.71	17.97	10.07	1.26	80098.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.17	4.15	51.22	1.20	17.53	10.45	1.27	82334.00
最 大 值	9.23	8.14	56.95	2.36	19.16	10.84	1.33	86868.85
發生時間	12	2	4	3	1	8		12
最 小 值	1.03	1.65	40.99	0.43	15.54	10.03	1.23	79192.36
發生時間	17	17	22	11	8	18		8
零點偏移(率)	-0.14 %	-0.00 %	-0.32 %	-0.00 %		-0.05		0.30 %
全幅偏移(率)	-0.30 %	-0.34 %	0.56 %	-0.50 %		0.10		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月13日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.01	6.13	53.86	2.10	17.30	10.31	1.05	87527.97
1	9.57	4.88	56.37	3.52	16.56	10.50	1.06	84128.97
2	9.85	1.56	65.64	3.64	14.90	10.69	1.06	87643.86
3	8.87	1.54	66.45	3.23	14.75	10.77	1.05	86913.89
4	9.12	1.57	65.48	3.21	14.76	10.79	1.03	86393.08
5	9.02	1.79	65.67	2.36	15.43	10.72	1.03	86575.87
6	5.72	2.22	63.53	2.06	14.60	10.98	1.04	89953.19
7	8.81	1.93	61.15	3.08	13.91	11.12	1.04	84655.52
8	9.37	4.79	56.27	3.10	13.94	10.68	1.03	82877.26
9	9.55	1.89	58.29	2.62	16.69	10.43	1.03	86337.16
10	9.66	1.81	60.71	2.26	17.34	10.40	1.04	85877.61
11	8.24	2.85	57.94	2.57	16.43	10.32	1.07	86062.48
12	8.82	2.58	56.89	2.45	16.55	10.37	1.08	85857.76
13	9.01	3.76	53.91	2.78	14.81	10.84	1.07	84069.50
14	9.38	2.77	60.07	2.32	15.52	11.28	1.09	79316.51
15	9.15	6.78	56.64	1.68	18.05	10.14	1.09	87354.37
16	9.18	9.20	51.48	2.15	18.06	9.70	1.07	88185.46
17	9.20	3.41	47.67	2.78	15.83	10.59	1.06	85580.95
18	9.19	1.98	48.15	2.54	15.44	10.79	1.06	84009.15
19	9.47	2.95	53.26	2.81	14.46	11.04	1.07	81983.05
20	8.94	4.30	54.19	3.52	13.81	10.98	1.06	82341.14
21	9.35	6.31	52.00	3.22	15.14	10.55	1.06	84230.27
22	10.67	12.18	51.22	3.61	14.42	10.47	1.05	84821.37
23	8.18	1.89	38.50	3.00	15.25	10.10	1.04	82105.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.06	3.79	56.47	2.78	15.58	10.61	1.06	85200.06
最 大 值	10.67	12.18	66.45	3.64	18.06	11.28	1.10	89953.19
發生時間	22	22	3	2	16	14		6
最 小 值	5.72	1.54	38.50	1.68	13.81	9.70	1.02	79316.51
發生時間	6	3	23	15	20	16		14
零點偏移(率)	-0.42 %	-0.03 %	-0.23 %	-0.00 %		0.02		0.10 %
全幅偏移(率)	0.14 %	-1.42 %	1.08 %	-0.03 %		0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月13日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.50	2.79	53.75	1.84	17.39	9.74	1.52	82416.03
1	7.42	9.69	60.50	2.51	17.12	10.18	1.53	84247.69
2	12.78	1.39	63.00	3.83	14.21	10.54	1.53	83187.08
3	6.13	3.54	61.75	2.84	14.80	10.20	1.53	83789.74
4	1.89	1.39	62.99	2.19	15.78	10.04	1.54	84954.63
5	1.94	1.22	60.94	2.32	15.35	10.18	1.55	83857.08
6	4.63	4.64	59.22	2.54	15.31	10.05	1.55	83277.59
7	8.93	3.45	57.45	2.23	14.62	10.39	1.56	82385.24
8	6.80	1.89	63.19	2.11	14.61	10.34	1.53	79115.48
9	8.49	6.77	66.96	1.94	15.20	10.47	1.55	80756.84
10	10.46	2.44	63.66	1.63	16.75	10.17	1.56	83789.51
11	6.17	4.94	61.80	1.19	17.29	9.89	1.56	84225.65
12	7.46	2.76	57.18	1.40	17.27	9.62	1.56	84860.49
13	9.93	2.69	62.49	1.73	17.12	9.81	1.53	84939.93
14	6.64	1.42	62.71	1.34	16.51	10.44	1.55	83359.74
15	5.36	2.06	54.31	1.17	17.82	9.77	1.55	85248.73
16	3.69	3.77	62.47	1.13	17.86	9.68	1.55	83152.96
17	3.34	8.77	57.67	1.02	17.35	9.61	1.54	84554.56
18	4.33	3.65	60.38	1.92	14.80	10.11	1.53	81949.93
19	5.61	5.28	50.02	2.16	15.25	9.34	1.52	77791.56
20	14.51	10.80	52.63	3.00	16.09	9.59	1.54	82862.05
21	7.84	8.60	45.63	1.41	16.77	9.52	1.54	83874.60
22	6.66	1.78	53.67	1.59	16.04	9.76	1.53	79451.75
23	5.66	6.23	56.79	1.45	17.50	9.65	1.55	82262.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.55	4.25	58.80	1.94	16.20	9.96	1.54	82929.62
最 大 值	14.51	10.80	66.96	3.83	17.86	10.54	1.59	85248.73
發生時間	20	20	9	2	16	2		15
最 小 值	0.50	1.22	45.63	1.02	14.21	9.34	1.50	77791.56
發生時間	0	5	21	17	2	19		19
零點偏移(率)	-0.08 %	-0.00 %	-0.25 %	-0.00 %		0.05		0.30 %
全幅偏移(率)	0.02 %	-1.43 %	0.36 %	-0.00 %		0.34		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								