

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.17	13.21	62.29	2.07	14.38	13.09	1.02	71782.31
1	2.50	9.23	62.79	0.90	15.69	12.48	1.02	75836.88
2	9.42	7.48	47.96	1.61	16.08	10.99	1.02	88344.56
3	10.20	8.40	47.37	2.86	14.03	11.55	1.02	85004.88
4	8.67	7.10	69.01	2.17	14.57	11.86	1.03	81867.62
5	3.19	8.34	40.11	0.66	15.98	11.65	1.04	78378.15
6	8.62	6.98	52.10	1.08	16.05	11.49	1.03	83536.96
7	9.75	10.40	40.44	2.70	14.25	11.95	1.04	81170.43
8	8.97	5.28	55.51	1.42	15.65	12.00	1.04	79662.05
9	10.13	8.44	59.11	0.99	15.59	11.90	1.06	80524.17
10	9.62	8.36	45.82	1.14	15.77	11.82	1.06	80937.54
11	8.74	9.21	49.50	2.01	14.36	12.12	1.06	79577.51
12	7.70	7.61	59.29	1.80	14.39	12.38	1.08	77162.43
13	6.21	8.74	63.11	1.51	14.72	12.87	1.08	73128.80
14	6.25	7.20	51.04	1.09	15.64	12.15	1.09	78752.89
15	2.39	7.94	61.19	1.09	15.16	12.67	1.09	74154.98
16	6.12	7.90	54.84	1.41	15.43	11.90	1.09	80865.52
17	9.95	7.37	50.78	1.74	15.69	11.36	1.09	85298.20
18	10.64	8.90	47.91	1.87	15.14	11.75	1.08	81998.50
19	9.22	8.63	57.61	1.77	15.19	11.93	1.08	80813.71
20	6.87	8.43	63.38	1.51	15.16	12.14	1.07	78705.97
21	4.37	8.45	60.62	0.87	15.95	12.20	1.08	77825.65
22	8.84	8.24	48.95	1.80	15.27	11.44	1.07	85055.77
23	11.71	7.91	58.33	2.10	15.55	11.68	1.07	82412.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.55	8.32	54.54	1.59	15.24	11.97	1.06	80116.58
最大值	11.71	13.21	69.01	2.86	16.08	13.09	1.10	88344.56
發生時間	23	0	4	3	2	0		2
最小值	1.17	5.28	40.11	0.66	14.03	10.99	1.02	71782.31
發生時間	0	8	5	5	3	2		0
零點偏移(率)	-0.44 %	-0.00 %	-0.01 %	-0.01 %		-0.08		0.10 %
全幅偏移(率)	1.82 %	0.57 %	0.03 %	0.12 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.27	4.55	56.78	2.41	15.10	11.52	1.02	78419.25
1	3.17	4.53	64.09	1.93	16.56	11.63	0.99	75465.76
2	0.27	5.03	62.78	1.84	16.01	11.53	0.99	77115.07
3	3.00	4.63	63.12	1.35	16.97	11.33	0.99	78065.77
4	5.78	4.74	50.63	1.17	17.92	10.64	1.00	82872.44
5	4.09	5.16	45.20	1.68	16.59	11.27	0.99	78571.06
6	1.82	6.41	50.68	2.24	17.57	10.79	1.02	78863.65
7	0.52	4.80	58.46	0.96	18.05	11.22	1.02	78052.08
8	0.92	4.67	42.76	1.13	18.26	11.44	1.01	78015.18
9	0.76	5.26	39.99	1.19	17.72	11.68	0.98	78768.69
10	3.61	5.52	34.39	2.64	16.02	11.57	0.98	82186.75
11	2.87	5.02	47.19	3.79	13.05	12.48	0.97	76799.54
12	2.20	4.25	55.51	3.28	13.90	12.34	0.97	77890.17
13	6.57	5.54	50.76	3.93	14.19	12.25	0.97	77669.17
14	7.68	7.61	63.73	3.39	14.02	12.38	0.98	76830.55
15	6.33	7.41	57.38	3.09	14.99	12.02	0.99	78947.69
16	7.18	7.25	57.35	3.72	14.48	11.88	1.02	80286.74
17	8.31	5.18	54.16	3.37	14.37	11.82	1.00	80984.04
18	8.57	4.78	60.75	2.08	13.60	12.02	1.01	79637.37
19	8.88	2.94	61.23	1.50	14.28	11.37	1.02	81637.19
20	9.85	3.23	56.55	1.57	15.15	11.07	1.02	81984.41
21	6.14	1.91	52.62	1.51	14.90	11.18	1.02	80670.75
22	10.50	3.49	53.43	2.52	14.44	11.38	1.02	78934.17
23	8.58	4.28	56.51	2.36	15.61	11.35	1.02	78452.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.20	4.92	54.00	2.28	15.57	11.59	1.00	79046.66
最大值	10.50	7.61	64.09	3.93	18.26	12.48	1.02	82872.44
發生時間	22	14	1	13	8	11		4
最小值	0.27	1.91	34.39	0.96	13.05	10.64	0.97	75465.76
發生時間	2	21	10	7	11	4		1
零點偏移(率)	-0.09 %	0.01 %	-0.01 %	-0.01 %		0.00		-0.10 %
全幅偏移(率)	-0.40 %	-0.70 %	0.45 %	0.15 %		-0.12		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.02	5.85	61.50	0.55	16.55	10.90	1.04	78617.19
1	1.71	6.17	57.55	0.45	17.51	10.50	1.04	80820.16
2	3.51	6.45	56.15	0.62	17.14	10.56	1.04	80603.09
3	1.26	6.24	59.02	0.42	18.25	10.24	1.04	82221.30
4	1.30	3.70	44.78	0.41	18.32	9.81	1.04	84598.49
5	0.71	1.25	54.93	0.80	15.81	10.61	1.04	80275.39
6	0.32	3.89	61.77	0.49	17.41	10.54	1.04	80129.76
7	0.13	7.53	58.65	0.70	15.94	11.49	1.09	81489.37
8	0.66	6.00	69.91	0.44	17.14	11.79	1.11	71554.53
9	0.33	7.21	54.97	0.72	15.44	12.82	1.35	64509.61
10	1.35	6.16	51.28	0.81	15.58	12.07	1.20	69858.80
11	1.19	3.02	34.32	0.89	15.48	10.76	1.06	80195.19
12	1.48	7.53	54.51	2.09	12.91	11.57	1.04	74832.59
13	1.44	3.10	57.78	0.83	15.06	11.23	1.05	73701.19
14	1.17	6.21	45.85	0.33	16.19	10.64	1.04	76296.86
15	1.27	4.81	56.18	0.57	15.78	11.34	1.07	74589.73
16	1.16	4.63	52.81	0.46	16.02	10.50	1.06	81967.36
17	5.01	5.00	57.59	1.24	15.11	10.90	1.06	79729.77
18	5.66	4.88	57.71	1.30	15.07	10.88	1.06	80308.01
19	7.16	4.72	59.20	0.92	16.31	10.71	1.06	81017.66
20	6.06	4.16	57.05	0.77	17.07	10.40	1.07	82505.31
21	3.26	1.78	50.90	1.38	14.22	11.05	1.06	76948.12
22	7.02	3.84	52.83	1.55	14.51	11.08	1.09	77926.58
23	5.08	7.03	54.48	1.80	14.25	11.32	1.09	76795.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.51	5.05	55.07	0.86	15.96	10.99	1.08	77978.82
最大值	7.16	7.53	69.91	2.09	18.32	12.82	1.90	84598.49
發生時間	19	7	8	12	4	9		4
最小值	0.13	1.25	34.32	0.33	12.91	9.81	1.04	64509.61
發生時間	7	5	11	14	12	4		9
零點偏移(率)	-0.09 %	0.00 %	-0.02 %	-0.01 %		-0.04		0.20 %
全幅偏移(率)	0.02 %	0.04 %	0.61 %	0.20 %		0.01		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								