

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月10日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 7.95     | 2.18     | 49.78    | 2.07     | 13.91    | 12.38    | 1.03     | 77423.88  |
| 1                 | 8.51     | 5.87     | 56.40    | 1.93     | 14.29    | 12.53    | 1.04     | 76081.11  |
| 2                 | 9.72     | 9.16     | 50.40    | 2.18     | 14.08    | 12.11    | 1.03     | 79722.06  |
| 3                 | 9.38     | 9.37     | 59.05    | 1.17     | 15.08    | 12.15    | 1.04     | 78655.70  |
| 4                 | 10.08    | 8.56     | 48.58    | 1.25     | 14.44    | 11.56    | 1.02     | 84913.22  |
| 5                 | 9.84     | 8.38     | 46.10    | 1.43     | 15.19    | 11.50    | 1.06     | 84272.77  |
| 6                 | 11.86    | 4.10     | 43.69    | 1.32     | 14.83    | 11.73    | 1.06     | 84553.06  |
| 7                 | 9.45     | 9.95     | 44.98    | 2.29     | 12.55    | 12.18    | 1.06     | 81136.22  |
| 8                 | 11.71    | 7.71     | 46.60    | 2.09     | 12.83    | 12.31    | 1.06     | 79622.20  |
| 9                 | 9.33     | 7.67     | 49.40    | 2.11     | 13.47    | 12.24    | 1.08     | 80703.42  |
| 10                | 10.89    | 9.87     | 53.13    | 2.18     | 12.46    | 12.36    | 1.10     | 80383.39  |
| 11                | 11.84    | 8.88     | 49.58    | 2.46     | 12.23    | 12.37    | 1.10     | 79930.89  |
| 12                | 11.57    | 11.19    | 47.42    | 2.28     | 13.09    | 12.14    | 1.09     | 81349.48  |
| 13                | 12.11    | 11.93    | 50.93    | 2.73     | 12.64    | 12.32    | 1.06     | 79951.02  |
| 14                | 8.79     | 9.82     | 62.44    | 2.09     | 13.30    | 12.16    | 1.06     | 80829.77  |
| 15                | 8.91     | 11.85    | 46.05    | 2.79     | 12.92    | 12.17    | 1.06     | 80398.11  |
| 16                | 7.38     | 8.77     | 59.49    | 1.33     | 14.34    | 12.10    | 1.08     | 80090.18  |
| 17                | 9.10     | 8.19     | 49.84    | 1.69     | 14.69    | 11.57    | 1.06     | 84235.96  |
| 18                | 9.34     | 9.39     | 33.22    | 2.02     | 14.53    | 11.65    | 1.06     | 83953.36  |
| 19                | 9.80     | 10.94    | 39.66    | 2.25     | 14.08    | 12.12    | 1.06     | 79982.01  |
| 20                | 5.73     | 8.14     | 41.99    | 1.65     | 15.09    | 11.77    | 1.05     | 81806.29  |
| 21                | 7.94     | 8.31     | 37.01    | 1.84     | 15.14    | 11.45    | 1.06     | 84514.48  |
| 22                | 2.98     | 8.73     | 51.56    | 1.01     | 15.25    | 12.27    | 1.07     | 77487.68  |
| 23                | 2.87     | 8.55     | 40.28    | 1.59     | 14.83    | 11.89    | 1.09     | 80815.05  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 9.04     | 8.65     | 48.23    | 1.91     | 13.97    | 12.04    | 1.06     | 80950.47  |
| 最 大 值             | 12.11    | 11.93    | 62.44    | 2.79     | 15.25    | 12.53    | 1.13     | 84913.22  |
| 發生時間              | 13       | 13       | 14       | 15       | 22       | 1        |          | 4         |
| 最 小 值             | 2.87     | 2.18     | 33.22    | 1.01     | 12.23    | 11.45    | 1.02     | 76081.11  |
| 發生時間              | 23       | 0        | 18       | 22       | 11       | 21       |          | 1         |
| 零點偏移(率)           | -0.06 %  | -0.05 %  | -0.03 %  | -0.00 %  |          | -0.01    |          | 0.30 %    |
| 全幅偏移(率)           | 0.02 %   | -1.27 %  | -0.51 %  | -0.19 %  |          | 0.22     |          | 0.30 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月10日

報表日期: 113年02月10日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 5.24     | 3.16     | 54.13    | 2.41     | 14.18    | 11.80    | 1.12     | 76508.10  |
| 1                 | 6.76     | 3.92     | 51.78    | 2.34     | 14.76    | 11.56    | 1.13     | 78227.99  |
| 2                 | 8.49     | 5.43     | 50.68    | 2.28     | 13.44    | 11.83    | 1.11     | 77850.04  |
| 3                 | 9.81     | 5.46     | 50.93    | 2.78     | 12.96    | 11.82    | 1.11     | 77790.22  |
| 4                 | 9.91     | 5.82     | 48.81    | 3.21     | 12.30    | 11.96    | 1.12     | 77355.85  |
| 5                 | 9.24     | 5.50     | 48.80    | 2.89     | 13.12    | 11.82    | 1.11     | 77776.25  |
| 6                 | 6.71     | 5.84     | 46.50    | 2.77     | 12.24    | 12.10    | 1.12     | 78495.18  |
| 7                 | 10.02    | 5.80     | 49.17    | 3.03     | 12.55    | 11.97    | 1.11     | 76828.80  |
| 8                 | 8.90     | 4.77     | 50.26    | 2.88     | 12.39    | 11.94    | 1.13     | 77521.51  |
| 9                 | 10.21    | 4.90     | 53.90    | 2.41     | 12.99    | 11.88    | 1.13     | 77201.85  |
| 10                | 7.85     | 5.49     | 51.43    | 3.35     | 11.74    | 12.17    | 1.10     | 76271.13  |
| 11                | 8.99     | 6.36     | 50.90    | 2.76     | 13.13    | 11.70    | 1.09     | 78542.43  |
| 12                | 10.02    | 6.54     | 51.71    | 3.13     | 11.99    | 12.00    | 1.09     | 77069.97  |
| 13                | 9.19     | 6.67     | 46.42    | 3.00     | 12.29    | 11.90    | 1.10     | 77969.06  |
| 14                | 10.10    | 8.28     | 48.27    | 3.25     | 11.69    | 12.24    | 1.10     | 75644.83  |
| 15                | 8.69     | 2.50     | 48.78    | 2.60     | 11.97    | 12.11    | 1.10     | 76078.52  |
| 16                | 6.80     | 4.84     | 52.83    | 2.00     | 14.08    | 11.75    | 1.10     | 77784.78  |
| 17                | 5.81     | 5.13     | 48.39    | 1.75     | 15.17    | 11.32    | 1.10     | 79870.45  |
| 18                | 5.22     | 5.97     | 43.73    | 2.43     | 13.81    | 11.74    | 1.09     | 77362.84  |
| 19                | 2.00     | 6.42     | 47.77    | 2.54     | 12.69    | 12.20    | 1.09     | 74943.62  |
| 20                | 1.61     | 5.24     | 51.33    | 1.88     | 14.45    | 11.67    | 1.09     | 77589.22  |
| 21                | 5.34     | 5.10     | 55.02    | 1.78     | 15.01    | 11.56    | 1.09     | 77976.07  |
| 22                | 6.21     | 5.61     | 51.11    | 2.39     | 15.28    | 11.23    | 1.09     | 80540.40  |
| 23                | 8.14     | 5.67     | 51.38    | 2.20     | 15.47    | 11.16    | 1.10     | 80545.57  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 7.55     | 5.43     | 50.17    | 2.59     | 13.32    | 11.81    | 1.10     | 77656.03  |
| 最 大 值             | 10.21    | 8.28     | 55.02    | 3.35     | 15.47    | 12.24    | 1.13     | 80545.57  |
| 發生時間              | 9        | 14       | 21       | 10       | 23       | 14       |          | 23        |
| 最 小 值             | 1.61     | 2.50     | 43.73    | 1.75     | 11.69    | 11.16    | 1.08     | 74943.62  |
| 發生時間              | 20       | 15       | 18       | 17       | 14       | 23       |          | 19        |
| 零點偏移(率)           | -0.01 %  | -0.17 %  | -0.02 %  | 0.00 %   |          | 0.05     |          | 0.10 %    |
| 全幅偏移(率)           | 0.02 %   | -0.23 %  | 0.03 %   | -0.11 %  |          | 0.07     |          | 0.20 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月10日

[illegible]