

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.30	9.77	61.46	0.73	18.00	11.18	1.07	78403.31
1	1.72	10.12	58.67	0.55	18.71	10.95	1.09	80897.60
2	2.43	9.50	32.87	1.94	16.59	11.39	1.07	75193.53
3	1.59	1.66	34.56	2.19	16.02	11.29	1.06	74507.28
4	6.15	13.15	41.45	1.98	16.74	11.22	1.06	77673.63
5	6.08	12.62	57.76	0.85	19.58	10.81	1.05	79015.86
6	8.32	13.06	57.67	1.40	17.25	11.39	1.07	78100.88
7	8.92	10.55	61.63	1.14	18.68	11.48	1.07	78228.11
8	9.78	9.86	54.37	1.47	17.48	11.40	1.07	77649.23
9	7.87	11.09	64.10	1.20	18.09	11.56	1.05	76120.14
10	7.95	11.17	51.69	1.34	16.77	11.77	1.07	77167.91
11	7.19	8.43	52.06	1.60	16.92	11.34	1.06	77985.55
12	3.27	7.30	58.58	0.60	19.09	10.53	1.05	76774.71
13	5.78	6.12	59.72	1.22	16.74	11.03	1.04	74369.27
14	6.68	9.78	44.63	1.86	16.55	11.74	1.05	72233.84
15	4.96	9.89	49.76	2.06	15.61	11.97	1.04	70228.92
16	6.36	6.96	59.91	1.42	17.17	11.67	1.09	75303.49
17	10.19	12.67	55.57	2.12	16.26	11.67	1.06	76144.48
18	6.74	8.33	59.11	1.41	17.08	11.96	1.07	73433.81
19	9.55	8.60	53.89	0.93	19.16	10.95	1.07	81270.77
20	6.42	15.58	54.46	1.35	16.64	11.78	1.07	74465.66
21	8.91	5.41	52.43	1.80	16.43	11.57	1.20	73311.83
22	8.44	9.98	60.59	1.54	16.92	11.77	1.10	71597.06
23	8.45	8.47	58.63	1.21	17.44	11.81	1.07	73178.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.59	9.59	53.98	1.41	17.33	11.43	1.07	75968.97
最大值	10.19	15.58	64.10	2.19	19.58	11.97	1.29	81270.77
發生時間	17	20	9	3	5	15		19
最小值	1.59	1.66	32.87	0.55	15.61	10.53	1.00	70228.92
發生時間	3	3	2	1	15	12		15
零點偏移(率)	0.00 %	0.00 %	-0.02 %	0.00 %		0.00		0.00 %
全幅偏移(率)	-1.66 %	1.21 %	-0.07 %	0.02 %		-0.06		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.09	7.35	37.14	1.02	17.86	11.39	1.07	74299.38
1	0.08	9.16	41.28	0.58	21.58	9.06	1.07	89487.73
2	12.26	12.57	60.81	2.61	17.94	10.06	1.05	85985.42
3	10.11	4.00	61.75	1.81	19.11	10.18	1.06	84263.44
4	9.01	6.84	56.39	1.66	17.88	10.27	1.05	84655.76
5	10.47	9.03	53.81	2.05	17.44	10.27	1.05	84361.76
6	10.91	9.69	56.34	1.61	17.78	10.41	1.05	79160.57
7	10.99	3.09	57.12	2.27	17.97	10.23	1.06	84389.23
8	7.72	5.45	58.03	1.82	17.39	10.81	1.07	80319.45
9	10.71	10.55	54.73	3.02	16.60	10.31	1.07	83318.72
10	6.02	5.48	58.69	1.74	17.50	10.62	1.06	80145.88
11	8.10	8.90	50.30	1.89	18.66	10.00	1.07	84383.45
12	9.90	6.88	57.94	2.39	16.07	10.59	1.07	81598.48
13	8.52	5.70	60.33	1.91	17.69	10.19	1.07	82613.95
14	7.48	7.53	59.71	1.69	17.74	10.14	1.06	81101.64
15	10.41	10.51	52.36	3.46	15.56	10.84	1.06	75929.18
16	10.25	13.88	47.39	2.63	15.12	10.46	1.05	76570.17
17	8.90	4.08	52.16	1.78	16.61	10.59	1.05	82172.24
18	8.16	4.10	56.35	1.08	18.26	10.29	1.05	84245.94
19	8.85	13.41	52.88	2.05	16.68	10.58	1.06	83000.13
20	9.89	4.93	60.57	2.13	16.25	10.74	1.05	81493.99
21	9.16	4.84	67.09	0.53	18.23	10.30	1.06	81749.97
22	9.67	8.64	52.86	1.54	17.78	10.23	1.06	84154.37
23	8.66	8.43	59.83	0.96	18.04	10.52	1.06	82351.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.60	7.71	55.24	1.84	17.57	10.38	1.06	82156.35
最大值	12.26	13.88	67.09	3.46	21.58	11.39	1.08	89487.73
發生時間	2	16	21	15	1	0		1
最小值	0.08	3.09	37.14	0.53	15.12	9.06	1.05	74299.38
發生時間	1	7	0	21	16	1		0
零點偏移(率)	-0.07 %	-0.15 %	-0.07 %	-0.08 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-0.03 %	0.57 %	0.09 %		-0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.79	9.88	44.48	1.18	17.38	9.68	1.05	81772.75
1	3.50	3.26	35.29	0.67	17.52	10.20	1.05	77419.32
2	3.92	6.10	43.57	1.41	16.66	10.38	1.05	76869.95
3	9.55	9.10	38.99	3.21	13.94	10.81	1.04	74078.45
4	10.23	6.52	47.41	1.95	16.78	10.56	1.05	79800.27
5	8.06	8.12	59.03	1.47	17.78	10.50	1.05	81247.82
6	8.90	7.53	42.06	1.61	15.88	11.44	1.05	79311.40
7	8.19	11.39	41.51	1.86	14.97	11.53	1.05	85519.76
8	7.52	7.76	45.53	1.20	17.36	11.01	1.04	81655.77
9	8.58	6.77	47.78	1.60	17.38	10.94	1.04	81973.25
10	8.85	5.14	40.05	1.54	16.24	11.24	1.06	78884.40
11	2.65	10.38	49.11	0.90	17.38	11.26	1.04	77732.63
12	4.35	3.26	41.79	1.68	15.49	11.30	1.06	76409.37
13	9.48	5.84	47.26	1.93	16.27	11.21	1.06	77153.08
14	9.18	6.34	51.39	1.65	16.23	11.44	1.02	76046.67
15	9.95	12.14	38.69	1.71	15.51	11.07	1.00	77459.82
16	14.18	14.79	45.38	3.17	13.67	11.29	1.18	78071.25
17	12.36	4.43	41.93	2.28	15.02	11.15	1.28	78567.18
18	7.84	1.87	61.66	1.26	17.11	11.38	1.35	81460.74
19	10.91	8.42	51.35	1.62	17.46	10.64	1.08	83188.29
20	7.67	10.54	45.70	1.29	16.22	10.55	1.07	77267.12
21	10.63	8.01	57.38	1.11	17.85	10.13	1.10	82100.96
22	9.91	10.99	38.91	1.11	17.73	9.86	1.06	81110.14
23	9.60	7.91	50.74	1.13	16.67	10.42	1.05	75617.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.45	7.77	46.12	1.61	16.44	10.83	1.08	79196.59
最大值	14.18	14.79	61.66	3.21	17.85	11.53	1.97	85519.76
發生時間	16	16	18	3	21	7		7
最小值	2.65	1.87	35.29	0.67	13.67	9.68	0.97	74078.45
發生時間	11	18	1	1	16	0		3
零點偏移(率)	-0.04 %	0.00 %	-0.07 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.64 %	-0.07 %	0.22 %		0.20		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								