

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年11月04日

報表日期: 114年11月04日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.83	13.86	68.17	2.51	17.56	11.78	1.20	71888.67
1	12.40	12.06	46.45	2.48	18.27	11.39	1.20	74502.01
2	12.55	11.72	48.21	3.97	16.86	10.95	1.20	79053.50
3	12.70	13.44	57.73	3.58	16.04	11.48	1.20	75888.98
4	10.93	12.24	54.11	3.02	16.46	11.57	1.23	74028.71
5	12.71	13.90	58.53	2.44	16.08	11.99	1.23	74627.56
6	11.63	13.57	59.93	2.36	16.48	11.71	1.23	73511.71
7	12.16	14.06	43.26	3.02	15.30	11.61	1.24	74177.91
8	10.99	14.39	66.56	2.05	15.99	12.35	1.25	69031.55
9	16.58	13.39	38.70	3.49	15.61	11.63	1.25	74002.76
10	11.54	13.54	54.44	3.32	15.02	11.88	1.25	72439.08
11	12.48	13.41	56.45	2.39	15.73	11.40	1.25	75984.73
12	10.55	14.26	50.20	2.49	15.37	11.73	1.25	73398.80
13	6.28	14.36	53.14	1.74	15.86	12.31	1.24	68088.60
14	12.00	13.52	59.03	1.49	16.86	11.66	1.25	72537.83
15	10.90	14.05	54.63	1.44	15.62	12.17	1.25	69824.77
16	16.25	13.37	54.82	2.71	16.23	11.42	1.25	74887.81
17	11.49	13.35	55.40	2.20	15.68	11.65	1.25	73668.20
18	9.58	14.27	54.15	0.93	16.98	12.07	1.25	69202.80
19	15.03	13.36	58.91	2.09	16.60	11.13	1.25	76292.33
20	11.34	13.75	52.01	2.00	15.25	11.64	1.26	74396.52
21	13.36	14.44	49.10	4.23	14.25	11.89	1.25	72509.23
22	11.46	15.11	45.87	1.78	15.67	11.92	1.24	71992.67
23	12.92	13.06	43.07	3.08	16.05	11.54	1.23	74394.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.99	13.60	53.45	2.53	16.08	11.70	1.24	73347.12
最 大 值	16.58	15.11	68.17	4.23	18.27	12.35	1.27	79053.50
發生時間	9	22	0	21	1	8		2
最 小 值	6.28	11.72	38.70	0.93	14.25	10.95	1.19	68088.60
發生時間	13	2	9	18	21	2		13
零點偏移(率)	-0.01 %	-0.03 %	0.00 %	-0.09 %		0.00	-0.01	0.30 %
全幅偏移(率)	0.67 %	0.17 %	-0.05 %	-0.24 %		0.03	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年11月04日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.84	11.85	68.63	2.61	18.81	10.06	1.47	79584.54
1	12.32	13.48	44.72	2.81	20.58	9.42	1.46	81662.14
2	12.90	10.33	38.46	2.80	21.59	9.60	1.44	71572.69
3	11.68	14.83	68.53	2.93	20.85	10.55	1.45	75643.09
4	12.89	14.60	52.52	3.24	19.62	10.62	1.45	74386.40
5	11.08	14.52	48.58	2.99	20.24	10.38	1.45	74088.60
6	12.76	14.33	44.46	3.26	20.11	10.15	1.43	74698.10
7	14.69	12.31	50.62	2.71	19.62	8.76	1.44	80420.53
8	12.99	13.27	48.67	2.73	19.97	8.59	1.43	83505.06
9	11.94	11.88	46.25	2.56	20.40	8.43	1.44	83838.81
10	10.61	13.33	48.38	2.43	19.55	8.66	1.46	84306.52
11	12.05	12.27	52.95	2.34	17.97	9.22	1.43	80173.08
12	12.05	12.13	54.62	2.72	18.75	9.02	1.43	82545.85
13	12.16	11.61	51.39	2.86	18.92	8.94	1.43	82220.31
14	12.41	12.28	53.88	2.73	18.95	8.87	1.43	82415.87
15	11.28	13.21	51.10	2.63	18.17	8.89	1.43	81888.62
16	13.39	12.13	54.35	3.03	18.28	9.15	1.44	83273.52
17	9.28	11.11	62.78	2.71	18.78	9.32	1.45	85137.45
18	12.67	11.67	55.95	2.72	18.76	9.26	1.47	85125.96
19	12.09	9.97	51.82	2.78	17.78	9.32	1.47	84016.39
20	13.29	10.83	53.61	1.47	17.38	9.31	1.43	82083.93
21	13.08	11.62	56.47	2.98	18.76	9.30	1.43	84906.86
22	13.45	11.21	60.72	2.76	18.46	9.48	1.43	82425.63
23	12.15	11.94	57.19	2.54	19.01	9.75	1.43	81385.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.21	12.36	53.19	2.72	19.22	9.38	1.44	80887.71
最 大 值	14.69	14.83	68.63	3.26	21.59	10.62	1.48	85137.45
發生時間	7	3	0	6	2	4		17
最 小 值	9.28	9.97	38.46	1.47	17.38	8.43	1.42	71572.69
發生時間	17	19	2	20	20	9		2
零點偏移(率)	-0.14 %	-0.00 %	-0.03 %	-0.05 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	0.20 %	-0.83 %	0.96 %	-0.48 %		0.17	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								