

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.93	3.03	39.67	1.45	16.10	11.67	0.99	80825.86
1	9.42	7.58	61.37	1.46	17.30	11.87	0.98	78527.02
2	8.69	6.94	58.96	1.45	16.05	11.73	0.99	79193.40
3	8.97	7.03	66.89	0.95	16.36	12.01	1.02	76312.45
4	9.00	7.27	62.23	0.79	16.87	11.76	1.02	78144.95
5	8.88	7.72	58.35	1.85	14.55	11.86	1.02	79312.71
6	11.20	8.31	43.51	2.47	15.17	11.63	1.02	79440.50
7	9.12	6.72	52.73	1.86	16.04	11.60	1.02	79485.57
8	6.93	6.91	59.59	1.27	16.25	11.74	1.01	77388.27
9	8.14	5.97	61.01	1.13	16.46	11.29	1.02	80925.21
10	8.91	6.62	53.90	1.91	14.78	11.80	1.02	78284.33
11	8.18	7.37	54.81	1.94	15.42	11.76	1.02	78642.12
12	6.70	6.41	56.12	1.19	15.70	11.51	1.05	80496.70
13	6.95	7.30	45.28	1.69	14.88	12.01	1.04	75197.03
14	10.29	8.54	54.07	2.51	14.68	11.89	1.05	76978.23
15	10.35	6.51	58.52	1.50	15.76	11.81	1.03	78397.37
16	10.35	9.12	39.12	3.39	13.13	11.96	1.02	78214.62
17	8.96	2.71	41.83	3.01	14.14	12.10	1.04	75958.46
18	5.56	1.95	40.36	0.66	18.28	10.92	1.06	85571.01
19	8.18	1.10	37.53	1.04	17.51	11.24	1.05	83411.62
20	8.77	3.45	44.10	1.06	17.59	11.39	1.03	82367.64
21	8.33	3.48	54.69	0.70	18.95	10.81	1.02	85375.95
22	5.82	8.41	58.65	0.30	19.14	10.92	1.03	81296.62
23	0.90	8.86	42.67	3.94	21.13	9.38	1.02	86615.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.23	6.22	51.92	1.65	16.34	11.53	1.02	79848.47
最大值	11.20	9.12	66.89	3.94	21.13	12.10	1.08	86615.63
發生時間	6	16	3	23	23	17		23
最小值	0.90	1.10	37.53	0.30	13.13	9.38	0.97	75197.03
發生時間	23	19	19	22	16	23		13
零點偏移(率)	-0.01 %	-0.09 %	-0.01 %	-0.02 %		-0.05		0.10 %
全幅偏移(率)	0.00 %	0.94 %	-0.01 %	0.37 %		-0.01		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.03	4.36	54.90	2.07	18.21	11.12	1.03	78010.86
1	9.49	5.23	42.28	3.07	16.35	11.24	1.02	78626.61
2	3.68	3.67	53.92	2.25	15.66	11.60	1.03	77060.62
3	7.13	4.91	53.24	1.76	17.89	10.93	1.05	80769.91
4	9.50	2.41	49.71	2.71	16.98	10.92	1.04	81253.23
5	9.62	3.48	41.40	2.75	17.21	10.85	1.03	81278.11
6	13.24	4.74	47.50	3.71	16.44	10.86	1.03	79024.26
7	9.75	4.81	50.90	3.16	14.68	11.58	1.02	78203.67
8	7.56	4.38	53.92	2.98	15.12	11.90	1.02	74950.36
9	6.23	4.27	46.91	2.99	14.96	11.53	1.02	77840.89
10	7.63	5.02	47.77	2.89	14.66	11.69	1.03	77007.29
11	5.85	5.31	45.84	3.36	14.41	11.71	1.04	76858.56
12	3.14	5.75	50.84	2.84	14.66	11.89	1.04	75430.73
13	3.18	5.29	52.37	2.69	14.81	11.83	1.04	75850.71
14	0.75	4.53	48.78	2.94	15.03	11.44	1.05	78465.77
15	0.11	3.31	47.98	2.53	14.55	11.67	1.04	77434.91
16	1.39	7.35	47.58	3.63	14.52	11.53	1.05	78068.44
17	2.83	9.18	50.94	4.50	12.94	11.96	1.05	75690.67
18	2.61	3.03	43.17	3.41	16.19	11.04	1.05	80218.21
19	4.18	2.42	52.41	2.73	16.83	10.89	1.04	80494.35
20	8.02	1.88	49.09	3.04	16.08	11.34	1.05	77654.49
21	3.80	3.28	46.59	2.95	15.98	11.30	1.05	77912.92
22	3.87	4.62	48.07	1.74	16.94	11.34	1.04	77684.14
23	2.79	4.75	59.10	1.46	17.07	11.75	1.04	73394.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.60	4.50	49.38	2.84	15.76	11.41	1.04	77882.69
最大值	13.24	9.18	59.10	4.50	18.21	11.96	1.06	81278.11
發生時間	6	17	23	17	0	17		5
最小值	0.11	1.88	41.40	1.46	12.94	10.85	1.02	73394.93
發生時間	15	20	5	23	17	5		23
零點偏移(率)	-0.07 %	-0.09 %	-0.05 %	-0.03 %		-0.01		-0.10 %
全幅偏移(率)	-0.08 %	2.14 %	0.20 %	0.33 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.36	5.21	44.49	1.01	17.18	10.42	1.04	82293.81
1	6.44	5.61	55.99	0.95	17.23	10.66	1.04	80368.08
2	8.99	4.93	57.92	1.51	16.30	10.77	1.04	79497.19
3	7.50	4.69	59.76	0.93	17.02	10.59	1.04	81381.22
4	6.75	4.78	57.62	0.82	18.27	10.27	1.03	81238.03
5	6.69	4.91	54.71	0.94	16.61	10.68	1.04	80008.88
6	8.04	5.45	56.31	1.12	16.23	10.76	1.04	79947.84
7	11.59	3.98	57.01	2.15	15.18	10.92	1.01	78126.31
8	10.25	3.81	57.93	1.30	15.77	10.80	1.01	77010.35
9	4.99	3.30	56.57	0.77	16.31	10.42	0.99	79977.18
10	5.98	4.21	56.00	1.29	14.72	10.74	1.00	77219.72
11	3.14	6.85	60.77	3.66	14.15	11.04	1.00	74377.40
12	7.15	3.22	55.84	3.08	15.30	10.68	1.02	77272.17
13	2.34	2.02	57.83	0.66	15.60	10.70	1.02	76025.22
14	6.86	2.39	52.91	0.66	16.37	10.34	1.00	77229.90
15	8.05	2.54	57.98	0.49	16.61	10.61	0.99	75205.91
16	8.62	4.38	48.26	1.60	15.09	10.38	1.00	76044.36
17	4.05	5.93	55.59	0.76	16.80	10.46	0.98	73776.29
18	3.45	5.75	55.50	0.40	18.73	9.63	1.00	86163.39
19	10.00	5.85	52.07	1.35	16.60	10.01	1.02	85396.22
20	7.05	2.26	60.72	0.95	16.99	10.33	1.02	81096.74
21	5.63	2.55	60.46	0.49	17.62	10.40	1.01	80789.35
22	6.85	2.55	62.93	0.55	18.87	9.88	0.99	81893.75
23	3.34	2.98	55.16	0.52	17.32	10.50	0.99	78205.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.75	4.17	56.26	1.17	16.54	10.50	1.01	79189.36
最大值	11.59	6.85	62.93	3.66	18.87	11.04	1.04	86163.39
發生時間	7	11	22	11	22	11		18
最小值	2.34	2.02	44.49	0.40	14.15	9.63	0.97	73776.29
發生時間	13	13	0	18	11	18		17
零點偏移(率)	-0.01 %	-0.04 %	-0.07 %	-0.08 %		0.00		0.00 %
全幅偏移(率)	0.90 %	0.31 %	0.05 %	0.41 %		0.02		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								