

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.28	2.28	50.16	2.18	17.13	11.87	1.51	72843.79
1	10.28	1.26	54.55	2.09	18.05	11.85	1.51	72160.96
2	11.00	4.16	54.39	2.24	17.06	11.90	1.51	73019.30
3	9.01	4.78	51.94	2.22	17.10	11.93	1.51	73446.11
4	9.27	5.20	55.74	2.20	17.11	11.78	1.51	74045.79
5	11.51	5.20	57.94	2.44	16.76	12.03	1.48	71521.93
6	10.54	6.12	53.29	2.60	16.59	11.93	1.46	72412.42
7	10.30	3.70	53.57	2.46	17.58	11.69	1.46	74370.87
8	2.81	3.10	68.29	1.99	18.15	11.97	1.49	71107.76
9	3.93	2.98	70.91	2.03	18.79	12.00	1.51	70376.02
10	5.64	2.02	69.96	1.85	19.61	11.30	1.51	75215.99
11	10.95	3.67	57.26	2.14	17.84	11.58	1.44	73719.34
12	8.26	2.58	57.06	2.05	18.33	11.56	1.48	73050.21
13	8.56	1.20	55.96	2.20	17.94	11.70	1.47	72009.79
14	7.13	1.62	51.36	2.10	17.76	11.65	1.47	72741.63
15	5.19	1.59	54.97	2.15	17.09	11.82	1.49	72145.11
16	4.06	2.14	52.95	2.29	16.64	12.02	1.48	71111.77
17	3.52	1.76	62.45	2.08	17.31	11.90	1.46	71544.03
18	1.62	1.76	70.82	2.12	17.56	12.32	1.51	68168.20
19	1.09	1.27	69.08	1.88	18.54	11.74	1.51	72232.43
20	3.39	1.91	49.53	2.09	17.65	11.98	1.46	70481.20
21	5.55	1.91	50.89	2.19	17.48	11.86	1.43	71601.84
22	5.06	2.10	56.35	2.20	17.20	12.24	1.42	68717.92
23	2.60	4.05	68.08	2.19	17.45	12.44	1.45	68263.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.65	2.85	58.23	2.17	17.61	11.88	1.48	71929.48
最大值	11.51	6.12	70.91	2.60	19.61	12.44	1.58	75215.99
發生時間	5	6	9	6	10	23		10
最小值	1.09	1.20	49.53	1.85	16.59	11.30	1.41	68168.20
發生時間	19	13	20	10	6	10		18
零點偏移(率)	-0.01 %	-0.02 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.58 %	0.54 %	-0.70 %	0.22 %		0.15	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.49	1.07	52.08	2.32	15.11	11.12	1.44	63456.83
1	10.26	0.93	50.29	2.20	15.48	11.02	1.44	63982.90
2	10.29	3.82	53.68	2.44	14.41	11.16	1.44	64353.94
3	7.91	6.48	52.96	2.51	14.56	11.52	1.43	56318.49
4	10.63	4.80	49.25	2.42	14.90	10.95	1.43	65898.48
5	10.14	2.71	52.84	2.38	14.76	10.95	1.45	64020.72
6	9.53	2.30	48.91	2.24	15.90	10.78	1.46	60727.24
7	10.43	3.03	46.59	2.44	15.15	10.58	1.46	63291.51
8	10.02	3.60	45.95	2.37	14.83	10.53	1.46	62458.23
9	10.74	6.83	49.95	1.90	16.85	10.42	1.45	63979.52
10	9.45	3.54	42.98	1.95	17.24	10.31	1.40	65329.24
11	7.77	2.87	43.91	2.06	15.87	10.70	1.41	63677.73
12	4.31	10.44	51.31	1.55	17.91	10.25	1.44	64811.99
13	8.96	1.30	42.80	2.00	16.38	10.33	1.39	65160.35
14	10.62	0.91	42.00	2.10	16.17	10.47	1.41	64108.08
15	10.61	0.95	45.02	2.01	16.78	10.43	1.44	64108.43
16	10.29	2.64	47.35	2.08	16.00	10.71	1.43	65665.05
17	8.18	0.76	49.18	1.83	16.55	10.60	1.41	64935.41
18	9.26	3.56	47.73	1.72	17.12	10.34	1.38	65037.24
19	9.10	2.56	55.66	1.74	17.22	10.57	1.43	66410.24
20	8.84	9.22	48.79	2.22	15.29	11.00	1.43	63188.54
21	10.24	6.45	48.17	2.13	15.93	10.78	1.42	64563.63
22	10.62	4.08	48.21	2.13	15.67	10.87	1.42	63334.89
23	10.64	2.88	51.45	2.14	15.67	10.97	1.41	64412.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.56	3.66	48.63	2.12	15.91	10.72	1.43	63884.62
最大值	10.74	10.44	55.66	2.51	17.91	11.52	1.48	66410.24
發生時間	9	12	19	3	12	3		19
最小值	4.31	0.76	42.00	1.55	14.41	10.25	1.38	56318.49
發生時間	12	17	14	12	2	12		3
零點偏移(率)	-0.23 %	-0.05 %	-0.00 %	-0.02 %		-0.05	0.00	0.00 %
全幅偏移(率)	3.93 %	0.48 %	-0.31 %	0.37 %		0.17	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.45	1.97	61.10	2.64	13.15	11.50	1.80	82953.97
1	7.04	1.52	60.64	2.62	13.36	11.71	1.80	82744.08
2	10.46	3.85	60.14	2.99	12.87	11.56	1.80	82802.49
3	9.48	3.95	55.93	2.57	13.55	11.37	1.80	82977.70
4	9.98	4.63	55.52	2.28	13.95	11.22	1.80	85088.88
5	13.07	7.59	55.17	2.80	13.56	11.32	1.79	84242.63
6	13.16	9.16	56.93	2.67	13.53	11.61	1.77	82239.81
7	11.30	5.69	57.88	3.11	12.80	11.58	1.76	82451.74
8	11.38	3.72	56.36	3.14	12.56	11.56	1.77	81445.85
9	9.79	3.61	65.31	2.05	15.15	11.24	1.76	84366.31
10	12.53	9.99	57.97	2.14	15.42	11.15	1.79	85086.03
11	10.50	6.05	50.57	2.03	15.20	11.16	1.79	86892.29
12	7.89	8.99	52.22	2.26	14.01	10.97	1.80	82471.08
13	6.56	1.81	54.49	1.67	15.75	10.51	1.80	84121.91
14	8.23	1.63	49.96	2.11	14.61	10.84	1.80	82395.89
15	8.75	2.68	52.98	2.11	14.58	10.90	1.82	83176.76
16	11.48	4.65	53.29	2.06	15.25	10.78	1.81	83650.83
17	8.31	1.32	58.60	1.77	16.11	10.68	1.80	84390.30
18	10.69	3.50	53.28	1.80	15.38	10.96	1.80	86839.97
19	9.29	2.02	50.31	1.79	15.59	10.81	1.77	84910.97
20	12.01	1.40	54.09	1.95	15.51	10.75	1.78	85536.58
21	12.87	1.86	55.74	2.84	13.18	11.21	1.77	81247.94
22	11.89	1.00	54.65	1.92	15.84	10.74	1.77	84875.99
23	10.75	5.21	56.25	1.87	15.32	10.84	1.77	83964.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.24	4.08	55.81	2.30	14.43	11.12	1.79	83786.45
最大值	13.16	9.99	65.31	3.14	16.11	11.71	1.83	86892.29
發生時間	6	10	9	8	17	1		11
最小值	6.56	1.00	49.96	1.67	12.56	10.51	1.75	81247.94
發生時間	13	22	14	13	8	13		21
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.03 %		0.00	0.00	0.00 %
全幅偏移(率)	3.04 %	0.75 %	-0.21 %	0.50 %		0.07	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								