

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月26日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 1.50 | 11.63 | 55.17 | 2.02 | 17.91 | 11.24 | 1.23 | 73778.47 |
| 1 | 0.13 | 11.56 | 56.76 | 1.46 | 19.01 | 11.04 | 1.24 | 74317.37 |
| 2 | 3.70 | 11.85 | 58.21 | 2.28 | 17.99 | 11.41 | 1.25 | 72838.08 |
| 3 | 5.36 | 12.10 | 58.39 | 1.90 | 18.42 | 11.25 | 1.25 | 73960.19 |
| 4 | 5.00 | 12.08 | 57.01 | 1.36 | 19.96 | 10.67 | 1.25 | 76594.18 |
| 5 | 4.83 | 12.63 | 51.25 | 2.27 | 18.11 | 10.93 | 1.25 | 81518.36 |
| 6 | 5.42 | 12.42 | 52.72 | 2.33 | 17.97 | 10.99 | 1.25 | 76301.49 |
| 7 | 6.74 | 12.68 | 42.16 | 2.66 | 17.40 | 10.98 | 1.25 | 74313.66 |
| 8 | 11.44 | 11.91 | 55.13 | 1.80 | 17.45 | 11.35 | 1.26 | 73122.41 |
| 9 | 12.48 | 11.88 | 54.16 | 1.36 | 20.00 | 10.45 | 1.25 | 77202.22 |
| 10 | 7.89 | 11.70 | 55.72 | 1.95 | 17.28 | 11.13 | 1.24 | 74648.05 |
| 11 | 4.40 | 11.89 | 56.27 | 1.65 | 17.71 | 11.21 | 1.24 | 73416.28 |
| 12 | 5.93 | 11.60 | 55.93 | 1.77 | 17.04 | 11.33 | 1.25 | 73201.94 |
| 13 | 3.85 | 11.62 | 60.18 | 1.39 | 17.96 | 11.23 | 1.24 | 73302.95 |
| 14 | 5.36 | 11.64 | 49.17 | 1.98 | 16.81 | 11.36 | 1.23 | 72665.39 |
| 15 | 8.55 | 12.03 | 55.79 | 1.36 | 17.97 | 11.32 | 1.23 | 72766.57 |
| 16 | 8.27 | 11.80 | 53.19 | 1.75 | 17.27 | 11.20 | 1.24 | 73420.43 |
| 17 | 6.64 | 11.26 | 55.29 | 1.03 | 19.83 | 10.64 | 1.23 | 76169.65 |
| 18 | 7.38 | 11.65 | 49.35 | 1.47 | 17.88 | 10.92 | 1.24 | 75870.45 |
| 19 | 8.17 | 11.44 | 60.14 | 1.59 | 18.60 | 10.77 | 1.22 | 76346.10 |
| 20 | 5.70 | 11.33 | 58.90 | 2.77 | 17.17 | 11.09 | 1.23 | 75195.36 |
| 21 | 3.35 | 12.31 | 61.80 | 1.98 | 19.28 | 10.95 | 1.25 | 74430.46 |
| 22 | 8.28 | 12.24 | 55.36 | 2.98 | 16.31 | 11.17 | 1.24 | 74765.84 |
| 23 | 12.57 | 12.80 | 41.76 | 2.93 | 18.04 | 11.09 | 1.23 | 74751.75 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 6.37 | 11.92 | 54.58 | 1.92 | 18.06 | 11.07 | 1.24 | 74787.40 |
| 最大值 | 12.57 | 12.80 | 61.80 | 2.98 | 20.00 | 11.41 | 1.30 | 81518.36 |
| 發生時間 | 23 | 23 | 21 | 22 | 9 | 2 | | 5 |
| 最小值 | 0.13 | 11.26 | 41.76 | 1.03 | 16.31 | 10.45 | 1.20 | 72665.39 |
| 發生時間 | 1 | 17 | 23 | 17 | 22 | 9 | | 14 |
| 零點偏移(率) | -0.01 % | -0.12 % | -0.01 % | 0.00 % | | -0.06 | -0.01 | 0.20 % |
| 全幅偏移(率) | 2.53 % | -0.55 % | 0.24 % | -0.15 % | | -0.18 | 0.10 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月26日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 7.96 | 11.85 | 70.05 | 1.07 | 18.58 | 10.33 | 0.99 | 79271.69 |
| 1 | 5.04 | 13.69 | 57.34 | 1.90 | 16.81 | 11.84 | 0.99 | 69904.89 |
| 2 | 6.88 | 13.65 | 59.69 | 1.03 | 17.65 | 11.65 | 0.98 | 72265.56 |
| 3 | 8.68 | 12.88 | 53.03 | 1.09 | 17.72 | 10.89 | 0.97 | 82501.93 |
| 4 | 12.40 | 12.54 | 51.05 | 1.61 | 16.90 | 11.08 | 0.98 | 81042.49 |
| 5 | 9.81 | 12.48 | 58.53 | 0.94 | 18.46 | 10.81 | 0.99 | 82368.67 |
| 6 | 7.44 | 12.04 | 47.32 | 1.09 | 17.64 | 10.58 | 1.02 | 85451.06 |
| 7 | 8.89 | 12.00 | 53.54 | 0.93 | 17.77 | 10.74 | 1.02 | 80035.65 |
| 8 | 11.91 | 12.83 | 53.47 | 1.96 | 17.67 | 10.60 | 1.00 | 79602.39 |
| 9 | 8.16 | 12.56 | 44.02 | 1.79 | 17.96 | 10.01 | 1.01 | 80254.55 |
| 10 | 9.99 | 12.69 | 37.50 | 1.17 | 19.27 | 9.82 | 1.01 | 78978.79 |
| 11 | 11.75 | 12.75 | 42.30 | 1.93 | 18.32 | 10.13 | 1.02 | 78462.16 |
| 12 | 7.70 | 12.70 | 66.87 | 1.45 | 17.93 | 10.34 | 1.00 | 79687.13 |
| 13 | 8.53 | 12.44 | 44.79 | 1.46 | 17.60 | 10.16 | 1.00 | 77803.41 |
| 14 | 11.58 | 12.76 | 46.20 | 2.61 | 16.19 | 10.49 | 1.02 | 78662.37 |
| 15 | 7.65 | 12.37 | 38.58 | 1.60 | 18.18 | 9.90 | 1.00 | 78268.05 |
| 16 | 8.16 | 13.15 | 47.92 | 1.67 | 18.24 | 10.51 | 1.02 | 75056.42 |
| 17 | 8.64 | 12.54 | 52.34 | 1.25 | 18.85 | 10.01 | 1.00 | 77760.47 |
| 18 | 8.10 | 13.51 | 38.78 | 1.64 | 18.50 | 9.99 | 1.00 | 81134.59 |
| 19 | 9.62 | 12.04 | 43.31 | 1.69 | 18.70 | 9.90 | 0.99 | 80829.43 |
| 20 | 12.10 | 12.08 | 60.46 | 2.00 | 17.66 | 10.32 | 1.01 | 82728.59 |
| 21 | 7.72 | 11.60 | 37.55 | 1.81 | 18.52 | 9.72 | 0.98 | 79495.86 |
| 22 | 8.75 | 11.99 | 39.61 | 1.86 | 18.46 | 9.66 | 0.99 | 81855.44 |
| 23 | 9.67 | 12.52 | 50.02 | 1.14 | 19.61 | 9.57 | 0.99 | 81964.25 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.05 | 12.57 | 49.76 | 1.53 | 18.05 | 10.38 | 1.00 | 79391.08 |
| 最大值 | 12.40 | 13.69 | 70.05 | 2.61 | 19.61 | 11.84 | 1.02 | 85451.06 |
| 發生時間 | 4 | 1 | 0 | 14 | 23 | 1 | | 6 |
| 最小值 | 5.04 | 11.60 | 37.50 | 0.93 | 16.19 | 9.57 | 0.97 | 69904.89 |
| 發生時間 | 1 | 21 | 10 | 7 | 14 | 23 | | 1 |
| 零點偏移(率) | -0.06 % | -0.00 % | -0.03 % | -0.00 % | | -0.08 | -0.01 | 0.00 % |
| 全幅偏移(率) | 0.37 % | -1.84 % | 0.87 % | -0.26 % | | 0.04 | 0.00 | 0.00 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月26日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 7.39 | 11.60 | 59.20 | 2.85 | 17.40 | 10.30 | 1.35 | 78308.35 |
| 1 | 5.02 | 11.83 | 52.11 | 2.62 | 19.56 | 9.93 | 1.34 | 78229.88 |
| 2 | 5.20 | 12.04 | 38.13 | 2.51 | 20.36 | 9.02 | 1.32 | 75960.15 |
| 3 | 6.19 | 12.18 | 31.83 | 2.83 | 19.66 | 8.74 | 1.31 | 76383.71 |
| 4 | 4.24 | 12.40 | 30.58 | 2.67 | 18.65 | 8.91 | 1.31 | 74749.69 |
| 5 | 6.16 | 11.61 | 37.66 | 2.80 | 18.99 | 8.84 | 1.31 | 74884.11 |
| 6 | 6.95 | 12.06 | 31.36 | 3.05 | 19.28 | 8.79 | 1.31 | 74625.30 |
| 7 | 8.37 | 11.42 | 41.85 | 2.95 | 17.70 | 9.42 | 1.34 | 76659.41 |
| 8 | 8.34 | 11.29 | 48.94 | 2.40 | 18.18 | 9.48 | 1.33 | 75479.38 |
| 9 | 8.01 | 10.97 | 49.62 | 2.00 | 18.35 | 9.35 | 1.34 | 76275.59 |
| 10 | 9.74 | 11.33 | 40.70 | 2.15 | 18.69 | 9.04 | 1.31 | 77971.58 |
| 11 | 6.09 | 10.76 | 49.04 | 1.87 | 18.23 | 9.32 | 1.34 | 75915.13 |
| 12 | 9.27 | 10.71 | 48.52 | 2.07 | 19.10 | 9.14 | 1.33 | 77113.43 |
| 13 | 6.03 | 10.67 | 53.33 | 1.98 | 19.01 | 9.25 | 1.31 | 77425.87 |
| 14 | 7.50 | 11.38 | 51.32 | 1.91 | 17.74 | 9.57 | 1.33 | 75753.47 |
| 15 | 7.67 | 12.06 | 53.17 | 1.93 | 16.89 | 9.74 | 1.35 | 74469.90 |
| 16 | 7.25 | 12.11 | 52.80 | 2.03 | 17.92 | 9.75 | 1.36 | 74606.43 |
| 17 | 7.39 | 12.14 | 52.99 | 1.94 | 18.17 | 9.78 | 1.34 | 74562.95 |
| 18 | 6.08 | 12.15 | 43.54 | 1.86 | 20.01 | 9.35 | 1.31 | 74894.47 |
| 19 | 9.35 | 11.85 | 47.85 | 2.48 | 18.75 | 9.68 | 1.31 | 74308.09 |
| 20 | 4.93 | 11.14 | 46.23 | 2.68 | 18.53 | 9.55 | 1.31 | 74752.28 |
| 21 | 6.95 | 11.55 | 46.82 | 2.90 | 16.78 | 9.70 | 1.32 | 74283.43 |
| 22 | 6.84 | 11.08 | 54.78 | 3.02 | 17.99 | 9.62 | 1.31 | 75252.00 |
| 23 | 9.25 | 11.48 | 42.03 | 2.92 | 18.14 | 9.42 | 1.31 | 74582.96 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 7.09 | 11.58 | 46.02 | 2.43 | 18.50 | 9.40 | 1.32 | 75726.98 |
| 最大值 | 9.74 | 12.40 | 59.20 | 3.05 | 20.36 | 10.30 | 1.36 | 78308.35 |
| 發生時間 | 10 | 4 | 0 | 6 | 2 | 0 | | 0 |
| 最小值 | 4.24 | 10.67 | 30.58 | 1.86 | 16.78 | 8.74 | 1.29 | 74283.43 |
| 發生時間 | 4 | 13 | 4 | 18 | 21 | 3 | | 21 |
| 零點偏移(率) | -0.10 % | -0.06 % | -0.11 % | 0.00 % | | -0.11 | -0.01 | 0.20 % |
| 全幅偏移(率) | 1.18 % | -0.61 % | 0.48 % | -0.14 % | | 0.24 | 0.04 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |