

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.81	4.43	67.90	2.19	16.73	12.87	1.42	65390.25
1	7.20	3.47	53.42	2.00	17.46	11.99	1.38	71812.68
2	10.65	3.65	52.73	2.16	18.61	11.41	1.37	75653.21
3	10.44	3.35	54.13	2.90	15.91	11.99	1.37	72995.59
4	9.56	6.10	57.42	2.76	16.50	11.98	1.38	72443.00
5	12.98	5.75	59.04	2.40	17.55	11.76	1.39	72414.81
6	5.69	3.50	54.38	2.05	17.07	11.98	1.41	72473.22
7	7.28	4.00	59.67	2.37	16.40	12.78	1.43	66429.05
8	2.94	3.97	59.03	2.04	16.81	12.20	1.46	70652.39
9	3.26	3.44	54.06	1.90	16.66	12.03	1.42	71854.87
10	8.56	3.34	57.11	2.66	15.32	12.05	1.40	72572.31
11	9.42	3.60	53.97	2.57	15.67	12.23	1.40	70993.88
12	9.05	7.45	57.91	3.12	14.63	12.71	1.44	66439.08
13	7.21	3.51	61.34	2.88	14.97	12.46	1.46	69529.05
14	3.06	3.75	61.42	2.24	16.10	12.43	1.46	69066.56
15	0.46	3.91	64.90	2.08	15.84	12.57	1.45	67435.87
16	0.14	3.54	58.84	1.56	17.56	12.05	1.46	70560.25
17	0.08	3.23	62.36	1.58	16.87	11.79	1.44	73285.37
18	3.45	3.72	56.44	2.22	15.96	12.07	1.42	70858.33
19	4.66	3.84	63.48	1.95	17.10	12.20	1.44	69434.65
20	9.13	3.64	51.50	2.24	16.64	11.99	1.42	71722.48
21	10.89	5.61	48.50	2.74	15.74	12.30	1.42	70017.01
22	10.40	5.96	64.19	2.53	16.01	12.52	1.45	67646.93
23	8.05	3.43	66.35	1.97	16.86	12.13	1.46	70604.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.52	4.17	58.34	2.30	16.46	12.19	1.42	70511.90
最大值	12.98	7.45	67.90	3.12	18.61	12.87	1.49	75653.21
發生時間	5	12	0	12	2	0		2
最小值	0.08	3.23	48.50	1.56	14.63	11.41	1.36	65390.25
發生時間	17	17	21	16	12	2		0
零點偏移(率)	0.00 %	0.00 %	-0.00 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.31 %	-0.01 %	-0.27 %	0.09 %		0.28	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.16	3.37	64.08	1.77	18.89	10.22	1.46	85074.46
1	10.39	4.04	39.78	2.05	18.80	10.17	1.46	86922.38
2	10.54	4.15	55.30	2.83	18.61	10.40	1.45	85572.31
3	9.89	3.51	56.42	2.24	18.18	10.43	1.45	86673.03
4	9.43	3.29	53.31	2.14	17.77	10.43	1.45	85549.29
5	10.40	5.83	55.23	2.43	16.97	10.74	1.45	83901.35
6	9.62	6.33	50.03	2.16	18.15	10.37	1.43	87080.75
7	9.76	3.76	50.96	2.21	18.36	10.33	1.44	85885.56
8	8.56	4.29	54.12	1.93	18.43	10.24	1.41	85317.88
9	7.47	6.64	52.61	2.26	17.03	10.57	1.38	82086.26
10	9.30	3.60	43.12	2.65	17.04	10.44	1.38	81556.04
11	9.47	4.06	47.09	2.73	15.75	10.87	1.39	81269.77
12	10.74	5.97	56.27	3.10	14.39	11.14	1.43	79124.96
13	7.88	7.99	62.77	2.62	15.89	11.02	1.43	79804.83
14	9.68	3.55	47.84	2.44	16.02	10.84	1.44	81873.66
15	12.60	4.92	48.75	2.70	15.71	10.91	1.45	79094.22
16	8.76	3.64	49.95	1.91	18.29	10.09	1.43	83817.68
17	8.50	4.36	48.19	2.23	16.10	10.58	1.42	79673.01
18	4.86	1.85	51.07	2.12	15.76	10.84	1.42	76522.55
19	2.13	1.64	49.01	1.25	18.03	10.26	1.43	84680.32
20	10.51	1.47	46.49	2.44	15.69	10.83	1.43	79567.56
21	8.75	1.53	48.42	2.18	16.30	10.75	1.43	80757.51
22	9.50	1.59	40.07	1.52	18.92	9.92	1.44	81507.08
23	6.70	1.53	39.87	1.18	19.75	9.86	1.45	83586.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.94	3.87	50.45	2.21	17.28	10.51	1.43	82787.45
最大值	12.60	7.99	64.08	3.10	19.75	11.14	1.47	87080.75
發生時間	15	13	0	12	23	12		6
最小值	2.13	1.47	39.78	1.18	14.39	9.86	1.37	76522.55
發生時間	19	20	1	23	12	23		18
零點偏移(率)	-0.09 %	-0.01 %	-0.02 %	-0.01 %		-0.05	0.00	0.00 %
全幅偏移(率)	0.95 %	0.02 %	-0.08 %	0.06 %		0.09	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.01	3.63	59.51	1.66	17.08	10.87	1.43	86517.74
1	8.22	7.76	57.04	1.49	17.54	10.68	1.43	87029.10
2	9.50	6.89	51.85	1.98	18.07	10.36	1.43	88180.39
3	10.08	6.57	56.80	2.41	15.92	10.86	1.43	85356.41
4	9.78	6.04	58.16	2.62	14.59	11.17	1.43	84517.92
5	9.19	4.96	61.29	2.45	15.43	11.13	1.43	82913.31
6	7.37	6.67	56.63	2.05	15.56	11.09	1.45	83713.23
7	9.30	4.70	58.12	2.02	16.27	10.81	1.45	89448.72
8	9.79	3.94	53.34	1.92	16.26	10.83	1.42	85687.03
9	8.50	3.88	56.63	1.93	16.41	10.72	1.42	84419.14
10	9.04	5.37	59.29	2.47	14.37	11.30	1.43	82922.87
11	8.12	4.83	56.88	2.52	14.46	11.17	1.43	80949.00
12	10.29	4.59	55.73	3.12	14.79	10.86	1.42	79434.25
13	10.21	6.09	51.47	5.25	12.13	11.07	1.41	77028.30
14	9.30	3.09	51.11	3.85	13.83	10.87	1.41	78397.38
15	8.39	3.28	47.88	2.28	15.58	10.62	1.40	78702.16
16	10.05	2.42	59.98	2.24	16.61	10.60	1.41	79830.89
17	9.43	3.32	57.82	2.01	17.27	10.23	1.42	81712.29
18	7.08	3.58	53.47	1.44	16.89	10.49	1.41	81009.12
19	7.48	3.14	52.64	1.49	16.71	10.54	1.42	81439.32
20	6.77	3.54	54.98	1.54	16.40	10.51	1.43	84457.92
21	9.04	3.02	57.93	1.76	15.61	10.89	1.43	82275.14
22	7.67	2.55	61.49	1.66	15.78	10.98	1.43	80685.95
23	6.97	2.59	53.24	1.51	16.24	10.69	1.43	82717.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.73	4.44	55.97	2.24	15.82	10.81	1.42	82889.38
最大值	10.29	7.76	61.49	5.25	18.07	11.30	1.49	89448.72
發生時間	12	1	22	13	2	10		7
最小值	6.77	2.42	47.88	1.44	12.13	10.23	1.38	77028.30
發生時間	20	16	15	18	13	17		13
零點偏移(率)	-0.14 %	0.00 %	-0.05 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.88 %	-0.03 %	-0.27 %	0.07 %		0.26	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								