

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.59	12.31	58.27	1.98	17.76	10.56	1.23	86334.74
1	7.87	13.10	49.48	1.57	16.94	11.64	1.23	78703.13
2	11.14	11.97	52.87	1.68	17.70	10.65	1.23	86107.12
3	9.35	12.17	52.02	1.88	15.72	11.09	1.23	84607.28
4	10.39	12.24	49.40	2.09	15.13	11.23	1.23	84047.78
5	6.16	11.72	51.62	1.64	14.23	11.85	1.18	82703.94
6	9.99	11.99	61.47	1.62	14.49	11.83	1.18	79912.61
7	12.08	11.70	55.54	1.54	16.95	11.14	1.18	82853.85
8	6.78	11.26	57.40	1.03	16.68	11.12	1.19	83187.94
9	8.22	11.45	56.33	1.60	16.21	11.38	1.20	81669.75
10	9.18	11.69	58.02	1.95	15.83	11.63	1.18	79644.74
11	7.43	12.06	51.68	2.69	13.87	12.07	1.19	77924.73
12	6.15	12.04	55.44	2.42	14.35	12.01	1.19	77576.17
13	10.45	12.05	56.04	2.28	15.30	11.60	1.18	79978.12
14	9.56	12.38	56.77	2.83	13.94	12.15	1.19	77041.41
15	8.81	11.87	56.74	2.23	15.93	11.56	1.18	79921.49
16	9.04	12.37	50.01	2.55	15.27	11.44	1.18	80378.90
17	11.31	12.19	47.30	2.94	14.23	11.93	1.18	78479.24
18	8.00	11.70	48.03	2.48	15.10	11.65	1.18	80346.86
19	10.32	12.02	57.29	3.28	16.66	11.07	1.18	83570.28
20	9.07	12.21	51.57	2.22	14.63	11.55	1.18	81334.90
21	9.43	11.68	52.30	1.54	15.74	11.38	1.19	81788.73
22	9.31	11.76	47.54	1.55	15.39	11.46	1.18	81341.50
23	8.71	11.54	52.17	1.26	16.18	11.40	1.18	81204.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.14	11.98	53.55	2.04	15.59	11.47	1.19	81277.47
最大值	12.08	13.10	61.47	3.28	17.76	12.15	1.24	86334.74
發生時間	7	1	6	19	0	14		0
最小值	6.15	11.26	47.30	1.03	13.87	10.56	1.18	77041.41
發生時間	12	8	17	8	11	0		14
零點偏移(率)	-0.20 %	-0.01 %	-0.40 %	0.00 %		0.00	-0.01	0.10 %
全幅偏移(率)	-0.47 %	-1.14 %	1.83 %	-0.30 %		0.16	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.19	11.77	42.71	0.89	17.46	10.50	0.94	78822.68
1	5.68	12.61	54.73	1.95	17.35	11.15	0.94	77911.66
2	11.13	11.96	55.35	2.09	16.76	10.76	0.95	83885.71
3	9.21	11.89	59.50	2.44	16.70	10.72	0.94	84849.42
4	10.72	12.06	60.74	2.69	15.68	11.00	0.94	83401.36
5	6.84	12.16	65.64	2.50	15.47	11.10	0.94	81723.40
6	11.11	12.14	54.27	1.74	16.73	10.97	0.98	79089.55
7	9.57	12.11	51.20	2.41	16.87	10.89	0.99	82363.25
8	9.25	12.41	55.19	1.98	17.15	11.11	1.00	80314.16
9	11.54	11.97	57.53	1.82	17.46	10.73	1.00	82651.41
10	7.08	11.98	55.68	1.72	17.29	10.74	0.99	81807.71
11	12.53	12.13	53.42	1.99	16.25	10.87	0.99	80213.40
12	7.02	12.00	52.33	1.60	16.93	10.72	0.99	80120.66
13	8.99	12.32	48.09	2.30	16.42	10.96	0.99	79079.58
14	11.10	12.69	59.08	2.26	16.81	10.99	1.01	79850.03
15	9.50	11.99	49.57	2.47	17.01	10.74	1.01	81785.44
16	6.58	11.89	55.04	2.11	17.47	10.40	1.00	81735.28
17	11.94	12.02	56.31	2.57	16.96	10.67	1.00	80194.82
18	5.63	11.81	57.88	1.16	17.99	10.48	0.98	80418.60
19	13.49	12.45	57.58	1.93	17.24	11.04	0.97	79135.36
20	6.68	11.95	54.99	0.98	18.66	10.48	0.99	83363.40
21	12.96	12.13	48.80	1.43	18.12	10.41	1.00	83280.86
22	6.14	12.01	43.59	1.45	17.67	10.60	0.99	78148.80
23	10.71	12.22	44.83	0.48	19.71	9.87	0.99	81657.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.32	12.11	53.92	1.87	17.17	10.75	0.98	81075.17
最大值	13.49	12.69	65.64	2.69	19.71	11.15	1.02	84849.42
發生時間	19	14	5	4	23	1		3
最小值	5.63	11.77	42.71	0.48	15.47	9.87	0.94	77911.66
發生時間	18	0	0	23	5	23		1
零點偏移(率)	-0.62 %	-0.00 %	-0.12 %	-0.00 %		0.00	-0.01	-0.10 %
全幅偏移(率)	0.49 %	-0.69 %	1.88 %	-0.11 %		0.12	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.97	11.18	53.39	3.06	19.13	9.63	1.30	78317.05
1	2.12	12.78	60.96	2.72	18.38	11.14	1.30	68500.09
2	2.08	11.38	45.36	2.48	19.01	9.40	1.30	77545.46
3	2.76	11.60	59.95	2.34	16.90	10.11	1.30	74830.72
4	2.20	12.29	50.31	2.23	16.38	9.73	1.27	75121.46
5	3.43	11.91	61.97	2.51	15.47	10.10	1.27	75811.58
6	2.94	11.59	61.74	2.37	16.52	9.93	1.27	76534.02
7	3.27	11.36	51.01	2.77	16.66	10.15	1.30	80839.65
8	3.48	11.45	59.70	2.74	17.86	10.11	1.34	76433.95
9	2.43	11.66	50.12	2.66	18.14	9.81	1.31	76225.44
10	4.41	11.51	56.23	2.87	16.76	10.08	1.31	74445.92
11	3.64	11.41	59.15	2.67	16.92	10.17	1.32	74110.11
12	2.33	12.07	60.44	2.67	16.83	10.47	1.28	71794.68
13	2.71	11.49	57.75	2.60	17.95	10.12	1.31	74671.03
14	2.57	11.58	51.04	2.43	17.23	10.28	1.31	74172.13
15	4.71	11.43	57.98	2.74	17.37	10.11	1.29	75732.35
16	4.03	11.37	56.21	2.69	17.80	10.03	1.28	75780.20
17	3.26	11.27	50.84	2.52	18.29	9.58	1.27	76240.28
18	4.40	11.26	49.75	2.65	18.29	9.55	1.29	75918.61
19	3.60	11.26	60.80	2.86	19.55	9.70	1.28	74370.61
20	3.64	10.87	50.42	2.69	19.42	9.23	1.30	78337.20
21	4.08	12.42	46.43	2.82	18.88	9.34	1.31	78460.45
22	5.33	11.03	55.41	2.73	18.18	9.65	1.31	74532.77
23	4.94	11.16	49.66	2.70	18.21	9.26	1.31	75205.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.35	11.56	54.86	2.65	17.76	9.90	1.30	75580.48
最大值	5.33	12.78	61.97	3.06	19.55	11.14	1.36	80839.65
發生時間	22	1	5	0	19	1		7
最小值	1.97	10.87	45.36	2.23	15.47	9.23	1.27	68500.09
發生時間	0	20	2	4	5	20		1
零點偏移(率)	-0.07 %	-0.00 %	-0.52 %	0.00 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	2.59 %	-0.15 %	1.81 %	0.01 %		0.14	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								