

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月20日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	2.49	11.19	58.17	0.49	17.21	12.15	1.06	76119.56
1	6.29	7.46	55.57	0.57	19.71	10.21	1.03	90069.88
2	8.57	5.16	37.30	2.64	14.53	12.38	1.02	76768.80
3	9.52	5.82	46.55	0.98	16.96	11.74	1.00	80267.06
4	8.80	8.87	34.22	1.88	15.17	11.93	0.97	79982.64
5	11.33	5.74	53.52	0.73	17.28	11.44	0.95	84740.15
6	9.82	6.77	32.19	0.85	17.64	11.30	0.95	83310.34
7	8.50	6.12	38.41	1.44	16.23	11.82	0.95	80414.46
8	10.67	3.79	53.38	0.97	17.40	11.92	0.96	79359.24
9	9.81	3.73	43.71	1.33	16.57	11.82	0.97	81970.34
10	8.57	5.84	44.44	1.15	15.41	12.20	0.99	79960.35
11	9.30	3.66	51.50	0.77	16.11	12.25	0.97	78344.83
12	9.92	4.67	49.08	2.18	14.62	12.35	0.98	80120.11
13	8.11	3.94	65.35	0.97	16.12	12.51	0.99	77169.83
14	10.02	3.59	56.56	0.26	17.42	11.68	0.99	82130.34
15	9.32	4.64	51.20	0.89	15.37	11.85	0.98	82229.81
16	9.67	10.13	38.87	1.66	15.29	11.64	0.97	83052.81
17	9.85	3.90	37.99	2.34	14.62	12.07	0.98	77566.17
18	9.02	4.42	52.40	0.97	17.12	11.76	1.02	80332.03
19	9.71	7.06	45.00	0.48	17.74	11.26	1.01	84838.35
20	9.41	6.95	41.81	0.46	18.25	10.89	0.99	87016.13
21	7.95	7.45	52.26	0.62	17.21	11.88	0.99	79580.20
22	8.95	7.16	58.29	0.48	16.62	12.09	1.01	78103.40
23	7.19	9.71	57.33	1.21	15.52	13.11	1.02	69724.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.87	6.16	48.13	1.10	16.50	11.84	0.99	80548.80
最 大 值	11.33	11.19	65.35	2.64	19.71	13.11	1.10	90069.88
發生時間	5	0	13	2	1	23		1
最 小 值	2.49	3.59	32.19	0.26	14.53	10.21	0.94	69724.26
發生時間	0	14	6	14	2	1		23
零點偏移(率)	-0.12 %	-0.05 %	-0.01 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	0.02 %	-0.01 %	0.02 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.28	6.57	42.15	1.05	17.90	10.85	1.07	80831.29
1	0.14	8.28	34.56	1.51	17.50	11.43	1.06	75821.05
2	1.01	7.25	38.36	1.84	16.09	11.22	1.06	79451.57
3	1.36	8.35	42.45	2.53	15.20	11.11	1.05	80580.00
4	4.53	2.42	44.24	2.75	14.92	11.23	1.04	80824.60
5	7.63	3.82	60.01	1.48	17.27	10.71	1.04	82678.00
6	5.37	1.64	48.64	2.42	14.93	11.25	1.02	84579.18
7	5.95	4.93	48.16	1.99	16.11	11.03	1.03	80917.58
8	8.91	1.89	44.57	1.86	16.00	11.10	1.02	79854.54
9	7.32	2.16	45.94	1.82	15.88	11.47	1.03	77219.72
10	7.36	2.24	37.21	1.62	17.20	10.86	1.06	81122.18
11	3.37	2.44	42.83	1.26	17.31	11.01	1.05	79794.15
12	2.11	2.46	46.11	1.38	15.91	11.55	1.06	76518.24
13	8.87	2.48	44.30	1.67	16.46	10.99	1.06	81010.65
14	7.43	5.89	44.61	2.51	15.79	10.84	1.11	81606.09
15	9.74	2.38	50.72	3.78	12.93	11.54	1.07	79670.78
16	8.21	1.98	47.86	3.18	13.63	11.50	1.06	78303.28
17	8.82	3.14	41.24	3.15	13.51	11.78	1.05	76535.54
18	4.11	4.99	46.27	2.27	15.42	11.76	1.05	75411.29
19	8.70	11.17	57.72	2.41	16.26	11.18	1.06	79162.96
20	9.46	2.12	43.49	3.04	13.90	11.17	1.03	80596.12
21	10.43	4.36	37.55	2.80	14.94	10.97	1.03	81828.23
22	9.11	3.11	42.52	2.31	15.03	11.34	1.04	78494.54
23	8.50	3.53	49.50	2.01	15.62	12.04	1.06	72941.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.24	4.15	45.04	2.19	15.65	11.25	1.05	79406.39
最 大 值	10.43	11.17	60.01	3.78	17.90	12.04	1.13	84579.18
發生時間	21	19	5	15	0	23		6
最 小 值	0.14	1.64	34.56	1.05	12.93	10.71	1.02	72941.87
發生時間	1	6	1	0	15	5		23
零點偏移(率)	-0.08 %	-0.11 %	-0.02 %	0.00 %		0.04		-0.20 %
全幅偏移(率)	0.02 %	0.19 %	-0.03 %	0.31 %		-0.03		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月20日

[illegible]