

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.28	11.79	52.30	2.46	16.64	11.40	1.25	81055.30
1	14.88	11.57	57.56	3.06	18.10	11.21	1.25	81548.63
2	7.08	11.69	52.96	3.48	16.60	11.48	1.25	80566.35
3	8.59	11.59	56.98	3.44	17.62	11.22	1.25	81929.87
4	15.51	11.83	55.94	3.92	16.84	11.59	1.25	79737.91
5	11.93	13.33	56.66	2.81	16.65	11.67	1.25	80315.78
6	9.87	12.96	53.79	1.93	17.07	11.45	1.25	80320.86
7	7.91	13.38	52.16	2.02	16.12	11.81	1.25	78252.39
8	10.41	14.19	58.28	2.33	15.48	12.45	1.25	73572.95
9	9.06	13.03	60.72	1.58	17.73	11.43	1.25	80238.19
10	7.78	12.82	64.64	1.58	18.13	11.15	1.25	81869.84
11	10.66	13.23	57.86	2.24	17.48	10.60	1.25	86205.75
12	9.36	12.48	46.67	1.58	17.16	10.79	1.24	85985.14
13	7.43	13.15	37.42	1.55	16.85	10.93	1.23	84909.64
14	9.43	13.43	37.52	1.22	18.29	10.43	1.23	87527.56
15	8.57	12.69	36.40	1.45	16.90	11.06	1.23	83955.01
16	8.34	12.57	43.23	1.26	17.35	11.12	1.24	83345.09
17	9.97	16.27	43.01	2.66	17.71	10.57	1.24	86477.01
18	7.66	13.08	39.63	1.26	18.00	10.94	1.24	83095.45
19	8.97	12.51	48.47	1.12	18.84	10.61	1.25	83533.88
20	8.81	12.11	46.59	1.20	18.72	10.53	1.25	84265.71
21	8.21	13.36	43.51	1.34	16.93	11.58	1.25	78845.46
22	10.89	15.36	41.31	1.41	18.78	10.69	1.25	84753.60
23	7.86	14.41	47.73	0.97	19.58	10.99	1.25	81009.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.39	13.03	49.64	1.99	17.48	11.15	1.25	82221.52
最大值	15.51	16.27	64.64	3.92	19.58	12.45	1.26	87527.56
發生時間	4	17	10	4	23	8		14
最小值	6.28	11.57	36.40	0.97	15.48	10.43	1.20	73572.95
發生時間	0	1	15	23	8	14		8
零點偏移(率)	-0.02 %	-0.06 %	-0.02 %	0.00 %		0.01	-0.01	0.10 %
全幅偏移(率)	-2.02 %	-0.00 %	-0.14 %	-0.02 %		-0.18	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.49	12.28	43.74	1.81	18.41	10.82	1.02	82188.59
1	7.12	12.27	40.11	1.95	18.85	10.76	1.02	82899.33
2	12.83	12.23	43.01	1.98	19.17	10.67	1.02	83474.86
3	5.43	12.54	38.03	1.12	19.52	10.50	1.02	85174.41
4	12.11	12.13	42.10	1.36	19.22	10.57	1.02	84013.97
5	12.75	14.06	40.64	1.62	19.38	10.67	1.02	83600.20
6	8.46	13.45	39.76	1.29	19.70	10.53	1.05	85859.84
7	10.30	13.41	51.17	2.34	17.57	11.18	1.07	80724.90
8	10.59	13.31	55.60	2.47	17.09	11.82	1.04	75754.87
9	6.20	12.33	51.42	1.51	18.15	10.98	1.04	82290.76
10	8.92	11.90	51.04	1.26	18.32	10.61	1.04	85202.15
11	9.17	12.08	54.06	1.66	18.02	10.77	1.04	83689.62
12	2.83	12.24	53.27	0.71	18.42	10.55	1.04	85293.79
13	3.77	12.55	53.56	0.40	19.81	10.84	1.03	81077.85
14	7.63	11.69	45.15	0.81	20.53	9.52	1.02	91533.74
15	2.87	10.84	51.47	1.54	18.93	9.96	1.02	88769.76
16	5.31	12.42	44.28	0.99	17.72	10.49	1.02	85975.79
17	3.74	11.94	59.73	1.37	18.27	10.57	1.03	84896.78
18	6.68	12.39	61.45	1.08	20.01	10.15	1.04	86354.44
19	5.24	11.99	48.00	0.82	20.60	10.05	1.04	86096.42
20	9.54	12.02	56.69	1.54	18.70	10.18	1.03	86806.55
21	8.94	12.22	61.30	2.26	18.13	10.76	1.02	82749.59
22	9.30	12.55	55.90	0.94	19.36	11.01	1.03	79610.20
23	4.81	12.72	50.78	0.80	19.62	11.08	1.04	78640.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.63	12.40	49.68	1.40	18.90	10.63	1.03	83861.64
最大值	12.83	14.06	61.45	2.47	20.60	11.82	1.10	91533.74
發生時間	2	5	18	8	19	8		14
最小值	2.83	10.84	38.03	0.40	17.09	9.52	1.02	75754.87
發生時間	12	15	3	13	8	14		8
零點偏移(率)	-0.13 %	-0.00 %	-0.04 %	-0.01 %		-0.03	-0.01	-0.10 %
全幅偏移(率)	-0.87 %	-1.74 %	1.23 %	0.35 %		-0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

