

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.73	8.93	58.78	1.17	19.82	11.24	1.02	78828.58
1	8.37	9.60	53.05	1.41	20.46	10.77	1.05	81595.40
2	8.82	11.47	51.13	2.45	18.82	11.08	1.04	80710.31
3	5.01	11.91	62.22	1.66	17.88	12.00	1.03	74625.37
4	8.11	7.10	63.93	1.65	19.06	11.33	1.02	79099.35
5	6.87	10.38	44.66	1.93	18.79	10.88	1.00	80851.60
6	9.84	7.12	37.83	3.61	16.62	11.28	1.00	79401.26
7	9.14	8.69	49.41	2.95	17.48	11.61	1.00	77422.17
8	7.14	8.35	47.81	1.68	19.64	11.14	1.00	79483.17
9	3.55	7.51	53.76	1.35	18.49	11.44	1.04	76965.07
10	4.27	7.27	44.15	2.20	16.88	11.52	1.01	74083.00
11	4.73	7.15	53.06	1.81	18.08	11.26	0.99	77958.58
12	7.38	9.71	44.02	2.65	16.80	11.78	1.00	74118.51
13	3.87	7.46	66.22	1.68	17.62	12.06	1.02	72738.82
14	7.26	10.12	60.68	2.40	16.59	12.18	0.99	71017.19
15	5.63	7.99	63.82	1.38	17.76	11.68	1.04	76440.31
16	9.02	9.67	54.73	2.25	18.14	11.20	1.05	80462.68
17	7.78	9.53	54.39	1.70	18.83	11.20	1.05	80326.43
18	7.97	12.63	54.10	2.06	17.80	11.49	1.05	78720.22
19	8.04	12.47	50.78	2.30	17.18	11.56	1.04	78696.86
20	10.77	11.46	49.98	3.25	15.83	11.85	1.04	77334.65
21	9.05	10.15	59.47	2.44	17.65	11.48	1.05	79082.71
22	6.01	10.98	51.59	2.05	17.10	11.72	1.05	76988.99
23	6.44	11.27	57.69	1.80	18.41	11.55	1.05	77668.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.12	9.54	53.64	2.08	17.99	11.47	1.03	77692.47
最大值	10.77	12.63	66.22	3.61	20.46	12.18	1.06	81595.40
發生時間	20	18	13	6	1	14		1
最小值	3.55	7.10	37.83	1.17	15.83	10.77	0.97	71017.19
發生時間	9	4	6	0	20	1		14
零點偏移(率)	-0.41 %	-0.04 %	-0.01 %	-0.01 %		0.02		0.00 %
全幅偏移(率)	-1.12 %	0.14 %	0.07 %	0.25 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.80	5.10	45.86	1.12	19.66	10.35	1.01	83526.77
1	1.39	4.55	41.71	1.59	20.82	9.97	1.02	85372.27
2	1.14	7.69	50.44	2.27	17.73	10.53	1.03	83849.90
3	2.19	5.87	52.59	1.42	19.65	10.16	1.02	85164.41
4	6.64	6.59	47.45	2.27	18.61	10.36	1.02	84694.32
5	9.37	6.16	43.45	2.84	17.48	10.37	1.02	86300.27
6	6.58	7.05	48.67	2.02	16.86	10.70	1.00	86224.57
7	8.18	6.92	45.93	1.63	18.54	10.19	1.00	86084.18
8	3.33	3.09	43.80	0.77	20.69	9.68	0.99	87416.99
9	3.54	1.73	54.86	1.86	17.81	10.11	0.99	86581.75
10	5.86	2.16	51.07	1.76	17.98	10.31	0.99	85152.13
11	8.33	2.01	49.66	2.08	18.87	9.94	0.99	87277.73
12	3.68	3.28	52.54	2.25	17.23	10.41	0.99	84958.02
13	1.28	4.01	59.49	1.60	17.50	10.70	0.99	82651.31
14	1.13	2.65	56.02	1.73	17.44	10.63	0.96	82877.43
15	4.58	12.85	47.90	2.60	17.26	10.32	0.96	85305.22
16	7.25	5.50	54.03	1.85	17.83	10.39	0.97	85546.80
17	7.39	4.19	51.55	2.22	17.92	10.16	0.98	86584.41
18	6.47	6.46	55.57	1.35	18.32	9.91	0.97	87100.88
19	9.06	9.89	48.44	2.23	16.17	10.19	0.98	82777.38
20	7.60	7.25	49.66	1.91	16.41	10.13	0.98	82534.53
21	3.83	7.08	56.08	1.64	16.87	10.27	0.97	83718.49
22	1.83	7.47	50.10	1.59	17.06	10.29	0.96	85133.51
23	0.26	7.59	54.64	1.40	17.70	10.35	0.97	85590.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.65	5.71	50.48	1.83	18.02	10.27	0.99	85100.98
最大值	9.37	12.85	59.49	2.84	20.82	10.70	1.04	87416.99
發生時間	5	15	13	5	1	6		8
最小值	0.26	1.73	41.71	0.77	16.17	9.68	0.94	82534.53
發生時間	23	9	1	8	19	8		20
零點偏移(率)	-0.04 %	0.00 %	0.00 %	0.00 %		0.00		-0.20 %
全幅偏移(率)	0.04 %	0.22 %	0.23 %	0.18 %		-0.19		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.00	5.00	56.24	1.36	18.31	10.66	0.99	78303.24
1	7.85	9.05	50.86	1.57	18.32	10.59	0.99	79899.95
2	9.65	8.60	54.56	3.24	14.72	10.93	0.99	76193.75
3	8.03	7.99	55.14	2.52	15.63	10.76	0.99	77349.54
4	8.13	8.93	57.33	2.43	16.04	10.87	0.99	78121.59
5	9.01	7.65	46.53	2.40	15.03	10.71	0.99	77886.59
6	9.49	8.68	50.80	2.72	14.61	10.74	0.98	73621.49
7	8.22	7.30	55.85	2.74	14.05	11.24	0.98	71271.59
8	5.54	4.31	53.09	1.53	16.99	10.79	1.02	78882.77
9	7.86	3.38	53.74	1.68	17.45	10.47	0.98	82128.01
10	5.05	3.22	53.21	1.57	16.67	10.73	1.00	80181.17
11	3.17	3.34	56.05	1.53	16.28	10.85	1.02	79333.11
12	7.84	3.92	52.63	2.08	15.93	10.85	0.98	78353.68
13	7.08	4.39	66.75	1.85	16.57	11.21	0.97	74114.26
14	7.26	4.94	54.46	1.94	15.69	11.29	0.96	71910.98
15	6.71	5.70	51.70	1.89	16.46	10.71	0.97	76198.27
16	8.46	5.24	53.82	2.22	17.63	9.96	0.97	81379.60
17	7.11	9.29	46.92	1.86	17.03	10.29	0.97	79408.58
18	7.28	8.54	49.74	1.96	15.44	10.74	0.97	76730.90
19	7.03	10.84	50.51	2.17	15.11	10.70	0.97	76743.74
20	5.89	8.55	55.02	2.00	14.81	11.18	0.97	74989.57
21	7.85	9.10	51.65	2.65	14.60	10.90	1.00	77627.68
22	8.49	7.17	48.09	2.67	14.14	10.99	0.99	75293.13
23	8.26	7.31	52.78	1.76	16.51	10.49	0.99	77429.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.39	6.77	53.23	2.10	16.00	10.78	0.98	77223.02
最大值	9.65	10.84	66.75	3.24	18.32	11.29	1.05	82128.01
發生時間	2	19	13	2	1	14		9
最小值	3.17	3.22	46.53	1.36	14.05	9.96	0.94	71271.59
發生時間	11	10	5	0	7	16		7
零點偏移(率)	-0.10 %	0.00 %	-0.01 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	0.14 %	-0.87 %	0.02 %		0.17		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								