

報表日期: 115年01月06日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.43	11.02	44.74	2.17	16.18	9.94	1.36	73431.46
1	9.47	11.63	49.15	1.96	18.31	10.17	1.38	72435.48
2	9.69	11.20	38.79	2.24	16.91	9.68	1.38	76908.36
3	9.86	11.54	45.61	2.12	16.21	10.16	1.36	73667.66
4	8.52	12.35	56.74	2.49	15.26	11.14	1.36	67421.52
5	5.90	13.39	44.44	2.17	15.69	11.79	1.37	67549.17
6	8.58	11.91	60.19	2.17	15.65	10.80	1.37	76935.44
7	7.11	11.81	54.68	2.58	14.85	10.89	1.36	71916.94
8	8.71	12.74	58.40	3.56	13.34	11.59	1.36	73436.94
9	4.62	12.67	50.17	3.06	14.13	11.20	1.36	74329.78
10	5.91	12.65	51.52	3.46	14.15	11.27	1.36	74185.76
11	7.75	12.42	56.58	2.11	16.62	11.21	1.36	76362.28
12	5.92	12.57	53.86	2.48	14.83	11.52	1.36	73715.86
13	6.28	12.52	53.89	2.61	14.80	11.42	1.36	73958.65
14	7.12	12.70	54.34	2.96	14.25	11.68	1.37	73776.04
15	6.36	13.40	43.49	3.54	14.15	11.32	1.37	74671.91
16	6.72	13.67	29.29	2.48	15.36	10.18	1.36	76072.52
17	8.98	13.98	27.67	1.43	15.43	9.97	1.34	72890.52
18	8.24	5.21	31.16	1.18	16.64	8.99	1.34	75023.85
19	7.56	10.88	55.40	1.03	19.05	9.02	1.34	76937.50
20	8.84	11.82	47.36	1.26	16.95	9.37	1.36	78123.18
21	11.79	12.31	42.89	1.51	15.78	9.69	1.36	72769.53
22	13.27	11.64	48.82	1.44	17.22	9.23	1.36	74606.62
23	8.64	11.04	48.90	1.01	17.29	9.41	1.36	74916.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.14	11.96	47.84	2.21	15.79	10.49	1.36	74001.81
最 大 值	13.27	13.98	60.19	3.56	19.05	11.79	1.40	78123.18
發生時間	22	17	6	8	19	5		20
最 小 值	4.62	5.21	27.67	1.01	13.34	8.99	1.32	67421.52
發生時間	9	18	17	23	8	18		4
零點偏移(率)	-0.04 %	-0.03 %	-0.03 %	-0.01 %		-0.05	-0.01	0.00 %
全幅偏移(率)	0.10 %	-1.66 %	0.52 %	-0.47 %		0.16	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								