

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.09	4.22	62.99	1.79	16.84	12.54	1.43	66555.89
1	1.69	5.73	60.70	2.28	15.21	12.24	1.46	69523.19
2	5.29	3.45	53.63	2.16	15.70	12.06	1.40	70922.97
3	5.08	3.72	55.74	2.00	16.26	12.07	1.39	70393.05
4	4.69	3.72	58.95	2.42	14.58	12.28	1.39	70258.64
5	3.20	4.58	65.55	2.27	14.87	12.44	1.42	68744.83
6	2.39	8.03	52.10	3.41	13.31	13.12	1.41	64770.28
7	5.17	3.32	43.19	2.46	14.92	12.17	1.40	71012.83
8	5.95	5.16	46.36	3.01	14.01	12.62	1.43	68312.01
9	1.78	4.09	47.83	2.49	14.58	12.70	1.44	67266.34
10	4.24	3.49	36.82	2.58	14.51	12.05	1.46	71519.19
11	7.64	6.78	39.67	3.58	12.98	12.49	1.45	69676.38
12	8.40	9.56	39.99	4.43	12.81	12.51	1.46	69179.24
13	3.12	6.07	39.24	3.50	13.26	12.45	1.42	69513.25
14	0.16	3.07	51.52	2.62	14.05	12.61	1.45	68091.88
15	2.18	3.29	38.36	2.56	14.28	12.17	1.45	70786.11
16	6.89	2.82	55.76	2.34	15.06	12.37	1.47	68977.70
17	11.09	2.52	51.22	2.89	14.29	12.24	1.46	69897.08
18	9.20	3.36	35.18	3.56	13.46	12.47	1.47	69017.40
19	7.29	3.28	42.65	3.04	13.97	12.55	1.44	68086.56
20	8.82	4.36	38.40	3.62	13.33	12.58	1.41	68314.13
21	10.54	4.04	43.29	3.70	13.14	12.66	1.46	67676.34
22	7.98	5.48	41.89	3.58	13.19	12.68	1.45	67873.47
23	10.53	10.79	32.90	4.73	12.35	12.76	1.40	67457.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.56	4.79	47.25	2.96	14.21	12.45	1.43	68909.44
最大值	11.09	10.79	65.55	4.73	16.84	13.12	1.60	71519.19
發生時間	17	23	5	23	0	6		10
最小值	0.09	2.52	32.90	1.79	12.35	12.05	1.39	64770.28
發生時間	0	17	23	0	23	10		6
零點偏移(率)	-0.03 %	-0.02 %	-0.02 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	-0.86 %	0.10 %	-0.31 %	0.02 %		0.26	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.49	1.86	47.46	1.26	17.86	10.47	1.37	82532.25
1	4.36	1.79	47.31	1.17	18.59	10.30	1.40	86491.22
2	6.90	2.31	44.77	1.24	18.80	9.97	1.43	88509.35
3	8.46	6.66	51.30	1.58	19.20	10.18	1.42	85976.90
4	5.51	8.07	41.88	2.37	15.36	10.36	1.39	79873.73
5	7.88	4.21	43.14	2.48	15.14	10.90	1.38	82445.29
6	7.66	7.93	45.08	2.38	14.96	10.86	1.41	82001.00
7	10.25	5.18	45.82	2.44	15.67	10.87	1.41	84204.63
8	10.93	7.41	44.78	2.69	14.78	10.79	1.44	79105.46
9	8.85	3.52	56.71	2.19	16.72	10.63	1.41	83674.41
10	5.20	3.93	41.72	2.03	15.05	10.74	1.40	79815.04
11	8.70	5.01	40.27	2.50	14.81	10.41	1.42	76923.26
12	8.87	4.75	45.01	2.34	14.87	10.74	1.38	77971.31
13	9.51	5.19	39.95	2.51	15.20	10.64	1.38	78368.50
14	9.34	3.69	45.19	2.61	15.18	10.78	1.38	79526.60
15	10.35	3.87	44.60	2.25	16.99	10.45	1.37	81334.07
16	9.44	5.05	43.25	3.00	15.23	10.75	1.38	81316.50
17	7.38	5.81	44.63	2.77	14.63	10.58	1.41	78175.24
18	8.66	4.14	46.94	2.62	16.75	10.18	1.43	81012.56
19	9.46	3.77	41.32	2.31	17.31	10.29	1.39	81577.74
20	10.01	4.28	44.70	2.39	16.00	10.55	1.38	79205.50
21	11.13	4.77	49.71	2.90	15.40	10.59	1.41	80582.45
22	9.91	4.01	48.25	2.46	15.52	10.71	1.42	80358.06
23	10.77	4.04	48.34	2.64	16.48	10.64	1.39	82850.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.42	4.64	45.51	2.30	16.10	10.56	1.40	81409.64
最大值	11.13	8.07	56.71	3.00	19.20	10.90	1.45	88509.35
發生時間	21	4	9	16	3	5		2
最小值	2.49	1.79	39.95	1.17	14.63	9.97	1.36	76923.26
發生時間	0	1	13	1	17	2		11
零點偏移(率)	-0.38 %	-0.04 %	-0.00 %	-0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	0.33 %	-0.01 %	-0.26 %	0.03 %		0.20	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.46	2.45	59.65	0.89	17.47	10.34	1.74	89087.65
1	1.85	3.66	46.28	0.79	16.89	10.69	1.77	86601.77
2	1.26	2.36	52.04	0.83	16.89	10.94	1.77	84654.58
3	0.42	4.93	54.96	0.93	17.42	10.88	1.75	84598.23
4	1.08	3.59	54.65	1.23	15.31	11.05	1.75	84934.41
5	3.52	12.77	54.53	4.53	12.52	11.61	1.73	82260.86
6	4.28	8.06	52.26	2.17	14.08	11.05	1.72	85941.43
7	4.51	3.17	58.26	2.00	14.45	11.13	1.79	89965.12
8	7.99	5.20	53.51	2.34	14.00	11.29	1.81	82094.79
9	3.74	3.40	53.20	1.66	14.80	11.11	1.81	81587.00
10	4.21	3.91	54.17	1.92	14.12	11.43	1.84	81272.71
11	6.12	4.79	54.20	2.80	13.15	11.55	1.82	78632.27
12	4.29	5.38	52.09	2.62	12.83	11.44	1.84	79578.88
13	4.16	4.44	51.62	2.06	14.22	11.09	1.81	78411.89
14	2.75	3.76	50.85	2.12	13.63	11.26	1.82	78843.89
15	5.77	4.33	66.45	2.01	15.09	11.51	1.82	77855.40
16	7.76	4.16	65.40	1.78	15.96	11.08	1.83	82320.63
17	6.60	6.16	46.37	2.11	14.27	10.92	1.82	80560.12
18	2.91	4.57	51.84	1.20	15.95	10.72	1.81	80894.49
19	1.83	3.50	56.32	1.45	14.78	11.32	1.80	79857.69
20	2.10	4.33	53.80	1.61	14.95	11.21	1.82	81534.93
21	5.59	7.36	48.36	2.36	14.02	11.18	1.80	80804.65
22	9.59	6.14	54.92	2.93	13.67	11.42	1.79	78445.84
23	10.29	3.96	59.49	2.14	15.26	11.10	1.78	83182.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.34	4.85	54.38	1.94	14.82	11.14	1.79	82246.75
最大值	10.29	12.77	66.45	4.53	17.47	11.61	1.85	89965.12
發生時間	23	5	15	5	0	5		7
最小值	0.42	2.36	46.28	0.79	12.52	10.34	1.72	77855.40
發生時間	3	2	1	1	5	0		15
零點偏移(率)	-0.02 %	-0.04 %	-0.02 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	0.07 %	0.58 %	-0.37 %	-0.00 %		0.15	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								